

# **AMCA Publication 211-13**

## **(Rev. 09-17)**

### **Certified Ratings Program**

### **Product Rating Manual for Fan Air Performance**

---



Air Movement and Control Association International  
30 West University Drive  
Arlington Heights, Illinois  
60004

## AMCA Publications

**Authority** AMCA Publication 211-13 (Rev. 09-17) was adopted by the membership of the Air Movement and Control Association International Inc. on September 6, 2016.

**Copyright** © 2013 by the Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.

**Objections** The Air Movement and Control Association (AMCA) International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to

AMCA International  
30 West University Drive  
Arlington Heights, IL 60004-1893 U.S.A.

European AMCA  
Avenue des Arts, numéro 46  
à Bruxelles (1000 Bruxelles)

Asia AMCA Sdn Bhd  
No. 7, Jalan SiLC 1/6,  
Kawasan Perindustrian SiLC Nusajaya,  
Mukim Jelutong, 79200 Nusajaya, Johor  
Malaysia

**Disclaimer** AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

## Review Committee

Thomas Gustafson	Hartzell Air Movement Committee Chair
John Cermak	Acme Engineering and Manufacturing Corporation
Abishek Jain	Air Flow PVT. LTD.
Tim Sutton	Carnam Ltd.
Franco Cincotti	Comefri USA Inc.
Armin Hauer	ebm-papst Inc.
Fernando Ruiz	Contreras Equipos Electromecanicos, S.A. de C.V.
Scott Kurszewski	Greenheck Fan Corporation
Kim Osborn	Governair LLC
Michael Brendel	Lau Industries Inc.
Keith Lins	M. K. Plastics Corporation
Hesham Morten Gabr	Multi-Wing
Andy Timm	New York Blower
Rad Ganesh	Twin City Fan
Yong Ning Chen	Zhejiang Yilida Ventilator Co. Ltd.
Florian Braun	Ziehl-Abegg Inc.
Joe Brooks	AMCA International

# Contents

<b>Certified Ratings Program—Product Rating Manual for Fan Air Performance .....</b>	<b>1</b>
<b>1. Purpose and Scope.....</b>	<b>1</b>
<b>2. Normative References.....</b>	<b>1</b>
<b>3. Definitions .....</b>	<b>1</b>
3.1 Appurtenance (accessory).....	1
3.2 AMCA Certified Ratings Program air performance .....	1
3.3 Performance rating(s).....	1
3.4 Shall and should .....	2
3.5 Constant speed.....	2
3.6 As-run speed.....	2
3.7 Fan efficiency grade (FEG) .....	2
3.8 Single room air handler .....	2
3.9 Axial Impeller .....	2
<b>4. Data Submittal Requirements .....</b>	<b>2</b>
<b>5. Drive Methods.....</b>	<b>2</b>
<b>6. Ducted Inlet Simulation.....</b>	<b>3</b>
<b>7. Catalog Requirements .....</b>	<b>3</b>
7.1 Scope of certification .....	3
7.2 Statement required adjacent to the seal .....	3
7.3 Application statements.....	3
7.4 Noncertified efficiency, FEG and/or sound ratings .....	3
7.5 The AMCA Certified Ratings Program seals .....	4
<b>8. Fan Performance Ratings.....</b>	<b>4</b>
8.1 Manufacturer's responsibility .....	4
8.2 AMCA staff's responsibility.....	4
8.3 Rating development.....	5
8.4 Catalog data .....	7
<b>9. Rating Method Details .....</b>	<b>7</b>
9.1 Rating method A/B/D: centrifugal mixed flow axial, propeller fans, power roof ventilator, energy recovery ventilator, and axial impellers (constant speed rating method) .....	7
9.2 Rating method C/E: centrifugal, mixed flow, axial, propeller fans, power roof ventilator, energy recovery ventilator, axial impellers, and single room air handlers (as-run speed rating method).....	8
9.3 Rating method F: centrifugal, mixed flow, axial, propeller fans, power roof ventilator, energy recovery ventilator, axial impellers, and single room air handlers.....	9
9.4 Rating method G: air curtains .....	10
9.5 Rating method H: jet tunnel fans .....	12
9.6 Rating method I: agricultural fans .....	12
9.7 Rating method J: positive pressure ventilators.....	13
9.8 Rating method K: circulating fans .....	14
9.9 Rating method L: induced flow fans .....	14
9.10 Rating method M: residential ventilating fans .....	15

9.11 Rating method N: large diameter ceiling fans .....	17
<b>10. Check Tests .....</b>	<b>18</b>
10.1 Centrifugal fans, mixed flow, axial fans, propeller fans, power roof ventilators, agricultural fans, positive pressure ventilators and energy recovery ventilators .....	18
10.2 Air curtains .....	22
10.3 Jet tunnel fans .....	23
10.4 Circulating fans .....	23
10.5 Induced flow fans .....	23
<b>11. Product Rating Requirements for Centrifugal and Mixed Flow Fans .....</b>	<b>24</b>
11.1 Product configuration .....	24
11.2 Test conditions .....	24
11.3 Test data submittal requirements .....	25
<b>12. Product Rating Requirements for Axial Fans .....</b>	<b>25</b>
12.1 Product configuration .....	25
12.2 Test conditions .....	26
12.3 Test data submittal requirements .....	26
12.4 Precertification check tests .....	26
<b>13. Product Rating Requirements for Propeller Fans .....</b>	<b>26</b>
13.1 Product configuration .....	26
13.2 Test conditions .....	27
13.3 Test data submittal requirements .....	27
<b>14. Product Rating Requirements for Power Roof Ventilators .....</b>	<b>27</b>
14.1 Product configurations .....	27
14.2 Test conditions .....	28
14.3 Test data submittal requirements .....	28
14.4 Exhaust/supply units .....	28
<b>15. Product Rating Requirements for Jet Tunnel Fans .....</b>	<b>29</b>
15.1 Test setups .....	29
15.2 Product configuration .....	29
15.3 Test conditions .....	29
15.4 Test data submittal requirements .....	29
<b>16. Product Rating Requirements for Air Curtains .....</b>	<b>29</b>
16.1 Conformance to standards .....	29
16.2 Product configuration .....	30
16.3 Test conditions .....	30
<b>17. Product Rating Requirements for Agricultural Fans .....</b>	<b>31</b>
17.1 Product configuration .....	31
17.2 Catalog photographs or illustrations .....	31
17.3 Test conditions .....	31
17.4 Test data submittal requirements .....	32
17.5 Alternate motors .....	32
<b>18. Product Rating Requirements for Positive Pressure Ventilators .....</b>	<b>32</b>

18.1 Test setups.....	32
18.2 Product configuration.....	32
18.3 Catalog photographs or illustrations .....	33
18.4 Test conditions .....	33
18.5 Test data submittal requirements .....	33
18.6 Alternate motors/engines .....	33
<b>19. Product Rating Requirements for Energy Recovery Ventilators/Heat Recovery Ventilators .....</b>	<b>33</b>
19.1 Definitions .....	33
19.2 Test conditions .....	34
19.3 Catalog requirements .....	34
<b>20. Product Rating Requirements for Circulating Fans .....</b>	<b>35</b>
20.1 Test setups .....	35
20.2 Product configuration or examples of installation.....	35
20.3 Test conditions .....	35
20.4 Test data submittal requirements .....	36
<b>21. Product Rating Requirements for Induced Flow Fans .....</b>	<b>36</b>
21.1 Basic conditions.....	36
21.2 Test setups .....	36
21.3 Electric power requirements.....	36
21.4 Test data submittal requirements .....	36
<b>22. Product Rating Requirements for Ceiling Fans .....</b>	<b>36</b>
22.1 Test setups .....	36
22.2 Product configuration or examples of installation.....	36
<b>Annex A Dimensional Requirements (Normative) .....</b>	<b>38</b>
A.1 General requirements .....	38
<b>Annex B CRP Forms (Normative) .....</b>	<b>59</b>
<b>Annex C Electronic Catalogs (Normative) .....</b>	<b>64</b>
C.1 Introduction .....	64
C.2 Scope.....	64
C.3 Allowable performance modifications .....	64
C.4 Required qualifying statements .....	65
C.5 Certification of electronic performance data .....	67
C.6 Version numbers.....	67
C.7 Identifying certified performance.....	67
C.8 AMCA directory listings.....	67
<b>Annex D Guidelines for Development of Fan Performance Ratings (Informative).....</b>	<b>68</b>
D.1 Introduction .....	68
D.2 Similarity.....	68
D.3 Compressibility.....	68
D.4 Test fan sizes and test speeds .....	69
D.5 Power transmission losses .....	70
<b>Annex E Reference Material (Informative) .....</b>	<b>72</b>

This is a preview of "AMCA 211-13 (R2017)". [Click here to purchase the full version from the ANSI store.](#)

**Annex F Summary of Available Rating Methods (Informative)..... 73**

# Certified Ratings Program—Product Rating Manual for Fan Air Performance

## 1. Purpose and Scope

The purpose of this manual is to prescribe technical procedures to be used in connection with the AMCA Certified Ratings Program for fan air performance.

Products that can be licensed by AMCA to bear the AMCA certified ratings seal are those defined in ANSI/AMCA Standard 99, Section 0068; ISO 13349 and IEC 60335-2-80 and are within the product scope of AMCA International.

The program applies only to fans and axial impellers.

## 2. Normative References

AMCA Publication 11, Certified Ratings Program Operating Manual  
ANSI/AMCA Standard 99, Standards Handbook  
AMCA Publication 111, Laboratory Accreditation Program  
AMCA Publication 200, Air Systems  
ANSI/AMCA Standard 205, Energy Efficiency Classification for Fans  
ANSI/AMCA Standard 210, Laboratory Methods of Testing Fans for Certified Aerodynamic Performance  
ANSI/AMCA Standard 220, Laboratory Methods of Testing Air Curtain Units for Aerodynamic Performance Rating  
ANSI/AMCA Standard 230, Laboratory Methods of Testing Air Circulating Fans for Rating  
ANSI/AMCA Standard 240, Laboratory Methods of Testing Positive Pressure Ventilators for Aerodynamic Performance Rating  
ANSI/AMCA Standard 250, Laboratory Methods of Testing Jet Tunnel Fans for Performance  
ANSI/AMCA Standard 260, Laboratory Methods of Testing Induced Flow Fans for Rating  
AMCA Publication 311, Certified Ratings Program Product Rating Manual for Fan Sound Performance  
ISO 5801, Industrial Fans — Performance Testing Using Standardized Airways  
ISO 13350, Industrial Fans — Performance Testing of Jet Fans  
Appendix U to Subpart B of Part 430 — Uniform Test Method for Measuring the Energy Consumption of Ceiling Fans, 10 CFR Part 430, Subpart B — Test Procedures (including amendments published in the Energy Conservation Program: Test Procedures for Ceiling Fans; Final Rule, 81 FR 48619, July 25, 2016)  
IEC 62301, Ed. 2 2011-01, Household electrical appliances – Measurement of standby power

## 3. Definitions

All definitions in AMCA Publication 11, as well as the following, apply to this program.

### 3.1 Appurtenance (accessory)

Any item in or on the inlet or discharge airstream that affects the performance of the fan. An accessory/appurtenance is henceforth referred to as an appurtenance.

### 3.2 AMCA Certified Ratings Program air performance

A program for certifying a product's aerodynamic performance ratings, as defined in this document.

### 3.3 Performance rating(s)

A statement of the pressure performance and power versus airflow at a given speed at standard inlet air density or other specified density. Efficiency may also be included in the performance ratings at the option of the licensee. Power shall be