

AMCA Publication 511-10 (Rev. 2016)

Certified Ratings Program
Product Rating Manual for
Air Control Devices



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

AMCA Publication 511-10 (Rev. 2016)

Certified Ratings Program Product Rating Manual for Air Control Devices



Air Movement and Control Association International
30 West University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority AMCA Publication 511-10 (Rev. 2016) was adopted by the membership of the Air Movement and Control Association International Inc. on March 24, 2016.

The 2016 revision includes changes to the backdraft damper leakage section will allow manufacturers to show compliance with the new 2015 IECC and ASHRAE 90.1 - 2013 leakage requirements for non-motorized dampers. The proposal increases the number of samples required to be leakage tested from one to three.

Copyright © 2007 by Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International Inc. will consider and take action upon all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

European AMCA
Avenue des Arts, numéro 46
à Bruxelles (1000 Bruxelles)

Asia AMCA Sdn Bhd
No. 7, Jalan SiLC 1/6,
Kawasan Perindustrian SiLC Nusajaya,
Mukim Jelutong, 79200 Nusajaya, Johor
Malaysia

Disclaimer AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

Review Committee

Marty Gissel
Committee Chair

Greenheck Fan Company

Mike Steele

The Airlite Company, LLC

Jacob Carr

American Warming and Ventilation

Jeff Blake

Construction Specialties

Bin Ngo

Daniel Mechanic

Eric Gohring

Mestek Inc.

Michael J. Bulzomi

Nailor Industries Inc.

Matt Remington

Pottorff

Randal Geedey

Pottorff

Dan Huber

Ruskin Manufacturing Co.

Dane Carey

TAMCO Dampers

Jason Haley

Ventex Inc.

Tim Orris

AMCA International

Contents

AMCA Publications	2
Review Committee	3
1. Purpose	8
2. Scope	8
3. Definitions and Symbols	8
3.1 Definitions	8
3.2 Symbols	9
4. Data Submittal Requirements	9
5. Required Catalog Statements	10
5.1 Licensed product statement.....	10
5.2 Licensed performance statement.....	10
5.3 Appurtenances statement	10
6. General Guidelines for Air Control Products	10
6.1 Manufacturer’s responsibility	10
6.2 AMCA staff responsibility.....	10
6.3 Rating development	11
6.4 Aerodynamically similar products	11
6.5 Nameplated products	11
7. Check Test Tolerances and Required Tests	11
7.1 Licensee’s duty	11
7.2 Tolerances.....	11
7.3 Required tests.....	12
8. Louver Air Performance Rating Requirements	12
8.1 Testing requirements.....	12
8.2 Calculated performance	12
8.3 Published ratings.....	13
9. Louver Wind Driven Rain Rating Requirements	13
9.1 Testing requirements.....	13
9.2 Calculated performance	14
9.3 Published ratings.....	14
10. Louver Wind Driven Sand Rating Requirements	15
10.1 Testing requirements.....	15
10.2 Calculated performance	15
10.3 Published ratings.....	15
11. Louver Water Penetration Rating Requirements	16
11.1 Testing requirements.....	16
11.2 Calculated performance	16
11.3 Published ratings.....	17
12. Acoustical Louver Sound Performance Rating Requirements	18
12.1 Testing requirements.....	18
12.2 Calculated performance	18
12.3 Published ratings.....	19

13. Adjustable Louver Air Leakage Rating Requirements	19
13.1 Testing requirements.....	19
13.2 Calculated performance	19
13.3 Published ratings.....	19
14. Damper Air Performance Rating Requirements	20
14.1 Testing requirements.....	20
14.2 Calculated performance	21
14.3 Published ratings.....	21
15. Volume Control Damper Air Leakage Rating Requirements	21
15.1 Testing requirements.....	22
15.2 Calculated performance	22
15.3 Published ratings.....	22
16. Ultra-Low-Leakage Damper Air Leakage Rating Requirements	24
16.1 Testing requirements.....	24
16.2 Calculated performance	24
16.3 Published ratings.....	24
17. Bubble-Tight Damper Air Leakage Rating Requirements	25
17.1 Testing requirements.....	25
17.2 Calculated performance	25
17.3 Published ratings.....	26
18. UL-Classified Damper Air Leakage Rating Requirements	26
18.1 Testing requirements.....	26
18.2 Calculated performance	27
18.3 Published ratings.....	27
19. Backdraft Damper Air Leakage Rating Requirements	27
19.1 Testing requirements.....	27
19.2 Calculated performance	28
19.3 Published ratings.....	28
20. Gravity Ventilator (Excluding Louver Penthouses) Air Performance Rating Requirements	28
20.1 Testing requirements.....	29
20.2 Calculated performance	29
20.3 Published ratings.....	29
21. Round Spiral Duct Air Leakage Rating Requirements	31
21.1 Testing requirements.....	31
21.2 Calculated performance	31
21.3 Published ratings.....	31
22. Louver/Damper Energy Efficiency Rating Requirements	31
22.1 Testing requirements.....	31
22.2 Calculated performance	32
22.3 Published ratings.....	32
23. Transverse Duct Connectors Air Leakage Rating Requirements	32
23.1 Testing requirements.....	32
23.2 Calculated performance	34

23.3 Published ratings.....	34
Annex A Electronic Catalogs (Normative).....	35
A.1 Introduction.....	35
A.2 Scope.....	35
A.3 Definitions.....	35
A.4 Statements.....	35
A.5 Certification of electronic performance data.....	36
A.6 Version numbers.....	37
A.7 Certified performance identification.....	37
A.8 AMCA directory listings.....	37
Annex B Measurements (Normative).....	37
B.1 Calculating louver free area.....	38
B.2 Calculating damper area.....	39
Annex C Developing Air Control Product Catalogs (Informative).....	39
C.1 Louver Air Performance Test Report and Catalog Example.....	41
C.2 Louver Wind-Driven Rain Test Report and Catalog Example.....	43
C.3 Louver Water Penetration Test Report and Catalog Example.....	46
C.4 Louver Sound Performance Test Report and Catalog Example.....	48
C.5 Adjustable Louver Leakage Performance Test Report and Catalog Example.....	50
C.6 Damper Air Performance Test Report and Catalog Example.....	52
C.7 Volume Control Damper Leakage Performance Test Report and Catalog Example.....	54
C.8 Ultra-Low-Leakage Damper Leakage Test Report and Catalog Example.....	57
C.9 Bubble-Tight Damper Leakage Performance Test Report and Catalog Example.....	59
C.10 Backdraft Damper Leakage Performance Test Report and Catalog Example.....	61
C.11 Gravity Ventilator Air Performance Test Report and Catalog Example.....	63
C.12 Spiral Duct Leakage Performance Test Report and Catalog Example.....	65
C.13 Flat Oval Spiral Duct Leakage Performance Test Report and Catalog Example.....	67

This is a preview of "AMCA 511-10 (R2016)". [Click here to purchase the full version from the ANSI store.](#)

1. Purpose

AMCA Publication 511 dictates proper presentation of data and other required technical procedures for certification of air control devices under the AMCA Certified Ratings Program. This manual shall be used in conjunction with the current edition of AMCA Publication 11.

2. Scope

The products within the scope of this program are air control devices for use in general ventilation and air conditioning systems.

This program shall apply only to complete cataloged series of sizes. It shall not apply to individual sizes in a series, or part of a series of sizes, or to special units on which catalog ratings are not published.

The AMCA Certified Ratings seal shall be used only in connection with the specifically licensed device. The AMCA Seal shall be used only on complete units. The application of the AMCA seal to individual component parts, such as blades, frames, etc., is not permitted.

3. Definitions and Symbols

3.1 Definitions

All definitions found in AMCA Publication 11, as well as the definitions in this section, apply to this program.

3.1.1 Appurtenance

Appurtenance is any item in the air stream or on the inlet or discharge of the air control device that may affect the performance of the air control device.

An appurtenance shall be considered a part of the air control device if it is in place when the device is tested for performance rating and the effect of the appurtenance is included in the cataloged performance rating.

3.1.2 AMCA Certified Ratings Program

The Certified Ratings Program is a program for certifying a product's performance ratings, as defined in this document.

3.1.3 Performance rating(s)

Performance ratings are data generated from actual tested products used to derive the certified and published information.

3.1.4 Shall and should

The word *shall* indicates a mandatory requirement; the word *should* indicates an advisory statement.

3.1.5 Aerodynamically similar

Louver and damper designs are considered to be aerodynamically similar if the profiles of the components in the air stream are geometrically similar. The blades shall be in relative position to the frame and the center-to-center dimensions shall be the same. Frame, blade stops and blade profiles may have slight variances due to manufacturing methods. Blades must have the same streamline shape in that their leading and trailing edges shall be dimensionally equal. The overall angle or curvature of the blade must be the same. Slight deviations in material thickness shall not reduce the overall free area by more than 5% for dampers and 2.5% for louvers. Blade seals shall have the same profile, be of the same durometer and be secured to the blade in the same manner.

In addition to the requirements described above, louver or damper models claiming aerodynamic similarity for the purpose of certifying leakage performance or energy efficiency performance shall meet the following criteria:

The frames and blades shall have a modulus of elasticity (E) greater than or equal to the originally licensed model.

The blade action (i.e., whether the damper is parallel or opposed blade) shall be the same as the originally licensed model.