

AMCA Publication 600-06

Application Manual for Airflow Measurement Stations



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

AMCA PUBLICATION 600-06

Application Manual for Airflow Measurement Stations



**Air Movement and Control Association International, Inc.
30 West University Drive
Arlington Heights, IL 60004-1893**

This is a preview of "AMCA 600-06". [Click here to purchase the full version from the ANSI store.](#)

© 2006 by Air Movement and Control Association International, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Chief Staff Executive, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Authority

The first edition of AMCA Publication 600 was adopted by the Air Movement and Control Association, Inc. Membership on 21 December 2006.

AMCA 600 Review Committee

Dean DeBaun	Air Monitor Corporation
Michael Khoury	Paragon Controls, Inc.
Bob Van Becelaere	Ruskin Co.
Jim Maciupa	Ultratech Industries / The Hamlin Companies
Tim Orris	AMCA Staff

Disclaimer

AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

Objections to AMCA Standards and Certifications Programs

Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

or

AMCA International, Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire
RG10 9TH United Kingdom

Related AMCA Standards and Publications

ANSI/AMCA Standard 610 *Methods of Testing Airflow Measuring Stations for Rating*

AMCA Publication 99 *Standards Handbook*

AMCA Publication 111 *Laboratory Accreditation Program*

AMCA Publication 611 *Certified Ratings Program – Product Rating Manual for Airflow Measurement Performance*

TABLE OF CONTENTS

1. Introduction	1
2. Purpose and Scope	1
3. Definitions	1
3.1 Airflow	1
3.2 Airflow measurement station	1
3.3 Static pressure	1
3.4 Total pressure	1
3.5 Airflow measurement station performance variables	1
3.6 Miscellaneous	1
4. Principles of Operation	1
4.1 Types of AMS devices	2
5. Applications	7
6. Selection Considerations	11
6.1 Obstructions	11
6.2 Operational range	11
6.3 Environmental suitability	11
6.4 Maintenance access	11
7. Locating the AMS in the Air System	11
8. Airflow Turn-Down Considerations	11
9. Conditions of Air Being Measured: Temperature, Altitude, Static, Pressure, Humidity	12
9.1 Temperature	12
9.2 Altitude	12
9.3 Static pressure	12
9.4 Humidity	12
10. Materials of Construction	12
11. Installed Performance Evaluation	12

This is a preview of "AMCA 600-06". [Click here to purchase the full version from the ANSI store.](#)

Application Manual for Airflow Measurement Stations

1. Introduction

This publication provides information and important points to be considered when designing or specifying heating, ventilating, and air conditioning (HVAC) and other applications in installations requiring airflow measurement stations (AMS) for use in temperatures from -30°C to +120°C (-20°F to +250°F), pressures to 250 Pa (10 in. wg) and velocities to 28 m/s (5500 fpm). It is not the intent of this manual to be used for detailed specifications; rather it serves as a guide toward understanding the various types of airflow measurement stations available and items to be considered for their proper use.

2. Purpose and Scope

This application guide is intended to assist designers and users with the proper application, performance considerations, selection, and limitations of airflow measurement stations.

It is common to see an AMS misapplied or poorly installed. Typical problems include incorrect location, inappropriate measurement range, mismatched accompanying instrumentation, AMS incompatible with intended application, and the like.

This guide provides an overview of permanently installed airflow measurement stations and their application, such information not being readily available in current texts on HVAC or ventilation system design. This publication does not address portable devices used to measure airflow in test-and-balance applications.

3. Definitions

3.1 Airflow

A flow of air or an air current, specifically one that passes through a dimensionally defined plane.

3.2 Airflow measurement station (AMS)

An Airflow Measurement Station is a multiple-point sensing device which is used to measure the airflow rate in a duct system. It may consist of a single sensor or an array of sensors in permanent position

across the duct system. It may be supplied as a probe to be inserted into a ductwork or supplied in a casing approximating the size of the duct system in which it is installed.

3.3 Static pressure

That portion of the air pressure that exists by virtue of the degree of compression or expansion. If expressed as gauge pressure, it may be negative or positive. (AMCA 99-0066)

3.4 Total pressure

The air pressure that exists by virtue of the degree of compression and rate of motion. It is the algebraic sum of the velocity pressure and the static pressure at a point. Thus if the air is at rest, the total pressure will equal the static pressure. (AMCA 99-0066)

3.5 Airflow measurement station performance variables

3.5.1 Tested AMS airflow rate (Q_{AMS}). The tested device airflow rate calculated according to the manufacturer's instructions. This calculation is based upon the output (pressure, current or voltage) of the tested AMS.

3.5.2 AMS Differential pressure. With regard to the differential pressure type AMS only differential pressure is the observed differential pressure between the high pressure output and the low pressure output.

3.5.3 AMS Electronic output. With regard to an electronic output type AMS only, AMS electronic output is the observed voltage or current that relates directly and proportionately to the velocity of airflow in a duct.

3.5.4 Test AMS face area (A_{FACE}). Test device face area is the unobstructed area of the duct at the inlet (or outlet) of the AMS.

4. Principles of Operation

Proper application requires knowledge of the various types of AMSs and their principles of operation.

The airflow sensing devices used in an AMS include, but are not limited to, Pitot-type, differential pressure type, thermal dispersion, vortex-shedding airflow