

AMCA Publication 611-15

Certified Ratings Program -
Product Rating Manual for
Airflow Measurement Stations



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

Certified Ratings Program Product Rating Manual for Airflow Measurement Stations



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority AMCA Publication 611 was approved by the membership of the Air Movement and Control Association International Inc. on December 29, 2015.

Copyright © 2006 by Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

AMCA International, Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire, United Kingdom
RG10 9TH

Disclaimer Asia AMCA Sdn Bhd
No. 7, Jalan SiLC 1/6,
Kawasan Perindustrian SiLC Nusajaya,
Mukim Jelutong, 79200 Nusajaya, Johor
Malaysia

AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

REVIEW COMMITTEE

| | |
|----------------|--------------------------|
| Paresh Davé | Air Monitor Corporation |
| Glenn Esser | Ruskin Company |
| Michael Khoury | Paragon Controls Inc. |
| Josiah Wiley | Ruskin Company |
| Tim Orris | AMCA International Staff |

This is a preview of "AMCA 611-15". [Click here to purchase the full version from the ANSI store.](#)

Related AMCA Documents

Related Publications

AMCA Publication 11

Damper Application Manual for Heating/ Ventilating and Air Conditioning

AMCA Publication 600

Application Manual for Airflow Measurement Stations

Related Standards

ANSI/AMCA Standard 610

Laboratory Methods of Testing Airflow Measurement Stations for Performance Rating

CONTENTS

| | |
|--|----------|
| 1. Purpose | 1 |
| 2. Scope | 1 |
| 3. Definitions | 1 |
| 3.1 Airflow measurement station (AMS) | 1 |
| 3.2 AMS – non-electronic (differential [velocity] pressure) output type | 1 |
| 3.3 AMS – electronic output type | 1 |
| 3.4 Test reference airflow rate | 1 |
| 3.5 AMS performance variables | 1 |
| 3.6 Shall and should | 1 |
| 3.7 Determination | 1 |
| 4. Guidelines for Developing Airflow Measurement Station Ratings | 2 |
| 4.1 Testing requirements | 2 |
| 4.2 Calculated performance | 2 |
| 4.3 Published performance ratings | 2 |
| 4.4 Required statement(s) | 2 |
| 5. Check Test | 3 |
| 5.1 General requirements | 3 |
| 5.2 Check test tolerance | 3 |
| Annex A Update Requirements for Approved and New Catalogs (Normative) | 4 |

This is a preview of "AMCA 611-15". [Click here to purchase the full version from the ANSI store.](#)

Certified Ratings Program

Product Rating Manual for Airflow Measurement Stations

1. Purpose

The purpose of this document is to prescribe and establish procedures to be used in the development and publication of certified performance ratings for airflow measurement stations. Certified ratings provide assurance to the buyer, user and specifier that the manufacturer's published performance ratings for airflow measurement stations are repeatable. The ratings also provide information on how the product was tested, what appurtenances (accessories or optional equipment) were accounted for in the ratings and other pertinent information.

This publication provides a procedure for the verification of the manufacturer's performance ratings on a regular schedule through check-testing of products in the AMCA International laboratory.

The publication also provides assurance that competitive ratings are comparable at the point where the output data is acquired and that they are based on standard test methods on ratings procedures.

This publication is an extension of the AMCA Certified Rating Program. Information on the operation of the program is given in AMCA Publication 11, *Certified Ratings Program – Operating Manual*.

2. Scope

This program applies to products or systems that output either analog electronic (E) or non-electronic (NE) signals. A non-electronic output is considered analog differential pressure, which requires additional hardware to convert differential pressure to an electronic signal.

3. Definitions

3.1 Airflow measurement station (AMS)

A sensing device which is used to measure the airflow rate in a system or fan appurtenance. It may consist of a single sensor or an array of sensors in permanent position in the air system. It may be supplied as a probe to be inserted into a ductwork or supplied in a casing approximating the size of the air system in which it is installed.

For the purposes of this Certified Ratings Program, an AMS shall be classified as one of the two following installation types:

- AMS in casing
- AMS insertion type.

3.2 AMS – non-electronic (differential [velocity] pressure) output type

Converts air velocity into a differential (velocity) pressure signal that correlates to the velocity or volume of air flowing through the AMS.

3.3 AMS – electronic output type

Converts air velocity into an electronic signal that correlates directly and proportionately to the velocity or volume of air flowing through the AMS.

3.4 Test reference airflow rate

The calculated airflow rate at measurement plane.

3.5 AMS performance variables

3.5.1 AMS airflow rate

The airflow rate, based upon the output (pressure, current or voltage of the AMS under test), calculated according to the manufacturer's instructions.

3.5.2 AMS differential pressure

The observed differential pressure between the high-pressure output and the low-pressure output of a differential pressure type AMS.

3.5.3 AMS electronic output

The observed voltage or current output of an electronic output type AMS that correlates directly and proportionately to the velocity or volume of airflow in a duct.

3.5.4 Face area of AMS

The total cross sectional area of a louver, duct, wall or AMS opening.

3.6 Shall and should

The word *shall* is to be understood as mandatory and the word *should* as advisory.

3.7 Determination

A complete set of six measurements at the AMS under test and of the reference airflow system, for one operational airflow test rating.