

AMCA 802-19

Industrial Process/Power Generation Fans:
Establishing Performance Using Laboratory Models



Air Movement and Control Association International

AMCA Corporate Headquarters

30 W. University Drive, Arlington Heights, IL 60004-1893, USA
communications@amca.org ■ Ph: +1-847-394-0150 ■ www.amca.org

© 2016 Air Movement & Control Association International

AMCA Publication 802-19

Industrial Process/Power Generation Fans: Establishing Performance Using Laboratory Models



Air Movement and Control Association International
30 West University Drive
Arlington Heights, Illinois

AMCA Publications

Authority AMCA Publication 802-19 was adopted by the membership of the Air Movement and Control Association International Inc. on February 7, 2019.

Copyright © 2008 by the Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893, U.S.A.

Objections The Air Movement and Control Association (AMCA) International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

AMCA International
30 West University Drive
Arlington Heights, IL 60004-1893
U.S.A.

European AMCA
Avenue des Arts, numéro 46
à Bruxelles (1000 Bruxelles)

Asia AMCA Sdn Bhd
No. 7, Jalan SiLC 1/6,
Kawasan Perindustrian SiLC Nusajaya,
Mukim Jelutong, 79200 Nusajaya, Johor
Malaysia

Disclaimer AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

Review Committee

Dan Banyay	Robinson Fans
Neal Boyd	Northern Blower Inc.
Franco Cincotti	Comefri USA
Jim Greenzweig	Howden North America
Marcel Kamutzki	Daltec Process Fans
Cheolyeong Lee	Dae-Ryun IND. Co., Ltd.
Joe Brooks	AMCA International

Industrial Process/Power Generation Fans: Establishing Performance Using Laboratory Models.....	5
1. Purpose	5
2. Scope.....	5
3. Definitions and Symbols.....	5
3.1 Rating criteria	5
3.2 Gas properties	8
3.3 Aerodynamic definitions.....	9
3.4 Geometric definitions.....	10
3.5 Symbols and subscripted symbols	11
4. Fan Performance Database.....	11
4.1 Establishing fan data base.....	11
4.2 Rating tolerances and test uncertainties	11
5. The Fan Performance Rating Process	12
5.1 Information necessary to properly calculate fan performance	12
5.2 Fan evaluation.....	17
6. Laboratory Test.....	18
6.1 Test setup requirements	18
6.2 Test methods	18
6.3 Test point determination	19
6.4 Instruments and methods of measurement.....	19
7. Fan Similarity Requirements	19
7.1 Minimum model size	20
7.2 Geometric similarity and tolerances.....	20
7.3 Flow similarity and tolerances	24
8. Performance Conversion Procedures	25
9. Prediction and Verification of the Specified Operating Points	27
9.1 Prediction of the specified operating points.....	27
9.2 Verification of the specified operating point.....	27
9.3 Conversion and presentation of test data.....	27
9.4 Numerical examples.....	28
9.5 Numerical examples of the application of test uncertainties.....	42
Annex A Specific Heat Ratio Calculation	47
Annex B.....	49
Compressibility Coefficient (K_p) Calculation	49
Annex C	52
Calculation of Absolute Viscosity	52
Annex D.....	53
Diffuser/Evasé Calculations.....	53
Annex E	55
Test Uncertainty Calculations.....	55

Industrial Process/Power Generation Fans: Establishing Performance Using Laboratory Models

1. Purpose

The purpose of this publication is to outline present methods used by fan manufacturers to determine the performance of full-size industrial process and power generation fans. These methods include:

- Predicting full-size fan ratings using a standard model's existing base performance data.
- Building and testing a model of a proposed fan or existing full-size fan to verify the full-size fan's performance.

This publication provides detailed insight into the variables that influence a fan rating and establishes the rules to be used as well as their limitations in converting performance from one fan to another geometrically similar fan. It also defines dimensional tolerances that must exist for two fans to be considered geometrically similar. It does not cover the detailed procedures a manufacturer uses to select a particular fan or modify a standard fan to achieve a specific rating. That information is confidential to each manufacturer and based on many years of experience and individual company research.

This publication, along with other documents contained in AMCA's 800 series, forms the basis for fan-related concepts and practices.

2. Scope

This publication applies to centrifugal and axial fans. Criteria are provided for establishing geometric and dynamic similarity between the model and the full-size fan, including appurtenances and drives.

This document does not deal with structural details, mechanical properties or components if they do not affect fan performance.

3. Definitions and Symbols

The following list covers definitions and symbols used in fan testing and rating. These are standard definitions as adopted by the fan industry. Certain definitions are similar to those used in general engineering practice and have been adapted for specific use in this publication.

3.1 Rating criteria

3.1.1 Fan

A device that utilizes a power-driven rotating impeller for moving air. A fan may have various appurtenances provided by the fan manufacturer as part of the fan equipment that affect performance. It is necessary to establish what appurtenances are to be considered part of the fan.

In many instances, a customer lists the system requirements and requests that the fan manufacturer supply additional appurtenances, such as silencers or dampers. The pressure losses for appurtenances must be accounted for if the system is to operate properly. If the fan manufacturer supplies these items and they are connected directly to the fan, appropriate losses are added to the system requirements and a fan is selected for the sum of the overall pressure losses.

3.1.2 Fan inlet

The plane perpendicular to the airstream where it first meets the inlet cone or the inlet box furnished by the fan manufacturer. In this publication, the fan inlet is indicated by "Plane 1" (see Figure 1).

3.1.3 Fan outlet

The plane perpendicular to the airstream at the outlet opening of the fan or the outlet opening of the evasé or diffuser. In this publication, the fan outlet is indicated by "Plane 2" (see Figure 1).

3.1.4 Fan airflow rate

The volumetric airflow rate at fan air density at the fan inlet.