This is a preview of "ANSI/AMCA 210-99". Click here to purchase the full version from the ANSI store.

Laboratory Methods of Testing Fans for Aerodynamic Performance Rating **ANSI/AMCA 210-99 ANSI/ASHRAE 51-1999** An American National Standard Approved by ANSI on December 2, 1999 Approved by ASHRAE on June 23, 1999



30 West University Drive Arlington Heights, Illinois, 60004-1893 USA Phone: 847/394-0150 · Fax: 847/253-0088 · www.amca.org

The Air Movement and Control Association International, Inc. is a not-for-profit international association of the world's manufacturers of related air system equipment primarily, but not limited to: fans, louvers, dampers, air curtains, airflow measurement stations, acoustic attenuators, and other air system components for the industrial, commercial and residential markets.



The International Authority on Air System Components

AIR MOVEMENT AND CONTROL ASSOCIATION INTERNATIONAL, INC.

This is a preview of "ANSI/AMCA 210-99". Click here to purchase the full version from the ANSI store.

Laboratory Methods of Testing Fans for Aerodynamic Performance Rating

ANSI/AMCA 210-99

ANSI/ASHRAE 51-1999

An American National Standard

Approved by ANSI on December 2, 1999 Approved by ASHRAE on June 23, 1999



The International Authority on Air System Components

AIR MOVEMENT AND CONTROL ASSOCIATION INTERNATIONAL, INC. ANSI/AMCA STANDARD 210

ANSI/ASHRAE STANDARD 51

LABORATORY METHOD OF TESTING FANS FOR AERODYNAMIC PERFORMANCE RATING

Published by Air Movement and Control Association International, Inc. and American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc. ©2000 By Air Movement and Control Association International, Inc. and American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the 1976 United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Vice President, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, Illinois, 60004-1893 USA - Fax: 847-253-0088 - E-mail: amca@amca.org.

JOINT AMCA 210/ASHRAE 51 PROJECT COMMITTEE

Robert Jorgensen, Chairman Steve Adamski Hoy R. Bohanon John Cermak Charles W. Coward, Jr. Daniel Fragnito Gerald P. Jolette John O'Connor † Paul R. Saxon James W. Schwier † Mark Stevens J. Thomas Sobieski William B. Swim † deceased AMCA - ASHRAE AMCA - ASHRAE AMCA - ASHRAE AMCA - ASHRAE ASHRAE ASHRAE ASHRAE AMCA - ASHRAE AMCA - ASHRAE AMCA - ASHRAE AMCA ASHRAE ASHRAE ASHRAE

SPECIAL NOTE

This National Voluntary Consensus Standard was developed under the joint auspices of the Air Movement and Control Association International, Inc. (AMCA) and the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE). Consensus is defined as "substantial agreement reached by concerned interests according to the judgement of a duly appointed authority, after a concerted attempt at resolving objections. Consensus implies much more than the concept of a simple majority but not necessarily unanimity." This definition is according to the American National Standards Institute (ANSI) of which both AMCA and ASHRAE are members.

This Foreword is not a part of ANSI/AMCA Standard 210 or ANSI/ASHRAE Standard 51 but is included for information purposes only. See also Appendix I for the History and Authority.

FOREWORD

This standard provides rules for testing fans, under laboratory conditions, to provide rating information. It was prepared by a joint committee consisting of the Air Movement and Control Association International, Inc. (AMCA) 210 Review Committee and the American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc. (ASHRAE) Standard 51-85R Committee.

The joint committee debated whether the International Standard for laboratory testing of industrial fans, ISO 5801 *Industrial fans: Performance testing using standardised airways*, should be adopted in lieu of preparing a new edition of this standard. The decision to proceed with a ninth edition was based on the conclusion that ISO 5801 allowed the use of measurements that did not meet the uncertainties requirements of this standard. However, certain features of ISO 5801 have been included, most of which were anticipated in the 1985 edition.

The principal changes compared to ANSI/AMCA 210-85//ANSI/ASHRAE 51-85 Laboratory Methods of Testing Fans for Rating are:

- 1) Incorporation of SI units in the text. SI units are primary, I-P units are secondary.
- 2) Addition of SI equations.
- 3) Numbering of equations for easier reference.
- 4) Deletion of tabular and graphical data as unnecessary, since equations are definitive and universal use of computers is anticipated.
- 5) Addition of Appendix F, giving an example of the iterative solution of Re and C.
- 6) Addition of Appendix I, giving the history of fan test codes in North America.

Suggestions for improvement of this standard will be welcome. They should be sent to either the Air Movement and Control Association International, Inc., 30 West University Drive, Arlington Heights, Illinois 60004-1893 U.S.A. or the American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA 30329 U.S.A.

DISCLAIMER

AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety of performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards, or that any tests conducted under its standards will be non-hazardous or free from risk.

ANSI/AMCA STANDARD 210 ANSI/ASHRAE STANDARD 51

CONTENTS

Figure

| Section | | Page |
|---------|--|------|
| 1. | Purpose | 1 |
| 2. | Scope | 1 |
| 3. | Definitions | 1 |
| | 3.1 Fans | 1 |
| | 3.2 Psychrometrics | 1 |
| | 3.3 Pressure | 2 |
| | 3.4 Fan Performance Variables | 2 |
| | 3.5 Miscellaneous | 2 |
| 4 | Symbols and Subscripts | 4 |
| 4. | 4.1 Symbols and Subscripted Symbols | 4 |
| | 4.1 Symbols and Subscripted Symbols 4.2 Additional Subscripts | 5 |
| | 4.2 Additional Subscripts | |
| 5. | Instruments and Methods of Measurement | 5 |
| | 5.1 Accuracy | 5 |
| | 5.2 Pressure | 5 |
| | 5.3 Airflow Rate | 7 |
| | 5.4 Power | 8 |
| | 5.5 Speed | 8 |
| | 5.6 Air Density | 8 |
| 6. | Equipment and Setups | 9 |
| 0. | 6.1 Setups | 9 |
| | 6.2 Ducts | 9 |
| | 6.3 Chambers | 10 |
| | 6.4 Variable Supply and Exhaust Systems | 10 |
| _ | | 11 |
| 7. | Observations and Conduct of Test | 11 |
| | 7.1 General Test Requirement | 11 |
| | 7.2 Data to be Recorded | 11 |
| 8. | Calculations | 12 |
| | 8.1 Calibration Correction | 12 |
| | 8.2 Density and Viscosity of Air | 12 |
| | 8.3 Fan Airflow Rate at Test Conditions | 12 |
| | 8.4 Fan Velocity Pressure at Test | |
| | Conditions | 14 |
| | 8.5 Fan Total Pressure at Test Conditions | 15 |
| | 8.6 Fan Static Pressure at Test Conditions | 16 |
| | 8.7 Fan Power Input at Test Conditions | 16 |
| | 8.8 Fan Efficiency | |
| | 8.9 Conversions to Nominal Constant Values | |
| | of Density and Speed | |
| ٥ | Report and Results of Test | 18 |
| 7. | 9.1 Report | 18 |
| | 9.1 Report 9.2 Performance Curves | |
| 10 | . Normative References | 19 |

| 1 | Pitot-Static Tubes | 20 | | |
|---------------|---------------------------------------|----|--|--|
| 2A | Static Pressure Tap | 21 | | |
| 2B | Total Pressure Tube. | 21 | | |
| 3 | Traverse Points in a Round Duct | 21 | | |
| 4A | Nozzles | 22 | | |
| 4B | Three-Arc Approximation of | | | |
| | Elliptical Nozzle | 23 | | |
| 5 | Transformation Piece | 24 | | |
| 6 | Flow Straightener | 25 | | |
| 7 | Outlet Duct Setup-Pitot Traverse | | | |
| | in Outlet Duct | 26 | | |
| 8 | Outlet Duct Setup-Nozzle on End | | | |
| | of Outlet Duct | 27 | | |
| 9 | Outlet Duct Setup-Nozzle on End | | | |
| | of Chamber | 28 | | |
| 10 | Outlet Duct Setup-Multiple Nozzles | | | |
| | in Chamber | 29 | | |
| 11 | Outlet Chamber Setup-Nozzle on End | | | |
| | of Chamber | 30 | | |
| 12 | Outlet Chamber Setup-Multiple Nozzles | | | |
| | in Chamber | 31 | | |
| 13 | Inlet Chamber Setup-Pitot Traverse | | | |
| | in Duct | 32 | | |
| 14 | Inlet Chamber Setup-Ducted Nozzle | | | |
| | on Chamber | 33 | | |
| 15 | Inlet Chamber Setup-Multiple Nozzles | | | |
| | in Chamber | 34 | | |
| 16 | * | | | |
| | Inlet Duct | 35 | | |
| 17 | Typical Fan Performance Curve, SI | 36 | | |
| 17 | Typical Fan Performance Curve, I-P | 37 | | |
| Appendix Page | | | | |
| Appendix I | | | | |

Page

| Α. | Units of Measurement | 38 |
|----|---------------------------------------|----|
| В. | SI Conversions and Physical Constants | 39 |
| C. | Derivation of Equations | 41 |
| D. | Similarity and Fan Laws | 44 |
| | Uncertainties Analysis | 48 |
| F. | Iterative Procedure | 56 |
| G. | Tubing | 58 |
| H. | Bibliography | 59 |
| I. | History and Authority | 61 |
| | Index | 64 |

An Interpretation (requested during public comment) 66

This is a preview of "ANSI/AMCA 210-99". Click here to purchase the full version from the ANSI store.

Laboratory Methods of Testing Fans For Aerodynamic Performance Rating

1. Purpose

This standard establishes uniform methods for laboratory testing of fans and other air moving devices to determine aerodynamic performance for rating or guarantee purposes in terms of airflow rate, pressure, power, air density, speed of rotation, and efficiency.

It is not the purpose of this standard to specify the testing procedures to be used for design, production, or field testing.

2. Scope

2.1 This standard may be used as the basis for testing fans, blowers, exhausters, compressors, or other air moving devices when air is used as the test gas.

- 2.2 The scope of this standard does not cover:
- (a) circulating fans such as ceiling fans, desk fans and jet fans.
- (b) compressors with interstage cooling.
- (c) positive displacement machines.
- (d) testing procedures to be used for design, production, or field testing.

2.3 The parties to a test for guarantee purposes may agree on exceptions to this standard in writing prior to the test. However, only tests which do not violate any mandatory requirements of this standard shall be designated as tests conducted in accordance with this standard.

3. Definitions

3.1 Fans

3.1.1 Fan: A device for moving air which utilizes a power driven rotating impeller. A fan shall have at least one inlet opening and at least one outlet opening. The openings may or may not have elements for connection to ductwork.

3.1.2 Boundaries.

3.1.2.1 Fan Inlet and Outlet Boundaries. Fan inlet and outlet boundaries are defined as the interfaces between the fan and the remainder of the system, and are at a plane perpendicular to the air stream where it enters or leaves the fan. Various appurtenances, such as inlet boxes, inlet vanes, inlet cones, silencers, screens, rain hoods, dampers, discharge cones, evasé, etc., may be

included as a part of the fan between the inlet and outlet boundaries.

3.1.2.2 Fan Input Power Boundary. The interface between the fan and its driver. Drive or coupling losses may be included as a part of the input power.

3.1.3 Fan Outlet Area. Fan outlet area is the gross inside area measured in the plane(s) of the outlet opening(s). For roof ventilators and unhoused fans, the area shall be considered the gross impeller outlet area for centrifugal types or the gross casing area at the impeller for axial types.

3.1.4 Fan Inlet Area. Fan inlet area is the gross inside area measured in the plane(s) of the inlet connection(s). For converging inlets without connection elements, the inlet area shall be considered to be that where a plane, perpendicular to the airstream, first meets the bell mouth or cone.

3.2 Psychrometrics

3.2.1 Dry-Bulb Temperature. Dry-bulb temperature is the air temperature measured by a dry temperature sensor.

3.2.2 Wet-Bulb Temperature. Wet-bulb temperature is the temperature measured by a temperature sensor covered by a water-moistened wick and exposed to air in motion. When properly measured, it is a close approximation of the temperature of adiabatic saturation.

3.2.3 Wet-Bulb Depression. Wet-bulb depression is the difference between the dry-bulb and wet-bulb temperatures at the same location.

3.2.4 Stagnation (Total) Temperature. Stagnation (total) temperature is the temperature which exists by virtue of the internal and kinetic energy of the air. If the air is at rest, the stagnation (total) temperature will equal the static temperature.

3.2.5 Static Temperature. Static temperature is the temperature which exists by virtue of the internal energy of the air only. If a portion of the internal energy is converted into kinetic energy, the static temperature will be decreased accordingly.

3.2.6 Air Density. Air density is the mass per unit volume of the air.

Note: References which are enclosed in { } are normative for this standard, while those enclosed in [] are to be considered informative.