

ANSI/AMCA Standard 220-05

Laboratory Methods of Testing Air Curtain Units for Aerodynamic Performance Rating

An American National Standard
Approved by ANSI on June 7, 2005



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

ANSI/AMCA STANDARD 220-05

Laboratory Methods of Testing Air Curtain Units for Aerodynamic Performance Rating



Air Movement and Control Association International, Inc.
30 West University Drive
Arlington Heights, IL 60004-1893

This is a preview of "ANSI/AMCA 220-05". [Click here to purchase the full version from the ANSI store.](#)

© 2007 by Air Movement and Control Association International, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Director, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Authority

This publication was approved by the AMCA International membership on 14 January 2001 and as an American National Standard by the American National Standards Institute (ANSI) on 7 June 2005. This edition of ANSI/AMCA Standard 220 supersedes AMCA 220-91.

AMCA 220 Review Committee

David Johnson, Chair	Berner International Corp.
James M. Jagers	Alton
Michael Coscarelli*	Berner International Corp.
Jack Peters**	Loren Cook Co.
Vincent Vilarchao	Marley Engineered Products
Dennis Neibrook*	Marley Engineered Products
Frank Cuaderno	Mars Sales Co., Inc.
Steve Rosol*	Mars Sales Co., Inc.
Ken Lapinski	Powered Aire, Inc.
Brian K. Jones*	Powered Aire, Inc.
Paul Saxon	AMCA International Staff
Joe Brooks	AMCA International Staff

* *Alternate Committee Member*

** *Corresponding Committee Member*

Disclaimer

AMCA International uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA International does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA International standards or that any tests conducted under its standards will be non-hazardous or free from risk.

TABLE OF CONTENTS

1. Scope	1
2. Normative References	1
3. Definitions / Units of Measure / Symbols	1
3.1 Definitions	1
3.2 Systems of units	3
3.3 Symbols and subscripted symbols	3
4. Instruments and Methods of Measurement	4
4.1 Air curtain core velocity measurement	4
4.2 Power	4
5. Equipment and Setups	4
5.1 Air curtain airflow rate test	4
5.2 Air velocity projection and outlet air velocity uniformity test	4
6. Observation and Conduct of Tests	4
6.1 Initial conditions	4
6.2 Data to be recorded	4
7. Calculations	5
7.1 Average outlet air velocity	5
7.2 Outlet air velocity	5
7.3 Air curtain velocity projection	6
7.4 Air curtain unit efficiency	6
8. Report and Results	6
8.1 Outlet air velocity uniformity test	6
8.2 Air velocity projection test	6
Annex A. Uncertainty in Velocity Determination Using Pitot-Static Tube and Manometer (Informative)	17
Annex B. References (Informative)	18

This is a preview of "ANSI/AMCA 220-05". [Click here to purchase the full version from the ANSI store.](#)

Laboratory Methods of Testing Air Curtain Units for Aerodynamic Performance Rating

1. Scope

The scope of this standard covers the performance testing of air curtain units.

The purpose of this standard is to establish uniform methods for laboratory testing of air curtain units to determine aerodynamic performance in terms of airflow rate, outlet air velocity uniformity, power consumption, and air velocity projection, for rating or guarantee purposes.

It is not the purpose of this standard to specify the testing procedures to be used for design, production, or field testing.

2. Normative References

The following standard contains provisions which, through reference in this text, constitute provisions of this standard. At the time of publication, the edition indicated was valid. All standards are subject to revision, and parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent edition of the standard indicated below.

ANSI/AMCA 210-99 *Laboratory Methods of Testing Fans for Aerodynamic Performance Rating*, Air Movement and Control Association International, Inc., Arlington Heights, IL 60004 U.S.A., 1999.

3. Definitions / Units of Measure / Symbols

3.1 Definitions

3.1.1 Air curtain (airstream). A directionally-controlled airstream, moving across the entire height and width of an opening, which reduces the infiltration or transfer of air from one side of the opening to the other and/or inhibits insects, dust or debris from passing through. For the purposes of this standard, "air curtain" and "airstream" are synonymous.

3.1.2 Air curtain depth. The airstream dimension perpendicular to both the direction of airflow and the airstream width; the short dimension of the airstream.

3.1.3 Air curtain width. The airstream dimension perpendicular to both the direction of airflow and the airstream depth; the long dimension of the airstream.

3.1.4 Air curtain unit (ACU). An air moving device which produces an air curtain.

3.1.5 Air discharge nozzle. A component or an assembly, which may include adjustable vanes, in the ACU which directs and controls the airstream.

3.1.6 Air discharge nozzle depth (N_d). The inside dimension perpendicular to both the direction of airflow and the airstream width.

3.1.7 Air discharge nozzle width (N_w). The inside dimension perpendicular to both the direction of airflow and the nozzle depth.

3.1.8 Air discharge angle (θ). The angle between the plane of the protected opening and the direction in which the air curtain leaves the discharge.

3.1.9 Psychrometrics (from ANSI/AMCA 210)

3.1.9.1 Dry-bulb temperature (t_d). The air temperature measured by a dry temperature sensor.

3.1.9.2 Wet-bulb temperature (t_w). The temperature measured by a temperature sensor covered by a water-moistened wick and exposed to air in motion. When properly measured, it is a close approximation of the temperature of adiabatic saturation.

3.1.9.3 Wet-bulb depression. The difference between the dry-bulb and wet-bulb temperatures at the same location.

3.1.9.4 Stagnation (total) temperature. Stagnation (total) temperature is the temperature which exists by virtue of the internal and kinetic energy of the air. If the air is at rest, the total temperature will equal the static temperature.

3.1.9.5 Static temperature. Static temperature is the temperature which exists by virtue of the internal energy of the air only. If a portion of the internal energy is converted into kinetic energy, the static temperature will be decreased accordingly.