

ANSI/AMCA Standard 230-07

Laboratory Methods of Testing Air Circulating Fans for Rating and Certification

An American National Standard
Approved by ANSI on September 20, 2007



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

ANSI/AMCA STANDARD 230-07

Laboratory Methods of Testing Air Circulating Fans for Rating and Certification



**Air Movement and Control Association International, Inc.
30 West University Drive
Arlington Heights, IL 60004-1893**

This is a preview of "ANSI/AMCA 230-07". [Click here to purchase the full version from the ANSI store.](#)

© 2007 by Air Movement and Control Association International, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Director, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Authority

AMCA International Standard 230 was approved by the membership of the Air Movement and Control Association International, Inc. on February 11, 2007. It was approved as an American National Standard by the American National Standards Institute (ANSI) and became effective on September 20, 2007.

AMCA 230 Review Committee

Richard Aynsley, Chair	Big Ass Fan Co.
John Cermak	Acme Engineering & Manufacturing Corp.
Chris Riske	Airmaster Fan Co.
Xuwen Qiu	Concept NREC
Ryan Wade	Emerson Ventilation Products
Michael Brendel	Lau Industries, Inc.
Tung Nguyen	PennBarry
Hans Witt	Witt & Sohn AG
Joseph Brooks	AMCA International, Inc.

Disclaimer

AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

Objections to AMCA Standards and Certifications Programs

Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

or

AMCA International, Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire
RG10 9TH United Kingdom

Related AMCA Standards and Publications

AMCA Publication 11 *Certified Ratings Program - Operating Manual*

AMCA Publication 211 *Certified Ratings Program - Product Rating Manual for Fan Air Performance*

AMCA Standard 300 *Reverberant Room Method for Sound Testing of Fans*

AMCA Publication 311 *Certified Ratings Program - Product Rating Manual for Fan Sound Performance*

TABLE OF CONTENTS

1. Purpose	1
2. Scope	1
3. Units of Measurement	1
3.1 System of units	1
3.2 Basic units	1
3.3 Velocity	1
3.4 Thrust	1
3.5 Pressure	1
3.6 Power	1
3.7 Speed	1
3.8 Gas properties	1
3.9 Dimensionless groups	1
3.10 Physical constants	2
4. Symbols and Subscripts	2
5. Definitions	2
5.1 Air circulator fan	2
5.2 Psychrometrics	2
5.3 Pressure	3
5.4 Fan performance variables	3
5.5 Miscellaneous	3
6. Instruments and Methods of Measurement	3
6.1 Accuracy	3
6.2 Thrust	4
6.3 Power	4
6.4 Speed	4
6.5 Air density	4

7. Equipment and Setups	5
7.1 Allowable test setups	5
7.2 Load cell orientation	5
8. Observations and Conduct of Test	5
8.1 General test requirements	5
8.2 Data to be recorded	5
9. Calculations	5
9.1 Calibration correction	5
9.2 Atmospheric air density	5
9.3 Thrust	6
10. Report and Results of Test	6
Annex A. Circulating Fans and Their Relationship to Airflow and Air Velocity (Informative)	13
Annex B. References (Informative)	14

Laboratory Methods of Testing Air Circulating Fans for Rating and Certification

1. Purpose

The purpose of this standard is to establish uniform methods for laboratory testing of air circulating fans to determine performance in terms of thrust for rating, certification or guarantee purposes.

2. Scope

This standard may be used as the basis for testing air circulating fan heads, ceiling fans, box fans, table fans, portable personnel coolers, or other air circulating devices when air is used as the test gas.

Blowers, exhausters, compressors, positive displacement machines, and positive pressure ventilators are not within the scope of this standard.

The parties to a test for guarantee purposes may agree on exceptions to this standard in writing prior to the test. However, only tests which do not violate any mandatory requirements of this standard shall be designated as tests conducted in accordance with this standard.

3. Units of Measurement

3.1 System of units

SI units (The International System of Units (Le Système International d'Unités) [1]) are the primary units employed in this standard, with I-P units given as the secondary reference. SI units are based on the fundamental values of the International Bureau of Weights and Measures [1], and I-P values are based on the values of the National Institute of Standards and Technology which are, in turn, based on the values of the International Bureau.

3.2 Basic units

The unit of length is the meter (m) or millimeter (mm); I-P units are the foot (ft) or inch (in.). The unit of mass is the kilogram (kg); the I-P unit is the pound-mass (lbm). The unit of time is either the minute (min) or the second (s). The unit of temperature is either the Kelvin (K) or the degree Celsius (°C); the I-P unit is the degree Rankine (°R) or the degree Fahrenheit

(°F). The unit of force is the newton (N); the I-P unit is the pound-force (lbf).

3.3 Velocity

The unit of velocity is the meter per second (m/s); the I-P unit is the foot per minute (fpm).

3.4 Thrust

The unit of thrust is Newtons (N); the I-P unit is the pound force (lbf).

3.5 Pressure

For all pressures other than barometric pressure, the unit is the Pascal (Pa); the I-P unit is the inch water gauge (in. wg). The in. wg shall be based on a one inch column of distilled water at 68°F under standard gravity and a gas column balancing effect based on standard air. The unit of barometric pressure is the millimeter of mercury (mm Hg); The I-P unit is the inch mercury column (in. Hg). The mm Hg shall be based on a one millimeter column of mercury at 0°C under standard gravity *in vacuo*; The in. Hg shall be based on a one inch column of mercury at 32°F under standard gravity *in vacuo*.

3.6 Power

The unit of input power is the Watt (W).

3.7 Speed

The unit of rotational speed is the revolution per minute (rpm).

3.8 Gas properties

The unit of density is the kilogram per cubic meter (kg/m^3); the I-P unit is the pound-mass per cubic foot (lbm/ft^3). The unit of gas constant is the Joule per kilogram-Kelvin ($\text{J}/(\text{kg}\cdot\text{K})$); the I-P unit is the foot-pound per pound mass-degree Rankine ($\text{ft}\cdot\text{lb}/(\text{lbm}\cdot\text{°R})$).

3.9 Dimensionless groups

Various dimensionless quantities appear in the text. Any consistent system of units may be employed to evaluate these quantities unless a numerical factor is included, in which case units must be as specified.