

ANSI/AMCA Standard 250-12

Laboratory Methods of Testing Jet Tunnel Fans for Performance

An American National Standard
Approved by ANSI on February 22, 2012



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

ANSI/AMCA Standard 250-12

Laboratory Methods of Testing Jet Tunnel Fans for Performance



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority ANSI/AMCA Standard 250-05 was adopted by the membership of the Air Movement and Control Association International, Inc. on 14 January 2001. It was approved by ANSI as an American National Standard on 31 August 2005. The 2012 revision of Standard 250 was approved by ANSI on February 22, 2012.

Copyright © 2012 by Air Movement and Control Association International, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Director, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

AMCA International, Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire, United Kingdom
RG10 9TH

Disclaimer AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

REVIEW COMMITTEE

Ang Swee Hock Lawrence	DongGuan Wolter Chemco Ventilation Ltd
Roberto Arias	Zitron, S.A.
John Cermak	Acme Engineering and Manufacturing Corporation
Sisir Chakraborty	CB Doctor Ventilators Pvt. Ltd.
David Ortiz Gomez	Soler & Palau, S.A. de C.V.
Marcel Kamutzki	Daltec Canadian Buffalo Manufacturing Ltd.
Paul Okeley	Fan Group, Inc.
Chen Yongning	Taizhou Wolter Ventilation Co., Ltd.
Tim Orris	AMCA Staff

This is a preview of "ANSI/AMCA 250-12". [Click here to purchase the full version from the ANSI store.](#)

Related AMCA Documents

Related Publications

AMCA Publication 211

Certified Ratings Program - Product Rating Manual for Fan Air Performance

CONTENTS

1. Scope	1
2. Normative References	1
3. Definitions and Symbols	1
3.1 Definitions	1
3.2 Symbols	3
4. Characteristics to be Measured	3
4.1 General	3
4.2 Volume airflow rate	3
4.3 Thrust	3
4.4 Input power	5
4.5 Sound power level	5
4.6 Vibration velocity	5
5. Instrumentation and Measurements	5
5.1 Volume airflow rate	5
5.2 Thrust	5
5.3 Input power	5
5.4 Impeller rotational speed	5
5.5 Sound level	5
5.6 Vibration velocity	5
6. Determination of Airflow Rate	5
6.1 General	5
6.2 Direct connected airflow measuring device	5
6.3 Upstream chamber method	5
6.4 Upstream pitot traverse method	6
7. Determination of Thrust	6
7.1 General	6
7.2 Suspended configuration	6
7.3 Supported configuration	6
7.4 Test procedures	6
7.5 Test enclosure	6
8. Determination of Sound Level	7
8.1 General	7
8.2 Test arrangement	7
8.3 Enclosure suitability	7

9. Determination of Vibration Velocity	7
9.1 General	7
9.2 Test arrangement	7
9.3 Test procedure	8
9.4 Acceptance vibration velocity	8
10. Presentation of Results	8
10.1 Product description	8
10.2 Product performance	8
11. Tolerances and Conversion Rules	9
11.1 Tolerances	9
11.2 Conversion rules	9
Annex A Illustration of Reference Sound Source (Normative)	21
Annex B Combination of Sound Pressure Levels (Normative)	22
Annex C Conversion Rules (Normative)	23
C.1 General	23
C.2 Performance Coefficients	23
C.3 Sound Power Levels	23
Annex D Informative References (Informative)	24

Laboratory Methods of Testing Jet Tunnel Fans for Performance

1. Scope

This standard deals with the determination of those technical characteristics needed to describe all aspects of the performance of jet tunnel fans. It does not cover those fans designed for ducted applications nor those designed solely for air circulation, e.g., ceiling fans and table fans.

The test procedures described in this standard relate to laboratory conditions. The measurement of performance under in-situ conditions is not included.

The parties to a test for guarantee purposes may agree on exceptions to this standard in writing prior to the test. However, only tests that do not violate any mandatory requirements of this standard shall be designated as tests conducted in accordance with this standard.

2. Normative References

The following standards contain provisions that, through specific reference in this text, constitute provisions of this American National Standard. At the time of publication the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this American National Standard are encouraged to investigate the possibility of applying the most recent editions of the standards listed below.

AMCA 300-96
Reverberant Room Method for Sound Testing of Fans
Air Movement and Control Association International, Inc.,
Arlington Heights, IL, USA.

ANSI S2.19-1999 (R2004)
Mechanical Vibrations - Balance Quality Requirements of Rigid Motors - Part 1: Determination of Possible Unbalance, Including Marine Applications
American National Standards Institute, New York, NY, USA.

ANSI/AMCA 204-96
Balance Quality and Vibration Levels for Fans
Air Movement and Control Association International,
Arlington Heights, IL U.S.A., 1998

ANSI/AMCA 210-99
Laboratory Methods of Testing Fans for Aerodynamic Performance Rating
Air Movement and Control Association International,
Arlington Heights, IL U.S.A., 2000

ANSI/NEMA MG 1-2003
Motors and Generators
National Electrical Manufacturers Association, Rosslyn, VA,
USA.

ISO 5801:1997(E)
Industrial Fans - Performance Testing Using Standardized Airways
International Organization for Standardization, Geneva,
Switzerland, 1996

3. Definitions and Symbols

3.1 Definitions

For the purposes of this standard, the following definitions apply:

3.1.1 Air

A mixture of various gases forming the earth's atmosphere and commonly used to denote any gaseous medium measured, moved or controlled in a HVAC system.

3.1.2 Standard air

Air with a density of 1.2 kg/m³ (0.75 lbm/ft³), a specific heat ratio of 1.4, a viscosity of 1.819 × 10⁻⁵ Pa•s (1.222 × 10⁻⁵ lbm/ft-sec) and an absolute pressure of 101.325 kPa (408.0 in. wg). Air at 20°C (68°F), 50% relative humidity, and 101.325 kPa (29.92 in. Hg) has these properties, approximately.

3.1.3 Absolute pressure

Pressure above a perfect vacuum; the sum of gauge pressure and atmospheric pressure. The value is always positive.

3.1.4 Barometric pressure

The absolute pressure exerted by the atmosphere at a location of measurement.

3.1.5 Dry-bulb temperature

Air temperature measured by a temperature-sensing device without modifications to compensate for the effect of humidity.

3.1.6 Static pressure at a point

That portion of air pressure that exists by virtue of the degree of compression only. If expressed as gauge pressure, it may be negative or positive.

3.1.7 Volume airflow rate

The volume of air that passes through a given area in unit time.