

AMCA Publication 511-10

Certified Ratings Program -
Product Rating Manual for
Air Control Devices



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

Certified Ratings Program Product Rating Manual for Air Control Devices



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority AMCA International Publication 511-10 was approved by the membership of the Air Movement and Control Association, International on October 14, 2010.

Copyright © 2010 by Air Movement and Control Association International, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Director, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

AMCA International, Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire, United Kingdom
RG10 9TH

Disclaimer AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

REVIEW COMMITTEE

Marty Gissel Committee Chair	Greenheck Fan Corporation
Mike Binkholder	Mestek, Inc.
Jeff Blake	Construction Specialties, Inc.
Dane Carey	United Enertech
Eric Gohring	Cesco Products
Jason George	Ruskin Company
Doug Graham	T. A. Morrison & Co. Inc.
Dan Huber	Ruskin Company
Larry Kozak	Ward Industries
Vince Kreglewicz	Arrow United
Tim Malki	Daniel Mechanical, Co.
Bin Ngo	Daniel Mechanical, Co.
Dan Rau	Ruskin Company
Robert Van Becelaere	Ruskin Company
Tim Orris	AMCA International
John Pakan	AMCA International

Related AMCA Documents

Related Publications

AMCA Publication 11	<i>Certified Ratings Program Operating Manual</i>
AMCA Publication 111	<i>Laboratory Accreditation Program</i>
ANSI/AMCA Standard 500-D	<i>Laboratory Methods for Testing Dampers for Rating</i>
ANSI/AMCA Standard 500-L	<i>Laboratory Methods for Testing Louvers for Rating</i>
AMCA Publication 512	<i>AMCA Listing Label Program</i>
ANSI/AMCA Standard 540	<i>Test Method for Louvers Impacted by Wind Borne Debris</i>
ANSI/AMCA Standard 550	<i>Test Method for High Velocity Wind Driven Rain Resistant Louvers</i>

CONTENTS

1. Purpose	1
2. Scope	1
3. Definitions and Symbols	1
3.1 Definitions	1
3.2 Symbols	2
4. Data Submittal Requirements	2
5. Required Catalog Statements	2
5.1 Licensed product statement	2
5.2 Licensed performance statement	2
5.3 Appurtenances statement	2
6. General Guidelines for Air Control Products	2
6.1 Manufacturer's responsibility	2
6.2 AMCA Staff responsibility	2
6.3 Rating development	3
6.4 Aerodynamically similar products	3
6.5 Nameplated products	3
7. Check Test Tolerances	3
7.1 Licensee's duty	3
7.2 Tolerances	3
8. Louver Air Performance Rating Requirements	4
9. Louver Wind-Driven Rain Rating Requirements	5
10. Louver Water Penetration Rating Requirements	6
11. Acoustical Louver Sound Performance Rating Requirements	8
12. Adjustable Louver Air Leakage Rating Requirements	9
13. Damper Air Performance Rating Requirements	10
14. Volume Control Damper Air Leakage Rating Requirements	12
15. Ultra-Low Leakage Damper Air Leakage Rating Requirements	14
16. Zero Leakage Damper (Bubble-Tight) Air Leakage Rating Requirements	15
17. UL Classified Damper Air Leakage Rating Requirements	16
18. Backdraft Damper Air Leakage Rating Requirements	17
19. Gravity Ventilator (excluding louver penthouses) Air Performance Rating Requirements	18
20. Round Spiral Duct Air Leakage Rating Requirements	20
21. Louver/Damper Energy Efficiency Rating Requirements	21

This is a preview of "AMCA 511-10". [Click here to purchase the full version from the ANSI store.](#)

Annex B Measurements (Normative)	24
Annex C Developing Air Control Product Catalogs (Informative)	27

Certified Ratings Program

Product Rating Manual for Air Control Devices

1. Purpose

AMCA Publication 511 dictates proper presentation of data and other required technical procedures for certification of air control devices under the AMCA Certified Ratings Program. This manual shall be used in conjunction with the current edition of AMCA Publication 11.

2. Scope

The products within the scope of this program are air control devices for use in general ventilation and air conditioning systems.

This program shall apply only to complete cataloged series of sizes. It shall not apply to individual sizes in a series, or part of a series of sizes, or to special units on which catalog ratings are not published.

The AMCA Certified Ratings Seal shall be used only in connection with the specifically licensed device. The AMCA Seal shall be used only on complete units. The application of the AMCA Seal to individual component parts, such as blades, frames, etc., is not permitted.

3. Definitions and Symbols

3.1 Definitions

All definitions found in AMCA Publication 11, as well as the definitions in this section, apply to this program.

3.1.1 Appurtenance

Any item in the air stream or on the inlet or discharge of the air control device that may affect the performance of the air control device.

An appurtenance shall be considered a part of the air control device if it is in place when the device is tested for performance rating, and the effect of the appurtenance is included in the cataloged performance rating.

3.1.2 AMCA Certified Ratings Program

A program for certifying a product's performance ratings, as defined in this document.

3.1.3 Performance rating(s)

Data generated from actual tested products used to derive the certified and published information.

3.1.4 Shall and should

The word "shall" indicates a mandatory requirement; the word "should" indicates an advisory statement.

3.1.5 Aerodynamically similar

Louvers and dampers are considered to be aerodynamically similar if the profiles of the components in the air stream are geometrically similar. The blades shall be in relative position to the frame and the center-to-center dimensions shall be the same. Frame, blade stops, and blade profiles may have slight variances due to manufacturing methods. Blades must have the same streamline shape in that their leading and trailing edges shall be dimensionally equal. The overall angle or curvature of the blade must be the same. Slight deviations in material thickness shall not reduce the overall free area by more than 5% for dampers and 2.5% for louvers. Blade seals shall have the same profile, be of the same durometer, and be secured to the blade in the same manner.

3.1.6 Volume control damper

A volume control damper is a device which, when mounted to a duct or opening, is used to vary the volume of air through the duct or opening. It can be operated manually or mechanically and may have one or more blades.

For the purposes of this document, dampers meeting the definition of a backdraft damper or a UL classified damper shall not be considered a volume control damper. Ultra-low leakage dampers and zero leakage (bubble-tight) dampers may be tested as a volume control damper.

3.1.7 Backdraft damper

A damper which, when mounted in a duct or opening, permits airflow in one direction and prevents airflow in the opposite direction.

3.1.8 UL Classified damper

For the purpose of this document, a device which is classified to Underwriters Laboratories category code EMME (Dampers for Fire Barriers and Smoke Applications) as a smoke damper, combination fire and smoke damper, or corridor damper.

3.1.9 Ultra-low leakage damper

A device that leaks 35.2 L/s/m² (6.93 cfm/ft²) or less at a static pressure differential of 3.0 kPa (12 in. wg). Leakage performance of ultra-low leakage dampers may be certified at any static pressure differential 3.0 kPa (12 in. wg.) or greater as long as the leakage doesn't exceed $2 \times (\Delta P_s)^{0.5}$.