

AMCA Publication 511-10 (Rev. 11-13)

Certified Ratings Program
Product Rating Manual for
Air Control Devices



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

AMCA Publication 511-10 (Rev. 11-13)

Certified Ratings Program Product Rating Manual for Air Control Devices



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority AMCA International Publication 511-10 was approved by the membership of the Air Movement and Control Association International on October 14, 2010.

The August 2012 revision was approved on August 1, 2012.

The November 2013 revision was approved on November 18, 2013.

Copyright © 2013 by Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International Inc. will consider and decide all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

AMCA International Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire, United Kingdom
RG10 9TH

Disclaimer AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

REVIEW COMMITTEE

Marty Gissel Committee Chair	Greenheck Fan Corporation
Mike Binkholder	Mestek Inc.
Jeff Blake	Construction Specialties Inc.
Dane Carey	United Enertech
Eric Gohring	Cesco Products
Jason George	Ruskin Company
Doug Graham	T. A. Morrison & Co. Inc.
Dan Huber	Ruskin Company
Larry Kozak	Ward Industries
Vince Kreglewicz	Arrow United
Tim Malki	Daniel Mechanical Co.
Bin Ngo	Daniel Mechanical Co.
Dan Rau	Ruskin Company
Robert Van Becelaere	Ruskin Company
Tim Orris	AMCA International
John Pakan	AMCA International

Related AMCA Documents

Related Publications

AMCA Publication 11	Certified Ratings Program Operating Manual
AMCA Publication 111	Laboratory Accreditation Program
AMCA Publication 512	AMCA Listing Label Program

Related Standards

ANSI/AMCA Standard 500-D	Laboratory Methods for Testing Dampers for Rating
ANSI/AMCA Standard 500-L	Laboratory Methods for Testing Louvers for Rating
ANSI/AMCA Standard 540	Test Method for Louvers Impacted by Wind Borne Debris
ANSI/AMCA Standard 550	Test Method for High Velocity Wind Driven Rain Resistant Louvers

CONTENTS

1. Purpose	1
2. Scope	1
3. Definitions and Symbols	1
3.1 Definitions	1
3.2 Symbols	2
4. Data Submittal Requirements	2
5. Required Catalog Statements	2
5.1 Licensed product statement	2
5.2 Licensed performance statement	2
5.3 Appurtenances statement	2
6. General Guidelines for Air Control Products	3
6.1 Manufacturer's responsibility	3
6.2 AMCA staff responsibility	3
6.3 Rating development	3
6.4 Aerodynamically similar products	3
6.5 Nameplated products	3
7. Check Test Tolerances and Required Tests	3
7.1 Licensee's duty	3
7.2 Tolerances	3
7.3 Required tests	4
8. Louver Air Performance Rating Requirements (page 1 of 2)	5
8. Louver Air Performance Rating Requirements (page 2 of 2)	6
9. Louver Wind-Driven Rain Rating Requirements	7
10. Louver Water Penetration Rating Requirements (page 1 of 2)	8
10. Louver Water Penetration Rating Requirements (page 2 of 2)	9
11. Acoustical Louver Sound Performance Rating Requirements	10
12. Adjustable Louver Air Leakage Rating Requirements	11
13. Damper Air Performance Rating Requirements (page 1 of 2)	12
13. Damper Air Performance Rating Requirements (page 2 of 2)	13
14. Volume Control Damper Air Leakage Rating Requirements (page 1 of 2)	14
14. Volume Control Damper Air Leakage Rating Requirements (page 2 of 2)	15
15. Ultra-Low Leakage Damper Air Leakage Rating Requirements	16
16. Bubble-Tight Damper Air Leakage Rating Requirements	17
17. UL-Classified Damper Air Leakage Rating Requirements	18
18. Backdraft Damper Air Leakage Rating Requirements	19

20. Round Spiral Duct Air Leakage Rating Requirements	22
21. Louver/Damper Energy Efficiency Rating Requirements	23
22. Transverse Duct Connectors Air Leakage Rating Requirements (page 1 of 2)	24
22. Transverse Duct Connectors Air Leakage Rating Requirements (page 2 of 2)	25
Annex A Electronic Catalogs (Normative)	26
Annex B Measurements (Normative)	28
Annex C Developing Air Control Product Catalogs (Informative)	31

Product Rating Manual for Air Control Devices

1. Purpose

AMCA Publication 511 dictates proper presentation of data and other required technical procedures for certification of air control devices under the AMCA Certified Ratings Program. This manual shall be used in conjunction with the current edition of AMCA Publication 11.

2. Scope

The products within the scope of this program are air control devices for use in general ventilation and air conditioning systems.

This program shall apply only to complete cataloged series of sizes. It shall not apply to individual sizes in a series, or part of a series of sizes, or to special units on which catalog ratings are not published.

The AMCA Certified Ratings seal shall be used only in connection with the specifically licensed device. The AMCA Seal shall be used only on complete units. The application of the AMCA seal to individual component parts, such as blades, frames, etc., is not permitted.

3. Definitions and Symbols

3.1 Definitions

All definitions found in AMCA Publication 11, as well as the definitions in this section, apply to this program.

3.1.1 Appurtenance

Appurtenance is any item in the air stream or on the inlet or discharge of the air control device that may affect the performance of the air control device.

An appurtenance shall be considered a part of the air control device if it is in place when the device is tested for performance rating and the effect of the appurtenance is included in the cataloged performance rating.

3.1.2 AMCA Certified Ratings Program

The Certified Ratings Program is a program for certifying a product's performance ratings, as defined in this document.

3.1.3 Performance rating(s)

Performance ratings are data generated from actual tested products used to derive the certified and published information.

3.1.4 Shall and should

The word "shall" indicates a mandatory requirement; the word "should" indicates an advisory statement.

3.1.5 Aerodynamically similar

Louver and damper designs are considered to be aerodynamically similar if the profiles of the components in the air stream are geometrically similar. The blades shall be in relative position to the frame and the center-to-center dimensions shall be the same. Frame, blade stops and blade profiles may have slight variances due to manufacturing methods. Blades must have the same streamline shape in that their leading and trailing edges shall be dimensionally equal. The overall angle or curvature of the blade must be the same. Slight deviations in material thickness shall not reduce the overall free area by more than 5% for dampers and 2.5% for louvers. Blade seals shall have the same profile, be of the same durometer and be secured to the blade in the same manner.

In addition to the requirements described above, louver or damper models claiming aerodynamic similarity for the purpose of certifying leakage performance shall meet the following criteria:

- The frames and blades shall have a modulus of elasticity (E) greater than or equal to the originally licensed model.
- The blade action (i.e., whether the damper is parallel or opposed blade) shall be the same as the originally licensed model.
- The method used for interconnecting the damper or louver blades (i.e., the linkage) shall be the same as the originally licensed model.
- The jamb seal shall be the same as the originally licensed model.
- The blade axle bearing assemblies shall be the same as the originally licensed model.

3.1.6 Volume control damper

A volume control damper is a device which, when mounted to a duct or opening, is used to vary the volume of air through the duct or opening. It can be operated manually or mechanically and may have one or more blades.

For the purposes of this document, dampers meeting the definition of a backdraft damper or a UL-classified damper shall not be considered a volume control damper. Ultra-low-leakage dampers and bubble-tight dampers may be tested as volume control dampers.