Fan and Air System Applications Handbook AMCA International



Publication 200 Air Systems **Publication 201** *Fans and Systems* **Publication 202** *Troubleshooting*

Publication 203

Field Performance Measurements of Fan Systems This is a preview of "Fan Application Manu...". Click here to purchase the full version from the ANSI store.

Forward

Publication 200

Air Systems

Air Systems is intended to provide basic information needed to design effective and energy efficient air systems. Discussion is limited to systems where there is a clear separation of the fan inlet and outlet and does not cover applications in which fans are used only to circulate air in an open space.

- System Pressure Losses
- Fan Performance Characteristics
- System Effect
- System Design Tolerances

Publication 201 Fans and Systems

Fans and Systems is aimed primarily at the designer of the air moving system and discusses the effect on inlet and outlet connections of the fan's performance. System Effect Factors, which must be included in the basic design calculations, are listed for various configurations. AMCA 202 and AMCA 203 are companion documents.

- Fan Testing and Rating
- The Fan "Laws"
- Air Systems
- Fan and System Interaction
- System Effect Factors

Publication 202 Troubleshooting

Troubleshooting is intended to help identify and correct problems with the performance and operation of the air moving system after installation. AMCA 201 and AMCA 203 are companion documents.

System Checklist

- Fan Manufacturer's Analysis
- Master Troubleshooting Appendices

Publication 203 Field Performance

Measurements of Fan Systems

Field Performance Measurements of Fan Systems reviews the various problems of making field measurements and calculating the actual performance of the fan and system. AMCA 201 and AMCA 202 are companion documents.

- Acceptance Tests
- · Test Methods and Instruments
- Precautions
- · Limitations and **Expected Accuracies**
- Calculations

Review Committee

These members contributed to the final review of the publications contained in this Fan Application Manual.

Tom Berger	Pace Company, Division of York International
Rick Bursh	Illinois Blower, Inc.
Patrick Chinoda	Hartzell Fan, Inc.
Narsaiah Dasa	TLT-Babcock, Inc.
Gerald P. Jolette	AMCA Staff
Robert L. Lanier	Phelps Fan Manufacturing Co., Inc.
Tung Nguyen	Emerson Ventilation Products
Sutton G. Page	Austin Air Balancing Corp.
Scott Phillips	The New York Blower Company
Neil H. Rutherford	Delhi Industries, Inc.
Jack E. Saunders	Barry Blower/Snyder General Corp.
Paul R. Saxon	AMCA International
Erling Schmidt	Novenco, Inc.
Mark Schultz	American Fan Company
William Smiley	The Trane Company
James L. Smith	Aerovent, Inc.
Charles R. Voss	Phelps Fan Manufacturing Co., Inc.
Robert H. Zaleski	Acme Engineering & Manufacturing Corp.

Disclaimer

This manual has been prepared by the Air Movement and Control Association, Inc. The information contained in this manual has been derived from many sources and is believed to e accurate. Please note that the recommendations contained herein do not necessarily represent the only methods or procedures appropriate for the situation discussed, but rather are inteded to present consensus opinions and practices of the air movement and control industry which may be helpful, or of interest to those who design, test, install, operate or maintain fan-duct systems. Thus, AMCA disclaimes any and all warranties, expressed or implied, regarding the accuracy of the information contained in this maual and further disclaims any liability for the use or misuse of this information. AMCA does not guarantee, certify or assure the performance of any fan-duct system designed, tested, installed, operated or maintained on the basis of the information provided in this manual.

Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International 30 West University Drive Arlington Heights, IL 60004-1893 U.S.A.

or

AMCA International, Incorporated c/o Federation of Environmental Trade Associations 2 Waltham Court, Milley Lane, Hare Hatch Reading, Berkshire RG10 9TH United Kingdom

Table of Contents

Publication 200 Air Systems

- 1 Introduction
- 3 Symbols and Subscripts
- 4 Properties of Air
- 5 Airflow
- 13 The Flow System
- 34 System Design and Tolerances
- 40 Annex A SI / I-P Conversion Table
- 41 Annex B Standard Atmospheric Data Versus Altitude Charts
- 43 Annex C Psychrometric Density Tables
- 47 Annex D Friction Charts
- 49 Annex E Air Density Correction Factor Charts

Publication 201 Fans and Systems

- 51 Introduction
- 51 Symbols and Subscripts
- 51 Fan Testing
- 54 Fan Ratings
- 63 Catalog Performance Tables
- 66 Air Systems
- 74 System Effect Factor (SEF)
- 79 Outlet System Effect Factors
- 88 Inlet System Effect Factors
- 99 Effects of Factory Supplied Accessories 49
- 102 Annex A. SI / I-P Conversion Table (Informative)
- 103 Annex B. Dual Fan Systems Series and Parallel
- 106 Annex C. Definitions and Terminology
- 113 Annex D. Examples of the Convertibility of Energy from Velocity Pressure to Static Pressure
- 120 Annex E. References

Table of Contents (continued)

Publication 202 Troubleshooting

- 122 Introduction
- 122 Procedure for Troubleshooting
- 122 Safety Precautions
- 122 System Checklist
- 128 Fan Manufacturer's Analysis
- 130 Conclusion
- 131 Annex A. Noise
- 134 Annex B. Insufficient Airflow
- 136 Annex C. Airflow High
- 137 Annex D. Static Pressure Wrong
- 139 Annex E Power High
- 140 Annex F Fan Does Not Operate
- 141 Annex G Premature Failure
- 142 Annex H Vibration

Publication 203 Field Performance Measurement of Fan Systems

- 145 Introduction
- 145 Scope
- 145 Types of Field Tests
- 146 Alternatives to Conducting Field Tests
- 146 System Effect Factors
- 146 Fan Performance
- 146 Referenced Planes
- 147 Symbols and Subscripts
- 147 Fan Flow Rate
- 152 Fan Static Pressure
- 156 Fan Power Input
- 158 Fan Speed
- 158 Densities

Table of Contents (continued)

- 159 Conversion Calculations
- 160 Test Preparation
- 161 Precautions
- 161 Typical Fan-System Installations
- 165 Annex A Field Test Examples
- 241 Annex B Pitot-Static Tubes
- 242 Annex C Double Reverse Tube
- 243 Annex D Pitot-Static Tube Holder
- 244 Annex E Static Pressure Tap
- 245 Annex F Pitot-Static Tube Connections
- 246 Annex G Manometer Data
- 248 Annex H Distribution of Traverse Points
- 250 Annex J Instrumentation Characteristics
- 252 Annex K Phase Current Method for Estimating the Power Output of Three Phase Fan Motors
- 254 Annex L Estimated Belt Drive Loss
- 256 Annex M Density Determinations
- 260 Annex N Density Charts and Tables
- 269 Annex P Diffusion at Fan Outlets
- 270 Annex R Diffusion at Fan Outlets
- 274 Annex S Typical Format for Field Test Data
- 275 Annex T Uncertainties Analysis

Air Systems

<u>200</u>

1. Introduction

An air system is any assembly of ducts, filters, conditioning devices, dampers, louvers, fans, etc., the main purpose of which is to move air from one place to another in a controlled fashion. Most air systems draw air from one space and discharge it into another.

Air systems are often required to operate satisfactorily in a wide range of environmental conditions. The conditions which will be encountered must be considered in the design of the ducts, pipes, etc., which will contain the airflow and constitute the boundary of the system.

1.1 Air system components

A typical air system may contain one or more of the following (see Figure 1):

- a) System inlet
- b) Distribution system
- c) Fan
- d) Control device
- e) Conditioning device
- f) System outlet

1.1.1 System inlet. An air system usually includes devices such as louvers, filters, screens, guards, grilles, etc., where the air enters the system. These are used for safety reasons as well as to inhibit the entry of rain, dust, and other unwanted matter. Their appearance may be important as they are usually visible on the exterior of a structure.

1.1.2 Distribution system. Most air systems are made up of ducts specially designed and constructed to convey air from the system inlet(s) to the system outlet(s). In some cases, enclosed spaces in the structure such as plenums above ceilings or holes in walls may be used to confine and direct the flow.

1.1.3 Fan. Understanding the design and opera-tion of air systems begins with an understanding of the various types of fans, their performance characteristics, and their applications.

A fan is required in order to produce the pressure differential which results in the flow of air through a system. The fan must be carefully selected to meet the specified airflow and pressure for proper system operation. Different fan designs produce different pressure-volume and fan power relationships, which are critical to air system operation. Refer to Figure 4.2, AMCA Publication 201-90.

1.1.4 Control devices. In many air systems it is necessary to regulate and control the flow through the system in response to some monitoring signal, usually temperature or pressure. It may be also necessary to regulate the flow in the individual branches of the system. Control devices such as dampers function by controlling the amount of airflow. In some cases, the output of the fan can be varied by other methods (variable speed motor, variable inlet vanes, variable pitch impeller, etc.)

1.1.5 Conditioning device. Most air systems are designed to take air from the inlet and change its condition before discharging it at the outlet. Changes may include the temperature, humidity, pressure, contaminant level and cleanliness, etc., of the air. Many conditioning devices require outside energy sources, for example, heating and cooling coils; other components such as filters are passive devices and have no external energy connection. All conditioning devices increase the pressure drop across the system and this effect must be considered in the selection of the fan.

1.1.6 System outlet. An air system usually includes a special component at the termination of the system or at the end of each of the system's branches, such as a simple screen or louver. In many cases the distribution of the air at the outlet to the receiving space is very important, e.g., in an occupied air conditioned room. These systems require carefully selected outlets and diffusing devices to achieve desirable air motion and temperature conditions in the conditioned space. Typical devices are ceiling diffusers and grilles. In some cases these may incorporate control devices such as dampers and mixing boxes.