

American Nuclear Society


WITHDRAWN

April 9, 1990
ANSI/ANS-55.6-1979

**liquid radioactive waste
processing system for
light water reactor plants**

an American National Standard

**No longer being maintained as an
American National Standard. This
standard may contain outdated
material or may have been superseded
by another standard. Please contact
the ANS Standards Administrator for
details.**



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

This is a preview of "ANSI/ANS-55.6-1979". Click [here](#) to purchase the full version from the ANSI store.

**American National Standard
Liquid Radioactive Waste
Processing System for
Light Water Reactor Plants**

**Secretariat
American Nuclear Society**

**Prepared by the
American Nuclear Society
Standards Committee
Working Group ANS-55.6**

**Published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA**

**Approved April 24, 1979
by the
American National Standards Institute, Inc.**

Abstract This standard sets forth minimum design, construction and performance requirements, with due consideration for operation, for Liquid Radioactive Waste Processing Systems for light water reactor plants, for routine operation including design basis fuel leakage, and other design basis occurrences. Design requirements and recommendations, as well as quality requirements, are presented. Various methods of treating and disposing of input quantities of liquid radioactive waste are discussed along with sizing, capacity, arrangement and redundancy of the systems. Instrumentation and control requirements are provided as well as operating guidance to assure that the performance, safety and operational objectives of this standard are met.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of this standard may receive current information, including interpretation, on all standards published by the American Nuclear Society by calling or writing to the Society.

Published by

American Nuclear Society
555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Price: \$35.00

Copyright © 1979 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard, ANSI/ANS-55.6-1979, with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard Liquid Radioactive Waste Processing System for Light Water Reactor Plants, ANSI/ANS-55.6-1979.)

This standard supersedes the American National Standard for Liquid Radioactive Waste Processing System for Pressurized Water Reactor Plants, N199-1976, (ANS-55.2) and the American National Standard Liquid Radioactive Waste Processing System for Boiling Water Reactor Plants, N197-1976 (ANS-55.3)

A major aspect of nuclear power plant operation is management of the liquid radioactive waste generated as a by-product of nuclear power. Various quantities of liquid radioactive waste are generated by operation and maintenance activities and are dependent upon several factors including design conditions, type of equipment, equipment arrangement and operating philosophy. The development of facilities and equipment to handle and process liquid radioactive waste has provided the nuclear industry with the capability to maintain releases of radioactive material in liquid effluents within applicable regulatory requirements.

It is the purpose of this standard to establish uniform practices and minimum requirements for design, construction, and performance, with due consideration for operation of liquid radioactive waste processing systems. Adherence by system designers to the criteria contained in the standard will enable the operator; (a) to control, to regulatory levels, radiation exposures to operating personnel, (b) to assure a low probability of accidental release of radioactivity from the system, and (c) to control system releases of radioactivity, during and following design-basis inputs, as low as is reasonably achievable. It is not the intent of this standard to develop a "standard system" for processing liquid radioactive waste; it is clearly recognized that there is a wide variety of systems and equipment now in use and others continually being developed.

A number of designs, concepts, operating system histories and practices were reviewed in preparation of this standard. In addition applicable U.S. Nuclear Regulatory Commission (NRC) regulatory guides were considered in the development of this standard.

The requirements of this standard consider that the Liquid Radioactive Waste Processing Systems are operated on a level commensurate with other facility operations. This standard establishes the minimum quality requirements for the design, construction and operation of the system.

This standard employs a technique using a discrimination device called "boxing." This technique indicates those statements which are nuclear safety related. The term "nuclear safety" includes those requirements that are felt by the writing group to arise from official and implied NRC policies (including regulations, regulatory guides, branch positions, the Standard Review Plan, and past practice on applications) *as well as* other requirements the group believes are related to nuclear safety. Non-nuclear safety related requirements include the following types of needs as they exclusively apply to areas not considered to be nuclear safety related: conventional safety, equipment reliability, plant availability, good engineering practice, and contractual (commercial) requirements.

This standard was prepared by Working Group ANS-55.6 of the Standards Committee of the American Nuclear Society. The members of the Working Group were:

- | | |
|--|---|
| F. W. Hartley, Chairman, <i>Arizona Public Service Company</i> | M. C. Giuffre, <i>Commonwealth Edison Company</i> |
| J. S. Baron, <i>Stone and Webster Engineering Corporation</i> | S. A. Lamanna, <i>Babcock and Wilcox Company</i> |
| J. A. Battaglia, <i>Westinghouse Electric Corporation</i> | J. Y. Lee, <i>U.S. Nuclear Regulatory Commission</i> |
| R. E. Brisco, <i>Northeast Nuclear Energy Company</i> | P. D. Paquette, <i>Process Systems</i> |
| C. F. Falk, <i>General Electric Company</i> | G. A. Tidrick, <i>Pacific Gas and Electric Company</i> |
| G. D. Frieling, <i>Wisconsin Electric Power Company</i> | S. F. Wisla, <i>Consolidated Edison Co. of New York</i> |
| | T. R. Young, <i>Combustion Engineering, Inc.</i> |

The membership of Subcommittee ANS-50, the Power Reactor System Committee, at the time of its approval of this standard was:

- | | |
|--|---|
| J. F. Mallay, Chairman, <i>Babcock & Wilcox Company</i> | C. C. Lawrence, <i>Baltimore Gas & Electric Company</i> |
| R. E. Basso, <i>Catalytic, Inc.</i> | J. H. Noble, <i>Stone & Webster Engineering Corporation</i> |
| D. A. Campbell, <i>Westinghouse Electric Corporation</i> | T. J. Pashos, <i>Nuclear Services Corporation</i> |
| C. O. Coffey, <i>Kaiser Engineers</i> | D. R. Patterson, <i>Tennessee Valley Authority</i> |
| W. H. D'Ardenne, <i>General Electric Company</i> | J. W. Stacy, <i>Yankee Atomic Electric Company</i> |
| F. A. Dougherty, <i>EDS Nuclear Inc.</i> | G. C. Vellender, <i>Fluor-Pioneer</i> |
| J. R. Floyd, <i>Metropolitan Edison Company</i> | G. P. Wagner, <i>Commonwealth Edison Company</i> |
| C. J. Gill, <i>Bechtel Power Corporation</i> | M. D. Weber, <i>American Nuclear Society</i> |
| A. R. Kasper, <i>Combustion Engineering, Inc.</i> | G. L. Wessman, <i>General Atomic Company</i> |
| R. W. Keaten, <i>Atomics International Division, North American Rockwell Corporation</i> | J. E. Windhorst, <i>Southern Company Services, Inc.</i> |
| M. Kehnemuyi, <i>U.S. Nuclear Regulatory Commission</i> | F. C. Zapp, <i>Oak Ridge National Laboratory</i> |

The American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) had the following membership at the time it balloted this standard in October 1978:

- J. F. Mallay, *Chairman*
M. D. Weber, *Secretary*

Organization Represented

Name of Representative

U.S. Nuclear Regulatory Commission	G. A. Arlotto
Catalytic, Inc.	R. E. Basso
Institute of Electrical and Electronics Engineers (General Atomic Company).....	R. G. Benham
Institute of Electrical and Electronics Engineers (Knolls Atomic Laboratory).....	O. W. Bilharz, Jr., (Alt)
Pacific Gas and Electric Company	R. V. Bettinger
Westinghouse Advanced Reactor Division.....	P. Bradbury
Westinghouse Electric Corporation.....	D. A. Campbell
Kaiser Engineers.....	C. O. Coffey
Philadelphia Electric Company	M. J. Cooney
Nebraska Public Power District	L. J. Cooper
General Electric Company	W. H. D'Ardenne
U.S. Department of Energy.....	F. X. Gavigan
Bechtel Power Corporation	C. J. Gill
U.S. Environmental Protection Agency	J. M. Gruhlke
Combustion Engineering, Inc.....	A. R. Kasper
GPU Service Corporation	R. W. Keaten
Fluor Power Services.....	D. M. Leppke
American Nuclear Society (Babcock & Wilcox Company).....	J. F. Mallay
United Engineers and Constructors	A. T. Molin
Stone & Webster Engineering Corporation.....	J. H. Noble
Nuclear Services Corporation.....	T. J. Pashos
Tennessee Valley Authority	D. R. Patterson
Atomics, International.....	M. E. Remley
Yankee Atomic Electric Company	J. W. Stacy
Commonwealth Edison Company	G. Wagner
General Atomic Company	G. L. Wessman
American Society of Mechanical Engineers (Southern Company Services).....	J. E. Windhorst
NUS Corporation	E. R. Wiot

Contents	Section	Page
	1. Scope	1
	2. Definitions	1
	2.1 Limitations	1
	2.2 Glossary of Terms	1
	3. Objectives	2
	3.1 Performance Objectives	2
	3.2 Safety Objective.....	3
	3.3 Operation Objective	3
	4. System Requirements	3
	4.1 Process Design	3
	4.2 System Design	6
	4.3 Quality Assurance.....	7
	5. Equipment Requirements.....	8
	5.1 Tanks and Sumps.....	8
	5.2 Pumps.....	8
	5.3 Valves and Piping.....	8
	5.4 Ion Exchange	9
	5.5 Filters.....	9
	5.6 Evaporators.....	9
	5.7 Reverse Osmosis	9
	6. Controls and Instrumentation	9
	6.1 Process Instrumentation and Controls.....	10
	6.2 Process and Effluent Radiation Monitoring.....	11
	7. Physical Arrangement.....	11
	7.1 Criteria for Shielding and Arrangement	11
	7.2 Arrangement for Operation	11
	7.3 Arrangement for Maintenance	12
	7.4 Arrangement for Maintenance of Equipment with Accumulated Activity	12
	8. Capacity and Redundancy	12
	8.1 Design Basis Inputs for BWR Plants	12
	8.2 System Capacity for BWR Plants.....	13
	8.3 Design Basis Inputs for PWR Plants	14
	8.4 System Capacity for PWR Plants	14
	8.5 Redundancy.....	14
	9. Operation and Maintenance	14
	9.1 System Input Surveillance	15
	9.2 Operational Planning.....	15
	9.3 Maintenance Planning.....	15
	9.4 Operator Training.....	15
	9.5 Written Procedures.....	15
	9.6 Equipment Marking	15
	9.7 Flow Diagrams.....	15

10. Pre-Operational Testing and Cleaning	15
10.1 System Integrity Testing	15
10.2 Cleanness Control During Construction	15
10.3 Operability and Functional Testing	15
11. References.....	16

Figures

Figure 1 Basic BWR Liquid Radioactive Waste Processing Diagram	17
Figure 2 Basic PWR Liquid Radioactive Waste Processing Diagram	18

Tables

Table 1 Decontamination Factors	19
Table 2 Equipment Codes	20
Table 3 Sample Requirements and Recommendations	21
Table 4 Occupancy Time-Dose Rate Classifications	22
Table 5 Instrumentation and Controls	23
Table 6E BWR Plant Design Basis Inputs - High Purity Wastes (English Units)	26
Table 6M BWR Plant Design Basis Inputs - High Purity Wastes (Metric Units)	28
Table 7E BWR Plant Design Basis Inputs - Low Purity Wastes (English Units)	30
Table 7M BWR Plant Design Basic Inputs - Low Purity Wastes (Metric Units)	31
Table 8E BWR Plant Design Basis Inputs - Periodic Process Inputs (English Units)	32
Table 8M BWR Plant Design Basis Inputs - Periodic Process Inputs (Metric Units)	34
Table 9E Probable Inputs to the BWR Plant Processing System - Design Basis Occurrences (English Units)	36
Table 9M Probable Inputs to the BWR Plant Processing System - Design Basis Occurrences (Metric Units).....	37
Table 10E PWR Plant Design Basis Inputs (English Units).....	38
Table 10M PWR Plant Design Basis Inputs (Metric Units)	40

Liquid Radioactive Waste Processing System for Light Water Reactor Plants

1. Scope

This standard sets forth minimum design, construction and performance requirements, with due consideration for operation, of the Liquid Radioactive Waste Processing System for light water reactor plants for design basis inputs. It is applicable for routine operation including design basis fuel leakage and other design basis occurrences.

For the purpose of this standard, the Liquid Radioactive Waste Processing System begins at the interfaces with the reactor coolant pressure boundary and points of discharge in lines from other systems (including the steam generator blowdown system downstream from the outermost containment isolation valve), or at those sumps and floor drains provided for liquid waste with the potential of containing radioactive material; it terminates at the point of controlled discharge to the environment, at the point of interface with the waste solidification system, and at the point of recycle back to storage for reuse. The Liquid Radioactive Waste Processing System is not a "safety system" nor does it contain components that are "Safety Class." The requirements of this standard take precedence over requirements set forth in American National Standard Safety Criteria for the Design of Stationary Boiling Water Reactor Plants, ANSI/ANS-52.1-1978 [1]¹, American National Standard Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants, Sections 2.2 and 2.3, N18.2-1973 (ANS-51.1), [2], and American National Standard Revision and Addendum to Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants N18.2-1973, N18.2a-1975 (ANS-51.8) [3] wherein the definitions of "safety system" and Safety Classes are found. Planned revisions of ANS-52.1 and ANS-51.1/51.8 will delete requirements related to the scope of this standard and reference this stan-

dard for such requirements.

This standard does not include the reactor coolant cleanup system, condensate cleanup systems, the fuel pool cleanup system, sanitary waste system, any nonaqueous liquid system, or controlled area storm drains. It should be noted that the Liquid Radioactive Waste Processing System serves other functions such as maintaining chemical purity for reuse. These functions may place additional requirements and limitations on the processing systems which are outside the scope of this standard.

2. Definition

2.1 Limitations. The definitions given below are of a restricted nature for the purposes of this standard.

2.2 Glossary of Terms

chemical wastes. Liquid radioactive wastes having high conductivity, variable insoluble solids content, variable radioactivity content and not containing soaps, detergents, oils or similar organic materials.

crud. Insoluble particulate materials in the process streams.

controlled area. That portion of a nuclear facility, including outside yard areas, enclosed equipment, systems, and facilities which may contain radioactive material by definition or design. Controlled area does not normally, but may temporarily, include portions of secondary system areas of the plant.

decontamination factor (DF). The ratio of the concentration of the radioactive material in the influent stream to its concentration in the effluent.

decontamination wastes. Liquid radioactive wastes generated by decontamination of radioactive plant components, equipment and

¹Numbers in brackets refer to corresponding numbers in Section 11, References.