

American Nuclear Society

WITHDRAWN

July 26, 2002

ANSI/ANS-2.8-1992

**determining design basis
flooding at power reactor sites**

an American National Standard

**No longer being maintained as an
American National Standard. This
standard may contain outdated
material or may have been
superseded by another standard.
Please contact the ANS Standards
Administrator for details.**



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

**American National Standard
for Determining Design Basis
Flooding at Power Reactor Sites**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-2.8**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA**

Approved July 28, 1992
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

American Nuclear Society
555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Copyright © 1992 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-2.8-1992 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of the American National Standard for Determining Design Basis Flooding at Power Reactor Sites, ANSI/ANS-2.8-1992.)

The purpose of this document is to specify criteria for determining design basis flooding at power reactor sites. This standard was prepared by Working Group ANS-2.8 of ANS-2 Subcommittee, Site Evaluation, of the American Nuclear Society Standards Committee. The directive to the working group was as follows: "Guidelines are to be developed to establish design basis flooding at power reactor sites as a result of river, stream, or seismically induced dam failure; surge, seiche, or wave action flooding, or any combination of these events. Methodology will be described for evaluating the worst site-related flood at a power reactor site caused by either a probable maximum flood on streams and rivers and any dam failures resulting therefrom: a seismically induced dam failure flood; a probable maximum surge and seiche flood; and any attendant wind-generated wave activity associated with these events, or caused by a reasonable combination of less severe events."

This standard covers material that meets the requirements of Section 2.4, Hydrologic Engineering, of Regulatory Guide 1.70, Revision 3, November 1978, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants," issued by the Regulatory Staff of the U.S. Nuclear Regulatory Commission (NRC). This standard does not cover requirements of this Regulatory Guide on the following Standard Format 2.4 sections:

(1) Low Water Considerations—Addressed by American National Standard Evaluation of Surface-Water Supplies for Nuclear Power Sites, ANSI/ANS-2.13-1979 (R1988).

(2) Dispersion, Dilution, and Travel Times of Accidental Releases of Liquid Effluents in Surface Waters—Addressed by American National Standard Evaluation of Radionuclide Transport in Ground Water for Nuclear Power Sites, ANSI/ANS-2.17-1980 (R1989).

(3) Groundwater—Addressed by American National Standard Evaluation of Ground Water Supply for Nuclear Power Sites, ANSI/ANS-2.9-1980 (R1989).

(4) Technical Specifications and Emergency Operation Requirements.

(5) Probable Maximum Tsunami Flooding.

Before preparing the Safety Analysis Report (SAR) Section 2.4, Hydrologic Engineering, for the licensing of nuclear power plants, the applicant should be aware of hydrologic work that has been done by others in the area of interest. Almost invariably, much work can be saved by utilizing all or parts of studies by local, state, and federal agencies. Such information as dimensioned or dimensionless unit hydrographs, loss rates, lag times, historical floods, and geologic and groundwater data, etc., may be obtained from such sources. Sometimes the probable maximum flood has already been derived at the site or at a point near enough to be transposed.

The prime source of such information is the U.S. Army (Corps of Engineers). Other federal agencies that may have useful data are the Bureau of Reclamation, Soil Conservation Service, Weather Service, Geological Survey, Tennessee Valley Authority, Environmental Protection Agency, Federal Energy Regulatory Commission (formerly Federal Power Commission), Federal Emergency Management Agency, and the NRC. Most states have one or more agencies that are concerned with various

aspects of water resources. Power companies, particularly those with hydropower capacity, are another source, as are municipal or regional water-supply organizations.

Safety Analysis Reports for other nuclear plants in the area may also provide useful information. It is also profitable to discuss the specific site in detail with the hydrology staff of the NRC prior to starting preparation of Section 2.4.

The first issue of the standard was approved by the American National Standards Institute, Inc., on November 1, 1976, and was published by the American Nuclear Society as American National Standard for Determining Design Basis Flooding at Power Reactor Sites, N170-1976 (ANS 2.8).

The first revision of the standard was approved on February 17, 1981; it was published as American National Standard ANSI/ANS-2.8-1981.

This revision of the standard was developed by a reconstituted working group of ANS-2.8, which had the following members:

R. M. Noble, Chairman, <i>Noble Consultants, Inc.</i>	J. P. Jacobson, <i>Yankee Atomic Electric Company</i>
B. J. Buehler, Consultant (<i>formerly Tennessee Valley Authority</i>)	Y. J. Tsai, <i>Stone & Webster Engineering Corporation</i>
C. B. Cecilio, <i>Pacific Gas & Electric Company</i>	R. Wescott, <i>U.S. Nuclear Regulatory Commission</i>
G. B. Dougherty, <i>Consultant</i>	Fei-Fan Yeh, <i>Ebasco Services, Inc.</i>

Subcommittee ANS-2, Site Evaluation, of the American Nuclear Society Standards Committee had the following members at the time it approved this revision:

J. K. McCall, Chairman, <i>Pacific Gas & Electric Company</i>	G. W. Nicholas, <i>Dames and Moore</i>
L. L. Beratan, <i>U.S. Nuclear Regulatory Commission</i>	R. M. Noble, <i>Noble Consultants, Inc.</i>
A. Brearley, <i>Sargent & Lundy</i>	D. Ostrom, <i>Southern California Edison Company</i>
L. E. Escalante, <i>Los Angeles Department of Water & Power</i>	D. L. Siefken, <i>Roy F. Weston, Inc.</i>
M. I. Goldman, <i>NUS Corporation</i>	I. Spickler, <i>U.S. Nuclear Regulatory Commission</i>
W. W. Hays, <i>U.S. Geological Survey</i>	J. D. Stevenson, <i>Stevenson & Associates</i>
C. R. McClure, <i>Bechtel Civil and Minerals, Inc.</i>	A. Vaish, <i>PMB Systems Engineers, Inc.</i>
K. T. McLoughlin, <i>New York Power Pool</i>	R. W. Whalin, <i>U.S. Army Corps of Engineers</i>
S. J. Milioti, <i>Impell Corporation</i>	K. Wiedner, <i>Bechtel Power Corporation</i>

The American Nuclear Society's Nuclear Power Plant Standards Committee had the following membership at the time of its approval of this standard:

W. T. Ullrich, Chairman

M. D. Weber, Secretary

Representative

Organization

W. M. Andrews	Southern Company Services, Inc.
F. Boorboor	Impell Corporation
C. O. Coffey	Pacific Gas & Electric Company
L. J. Cooper	Nebraska Public Power District
J. D. Crawford	Combustion Engineering
W. H. D'Ardenne (Vice-chairman)	General Electric Company
S. N. Ehrenpreis	Westinghouse Electric Corporation
S. B. Gerdes	NUS Corporation
C. J. Gill	Bechtel National, Inc.
C. E. Johnson	U.S. Nuclear Regulatory Commission
(Vacant)	Tennessee Valley Authority
R. T. Lancet	Rockwell International Corporation
J. C. McCall	Pacific Gas & Electric Company
J. F. Mallay	Advanced Technology Engineering Systems, Inc.
R. E. Miller	Duke Power Company
J. A. Nevshemal	Toledo Edison Company
P. T. Reichert	Stearns Catalytic, Inc.
B. M. Rice	Duke Power Company (retired)
	(for the Institute of Electrical & Electronics Engineers, Inc.)
J. C. Saldarini	Ebasco Services, Inc.
M. O. Sanford	GPU Nuclear Corporation
S. L. Stamm	Stone & Webster Engineering Corporation
J. D. Stevenson	Stevenson & Associates
	(for the American Society of Civil Engineers)
T. J. Sullivan	Institute of Nuclear Power Operations
C. D. Thomas, Jr.	Yankee Atomic Electric Company
W. T. Ullrich	Philadelphia Electric Company
	(for the American Nuclear Society)
G. P. Wagner	Commonwealth Edison Company
G. L. Wessman	Torrey Pines Technology
G. J. Wrobel	Rochester Gas & Electric Corporation

Contents	Section	Page
	1. Introduction and Scope	1
	1.1 Scope	1
	1.2 Discussion	1
	2. Definitions	1
	3. Hydrologic Description	2
	3.1 Site and Facilities	2
	3.2 Hydrosphere	3
	4. Plant Safety from Floods	3
	4.1 Flood History	3
	4.2 Design Flood Bases	4
	4.3 Flooding Potential	4
	4.4 Effects of Lesser Floods	5
	4.5 Erosion and Scour	5
	4.6 Sedimentation	5
	5. Probable Maximum Flood from Precipitation	5
	5.1 General	5
	5.2 Probable Maximum Precipitation	6
	5.3 Snowpack and Snowmelt Flood	7
	5.4 Runoff and Stream-Course Models	10
	5.5 Hydrologic Dam Failures	11
	5.6 Sediment Transport	13
	5.7 Coincident Wind-Wave Activity	13
	5.8 Probable Maximum Flood Summary	14
	6. Nonhydrologic Dam Failures	14
	6.1 General	14
	6.2 Seismic Dam Failures	15
	6.3 Dam Failures from Other Causes	16
	6.4 Failure and Failure Surge Analysis	16
	6.5 Summary	17
	7. Probable Maximum Surge and Seiche Flooding	17
	7.1 General	17
	7.2 Probable Maximum Winds and Associated Meteorological Parameters	17
	7.3 Surge Water Levels	19
	7.4 Wave Action	23
	7.5 Seiche	28
	8. Ice Flooding	29
	8.1 General	29
	8.2 Ice Effect	29
	8.3 Surface Ice	29
	9. Combined Events Criteria	29
	9.1 General	29
	9.2 Summary of Combined Events Criteria	30

10. Cooling Water Canals and Reservoirs	33
10.1 General	33
10.2 Canals	33
10.3 Reservoirs	33
11. Plant Site Drainage	34
11.1 General	34
11.2 Factors for Consideration	34
11.3 Site Drainage Area	34
11.4 Roof Drainage.....	34
11.5 Grades and Drains.....	35
11.6 Local Intense Precipitation	35
11.7 Model.....	35
11.8 Snow and Ice Accumulation	35
11.9 Summary.....	35
12. References	35
Appendix A—Bibliography	39
Appendix B—Interpreted Probabilities of Combined Events	51
Tables	
Table 1 Example for 3.1.3	2
Table 2 Tide Characteristics	21
Table 3 Hawaii Fastest Mile Quantiles	31
Table 4 Puerto Rico Fastest Mile Quantiles.....	31
Figure 1 Isotach 0.50 Quantiles (in miles per hour): Annual Extreme- Mile, 30 ft Above Ground, 2-yr Mean Recurrence Interval	31



Determining Design Basis Flooding at Power Reactor Sites

1. Introduction and Scope

1.1 Scope. This document presents criteria to establish design basis flooding for nuclear safety-related features at power reactor sites. Methodology is described to evaluate the flood having virtually no risk of exceedance that can be caused by precipitation and snowmelt and any resulting dam failures; seismically induced dam failures; surge or seiche and attendant wind-generated wave activity; or a reasonable combination of these events.

1.2 Discussion. This standard covers that material necessary to develop the design basis flooding for use in the evaluation of the adequacy of a nuclear power plant site. Water-related effects such as water levels, waves, wave forces, ice, erosion, and sedimentation are included to assist in the design of safety-related facilities. Where information presentation requirements are stated in this standard, such as "provide," "tabulate," or "describe," such information shall be provided as a part of the documentation for the design basis flood estimate.

1.2.1 Exclusions. This standard does not cover:

- (1) Probable maximum tsunami flooding.
- (2) Low water considerations.
- (3) Dispersion, dilution, and travel times of accidental releases of liquid effluents.
- (4) Groundwater.
- (5) Technical specification and emergency operation requirements.
- (6) Channel diversions.
- (7) Flooding protection requirements (partially addressed).
- (8) Flooding from pipe rupture or on-site tank failures.

1.2.2 Probabilistic Approach. In this standard, guidelines to determine design basis floods are primarily associated with "probable maximum" events of deterministic origins. The standard does not include guidelines for using a probabilistic approach, including stochastic techniques. It does, however, recommend in 9.1.2 a target annual exceedance probability of less than 1×10^{-6} for selecting combined events that collectively comprise design bases floods.

At the time this standard was prepared, there were no recognized procedures to accurately and objectively define the exceedance probabilities of significant rare events included in probable maximum analysis. As data and procedures improve, probabilistic approaches are encouraged. The exclusion of probabilistic approaches from this standard should not be construed in a manner to inhibit innovation because preferred methodology for a particular case could likely be beneficial and acceptable for a specific site.

2. Definitions

moving squall line. A line or narrow band of active thunderstorms having a pressure jump with the cold front providing the initial piston-like impetus, and a mature instability line that is located in the warm sector of a wave cyclone about 50 to 200 miles in advance of a cold front usually oriented roughly parallel to the cold front and moving in about the same direction and speed as the cold front.

probable maximum flood (PMF). The hypothetical flood (peak discharge, volume, and hydrograph shape) that is considered to be the most severe reasonably possible, based on comprehensive hydrometeorological application of probable maximum precipitation and other hydrologic factors favorable for maximum flood runoff such as sequential storms and snowmelt.

probable maximum gradient wind. A probable gradient wind of a designated duration above the surface friction layer, of which there is virtually no risk of being exceeded. The event may be considered to have a probability of occurrence comparable to that of a probable maximum precipitation.

probable maximum hurricane (PMH). A hypothetical hurricane having that combination of characteristics that makes it the most severe that can reasonably occur in the particular region involved. The hurricane approaches the point under study along a critical path and at an optimum rate of movement, which results in the most adverse flooding.