

American Nuclear Society

WITHDRAWN


June 7, 2010

ANSI/ANS-57.9-1992;R2000;W2010

**design criteria for an independent spent
fuel storage installation (dry type)**

an American National Standard

**No longer being maintained as an
American National Standard. This
standard may contain outdated material
or may have been superseded by another
standard. Please contact the ANS
Standards Administrator for details.**



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA

ANSI/ANS-57.9-1992 (R2000)

**American National Standard
Design Criteria for an Independent Spent
Fuel Storage Installation (Dry Type)**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-57.9**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved May 14, 1992; Reaffirmed June 7, 2000
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

American Nuclear Society
555 North Kensington Avenue, La Grange Park, Illinois 60526 USA

Copyright © 1993 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-57.9-1992 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not part of American National Standard Design Criteria for an Independent Spent Fuel Storage Installation (Dry Type), ANSI/ANS-57.9-1992.)

This standard provides design criteria for an independent spent fuel storage installation (ISFSI) for light water reactor spent fuel that incorporates one or more of the dry storage concepts. The dry storage concepts covered include three major types: cask (silo), drywell (caisson), and vault (canyon). The standard sets down performance and design requirements along with general guidelines that will assist in the design and licensing efforts. Also presented are interface requirements where the installation is located at an existing nuclear facility. The standard is intended to be consistent with and provide guidance in meeting the requirements of the regulations in Title 10, "Energy," Code of Federal Regulations, Part 72, "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel and High-Level Radioactive Waste."

An ISFSI provides for the custody of spent fuel in a stable and quiescent state pending its future disposition. This does not preclude mechanical handling activities related to fuel storage, such as rod consolidation and the canning of assemblies or consolidated fuel rods. Such activities do not involve the exposure of the fuel itself to an uncontrolled environment.

Although the spent fuel is in passive storage, decay heat and the small volume of pressurized gas within the fuel rods are mechanisms that have the potential for causing off-site release of the radionuclides contained in the spent fuel. To lessen the effect of these mechanisms, the spent fuel is kept in storage at the nuclear power plant for at least 1 yr after reactor discharge before being transferred to an ISFSI. The radiological protection requirements for personnel occupancy of the storage area set forth in the standard are based on the principle of maintaining occupational exposure consistent with the as low as reasonably achievable (ALARA) principle.

In general, the safe storage of spent fuel assemblies is achieved by maintaining a minimum of two independent barriers between the fuel and the environs. The fuel cladding is considered the primary barrier for undamaged fuel. Fuel cladding is designed to withstand a far more severe environment in the reactor than in the low-temperature conditions of static storage at an ISFSI. The confinement integrity of the cladding is to be maintained during handling and storage in the ISFSI. In addition, the complete confinement system for the stored fuel is conservatively designed to withstand damaging events, including earthquake or other extreme natural phenomena, so that there is an effective secondary barrier(s) to the release of radioactive materials under all credible conditions.

A section is provided that identifies interface considerations for shared systems and facilities in those cases where the ISFSI is located at or near an existing nuclear facility. An ISFSI that cannot be demonstrated to be independent of a nuclear facility in respect to all support services that are important to confinement cannot be licensed under 10 CFR 72. In such cases, the criteria and performance requirements set forth herein might not be applicable. Appendices that are not part of the mandatory criteria of the standard are provided for information and clarification.

American National Standard Criteria for Nuclear Criticality Safety Controls in Operations with Shielding and Confinement, ANSI/ANS-8.10-1983(R1988), provides general guidelines for nuclear criticality safety in shielded facilities. It permits a single failure to result in criticality in facilities where personnel are adequately protected by radiation shielding. The ISFSI standard requires that the more conservative criterion be utilized in the nuclear power industry so that no single failure can result in nuclear criticality.

The membership of Working Group ANS-57.9 of the Standards Committee of the American Nuclear Society during the development of this document was as follows:

| | |
|--|---|
| J. A. Nevshemal, Chairman, <i>Toledo Edison Company</i> | M. E. Mason, <i>Transnuclear, Inc.</i> |
| G. J. Antonucci, <i>NUS Corporation</i> | J. A. McBride, <i>E. R. Johnson Associates, Inc.</i> |
| W. H. Baker, <i>E. I. duPont deNemours and Company</i> | P. N. McCreery, <i>Transnuclear, Inc.</i> |
| C. R. Bolmgren, <i>Westinghouse Electric Corporation</i> | J. B. Moegling, <i>Tennessee Valley Authority</i> |
| T. L. Bradley, <i>Duke Power Company</i> | S. J. Naqvi, <i>Ontario Hydro</i> |
| C. L. Brown, <i>Rockwell Hanford Operations</i> | D. W. Reisenweaver, <i>U.S. Nuclear Regulatory Commission</i> |
| S. H. Popper, <i>Stone & Webster Engineering Corporation</i> | I. H. Sargent, <i>WESTEC Services, Inc.</i> |
| D. Deacon, <i>GEC Energy Systems Ltd., England</i> | G. A. Tidrick, <i>Pacific Gas & Electric Company</i> |
| W. L. Dobson, <i>Gilbert/ Commonwealth Companies</i> | |
| E. R. Gilbert, <i>Battelle Pacific Northwest Laboratories</i> | |

Other individuals who contributed directly to the development of this standard by participation, review, and comment at the working group's working sessions are as follows:

| | |
|---|---|
| G. Bushnell, <i>Stone & Webster Engineering Corporation</i> | R. W. Lambert, <i>Electric Power Research Institute</i> |
| N. H. Davison, <i>U.S. Nuclear Regulatory Commission</i> | L. Duncan Schlesinger, <i>Ebasco Services</i> |
| C. J. Ealing, <i>GEC Energy Systems Ltd., England</i> | |

At the time of the standard's approval, Subcommittee ANS-55, Fuel and Waste Management, of the American Nuclear Society Standards Committee, had the following membership:

| | |
|--|---|
| G. P. Wagner, Chairman, <i>Commonwealth Edison Company</i> | R. E. Schreiber, <i>Battelle Pacific Northwest Laboratories</i> |
| L. J. Cooper, <i>Nebraska Public Power District</i> | |

The American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) had the following membership at the time of its ballot for approval of this standard:

W. T. Ullrich, Chairman
M. D. Weber, Secretary

| | |
|---------------------------------|---|
| W. M. Andrews | Southern Company Services, Inc. |
| F. Boorboor | Impell Corporation |
| C. O. Coffey | Pacific Gas & Electric Company |
| L. J. Cooper | Nebraska Public Power District |
| J. D. Crawford | Combustion Engineering Corporation |
| W. H. D'Ardenne (Vice Chairman) | General Electric Company |
| R. L. Domer | Pacific Gas & Electric Company |
| S. N. Ehrenpreis | Westinghouse Electric Corporation |
| S. B. Gerges | NUS Corporation |
| C. J. Gill | Bechtel National, Inc. |
| M. L. Hellums | Tennessee Valley Authority |
| C. E. Johnson | U.S. Nuclear Regulatory Commission |
| R. T. Lancet | Rockwell International Corporation |
| J. F. Mallay | Advanced Technology Systems, Inc. |
| R. E. Miller | Duke Power Company |
| J. A. Nevshemal | Toledo Edison Company |
| W. M. Rice | Duke Power Company (retired) |
| | (for the Institute of Electrical and Electronics Engineers) |
| J. C. Saldarini | Ebasco Services, Inc. |
| M. O. Sanford | GPU Nuclear Corporation |
| S. L. Stamm | Stone & Webster Engineering Corporation |
| J. D. Stevenson | Stevenson & Associates |
| | (for the American Society of Civil Engineers) |
| T. J. Sullivan | Institute of Nuclear Power Operations |
| C. D. Thomas, Jr. | Yankee Atomic Electric Company |
| W. T. Ullrich | Philadelphia Electric Company |
| | (for the American Nuclear Society) |
| G. P. Wagner | Commonwealth Edison Company |
| G. L. Wessman | Torrey Pines Technology |
| G. J. Wrobel | Rochester Gas & Electric Corporation |

| Contents | Section | Page |
|-----------------|--|-------------|
| 1. | Introduction | 1 |
| 1.1 | Scope | 1 |
| 1.2 | Limits of Application | 1 |
| 1.3 | Operating Functions | 1 |
| 1.4 | Overall Design Bases | 2 |
| 1.5 | Application of Codes and Standards | 2 |
| 2. | Definitions | 2 |
| 3. | Installation Function | 4 |
| 4. | ISFSI Systems | 5 |
| 4.1 | Transportation Package Handling Area | 5 |
| 4.2 | Fuel Unit Handling Area | 5 |
| 4.3 | Fuel Unit Transfer Area | 5 |
| 4.4 | Storage Area | 6 |
| 4.5 | Heating, Ventilation, and Air Conditioning (HVAC) | 6 |
| 4.6 | Buildings | 6 |
| 4.7 | Radwaste Treatment | 6 |
| 4.8 | Electrical Power, Instrumentation and Control (I&C), and Communications | 6 |
| 4.9 | Fire Protection | 6 |
| 4.10 | Physical Protection | 6 |
| 4.11 | Accountability | 6 |
| 4.12 | Nuclear Criticality Safety | 6 |
| 4.13 | Radiological Protection | 6 |
| 5. | ISFSI Performance Requirements | 6 |
| 5.1 | Transportation Package Handling Area | 7 |
| 5.2 | Fuel Unit Handling Area | 7 |
| 5.3 | Fuel Unit Transfer Area | 8 |
| 5.4 | Fuel Unit Storage Area | 8 |
| 5.5 | Heating, Ventilation, and Air Conditioning (HVAC) | 9 |
| 5.6 | Buildings | 9 |
| 5.7 | Radwaste Treatment | 9 |
| 5.8 | Electrical Power, Instrumentation and Control (I&C), and Communications | 9 |
| 5.9 | Fire Protection | 10 |
| 5.10 | Physical Protection | 10 |
| 5.11 | Accountability | 10 |
| 5.12 | Nuclear Criticality Safety | 10 |
| 5.13 | Radiological Protection | 10 |
| 6. | Design Requirements | 10 |
| 6.1 | Transportation Package Handling Area | 10 |
| 6.2 | Fuel Unit Handling Area | 12 |
| 6.3 | Fuel Unit Transfer Area | 16 |
| 6.4 | Storage Area | 17 |
| 6.5 | Heating, Ventilation, and Air Conditioning (HVAC) | 20 |
| 6.6 | Buildings | 21 |
| 6.7 | Radwaste Treatment | 22 |

| | | |
|------------------------|--|-------|
| 6.8 | Electrical Power, Instrumentation and Control (I&C), and Communications | 22 |
| 6.9 | Fire Protection | 23 |
| 6.10 | Physical Protection | 25 |
| 6.11 | Accountability | 26 |
| 6.12 | Nuclear Criticality Safety | 26 |
| 6.13 | Radiological Protection | 26 |
| 6.14 | Decommissioning | 27 |
| 6.15 | Quality Assurance | 27 |
| 6.16 | Interfaces for an ISFSI Located on an Existing Nuclear Facility Site | 28 |
| 6.17 | Structural Design | 28 |
| 7. | References | 29 |
| Appendices | | |
| Appendix A | Illustrative Flow Diagrams and Storage Concepts | 32 |
| Appendix B | Guidance for Computing the Limiting Fuel Temperatures During Storage in Unlimited, Limited Air, and Nonoxidizing Atmospheres | 39 |
| Appendix C | Characteristics of Typical LWR Spent Fuel Shipping Casks That May Interface with an ISFSI (Dry) | 42 |
| Appendix D | Physical Characteristics of Typical LWR Fuel Assemblies | 43 |
| Appendix E | Source Terms | 47 |
| Appendix F | Guidelines for Nuclear Criticality Safety Considerations | 52 |
| Appendix G | Guidelines for Radiological Risk Assessment | 56 |
| Appendix H | Seismic Analysis | 58 |
| Figures | | |
| Figure A-1 | Illustrative ISFSI Flow Diagram | 32 |
| Figures A-2 through -4 | Illustrative Internal Movement Diagrams | 33–35 |
| Figures A-5 through -7 | Illustrative Storage Concepts | 36–38 |
| Figure F-1 | Water Added Between Assemblies, Then to Assemblies | 54 |
| Figure F-2 | Water Added to Assemblies, Then Between Assemblies | 55 |
| Figure F-3 | Water Added Simultaneously Between and to Assemblies | 55 |
| Tables | | |
| Table D-1 | Principal Characteristics of Representative PWR Nuclear Fuels from Babcock & Wilcox and Combustion Engineering .. | 43 |
| Table D-2 | Principal Characteristics of Representative PWR Nuclear Fuels from Westinghouse | 44 |
| Table D-3 | Principal Characteristics of Representative PWR Nuclear Fuels from Exxon | 45 |
| Table D-4 | Principal Characteristics of Representative PWR Nuclear Fuels from General Electric and Exxon | 46 |
| Table E-1 | PWR Representative Decay Heat Generation Rates | 47 |
| Table E-2 | Guidance Data on LWR Fuel Crud | 48 |
| Table E-3 | Guidance Data on PWR Fuel Crud | 48 |
| Table E-4 | Guidance Data on BWR Fuel Crud | 49 |
| Table E-5 | Parameters Used to Calculate Radiation Source Terms | 49 |
| Appendix E3 | Tables | 50 |
| Table F-1 | Density of Various Water Forms | 52 |

Design Criteria for an Independent Spent Fuel Storage Installation (Dry Type)

1. Introduction

This standard provides design criteria for systems and equipment of an installation for the receipt and storage of spent fuel from light water reactors (LWRs) or from water pool-type independent spent fuel storage installations. The standard addresses only dry storage, which includes vault, metal cask, concrete silo, and drywell. The standard also addresses the preparation and reshipment of spent fuel to a geological repository. The standard presents interface requirements for shared systems and facilities for the situation where the installation is located at or near an existing nuclear facility.

Consolidation of whole fuel assemblies at the installation is covered by the standard. This installation is independent of nuclear power stations and reprocessing facilities and may or may not be located at an existing nuclear power station or reprocessing site. This installation is designed to receive and indefinitely store spent fuel elements that have experienced cooling times in excess of 1 yr at an in-plant facility, at another independent spent fuel storage installation, or both.

1.1 Scope. This standard is intended to be used by the owner and operator of a dry storage-type independent spent fuel storage installation (ISFSI) in specifying the design requirements and by the designer to meet the minimum requirements of such installations.

The standard includes requirements for the following: the design of major buildings and structures, shipping cask unloading and handling facilities, cask decontamination, loading and unloading areas, spent fuel storage areas and racks, fuel handling equipment, radiation shielding, special equipment and area layout configurations, air or gas quality, storage area integrity, air or gas cleanup, fuel inspection, ventilation, residual heat removal, radiation monitoring, prevention of criticality, radwaste control and monitoring systems, provisions to facilitate decommissioning, quality assurance, materials accountability, and physical security.

This standard continues the set of American National Standards on spent fuel storage. Similar standards are:

(1) Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants, ANSI/ANS-57.2-1983 [1]¹;

(2) Design Criteria for an Independent Spent Fuel Storage Installation (Water Pool Type), ANSI/ANS-57.7-1988 [2];

(3) Guidelines for Establishing Site-Related Parameters for Site Selection and Design of an Independent Spent Fuel Storage Installation (Water Pool Type), ANSI/ANS-2.19-1988(R1990) [3]; and

(4) Design Criteria for Consolidation of LWR Spent Fuel, ANSI/ANS-57.10-1987 [4].

1.2 Limits of Application. This standard applies to the design of an ISFSI that has the following limitations:

(1) Dry storage only.

(2) The spent fuel to be stored

(a) is only commercial LWR UO₂ fuel.

(b) has aged a minimum of 1 yr after discharge from the reactor core.

(c) can arrive at the installation in three forms: undamaged whole fuel assemblies, canned damaged whole fuel assemblies, and close-packed consolidated fuel rods.

(3) Fuel will be received from off-site locations in a U.S. Nuclear Regulatory Commission (NRC) certificated transportation package that is physically compatible with the systems of the installation.

1.3 Operating Functions. The operating functions are:

(1) Transportation package receiving and handling.

(2) Transportation package unloading.

(3) Decontamination, minor maintenance, and temporary storage of the transportation package.

(4) Fuel unit lag storage.

(5) Fuel unit preparation (which could include canisterization or rod consolidation) for storage and transfer to and from lag storage.

¹Numbers in brackets refer to corresponding numbers in Section 7, References.