

# American Nuclear Society

**WITHDRAWN**


September 21, 2009

**ANSI/ANS**

**radioactive source term for normal  
operation of light water reactors**

**an American National Standard**

**No longer being maintained as an  
American National Standard. This  
standard may contain outdated  
material or may have been  
superseded by another standard.  
Please contact the ANS Standards  
Administrator for details.**



**published by the  
American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60526 USA**

This is a preview of "ANSI/ANS-18.1-1999". [Click here to purchase the full version from the ANSI store.](#)

**ANSI/ANS-18.1-1999 (W2009)  
(Errata - Replacement Tables Version)**

**American National Standard  
Radioactive Source Term for Normal  
Operation of Light Water Reactors**

**Secretariat  
American Nuclear Society**

**Prepared by the  
American Nuclear Society  
Standards Committee  
Working Group ANS-18.1**

**Published by the  
American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60526 USA**

**Approved September 21, 1999  
by the  
American National Standards Institute, Inc.**

## **American National Standard**

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60526 USA**

Copyright © 1999 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-18.1-1999 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

**Foreword** (This Foreword is not a part of American National Standard Radioactive Source Term for Normal Operation of Light Water Reactors, ANSI/ANS-18.1-1999.)

The purpose of this standard is to provide a set of typical radionuclide concentrations for estimating the radioactivity in the principal fluid streams of a light water reactor. Some systems will have different concentrations than those indicated in this standard. The values in this report were those judged to be representative concentrations in a light water reactor over its lifetime based upon the data currently available. It is not intended that these data be used as the sole basis for design, but be used in environmental reports and elsewhere where expected operating conditions over the life of the plant would be appropriate. The data and methodology provided by previous versions of this standard have been incorporated in the GALE computer codes (see Bibliography) used for the calculation of gaseous and liquid effluents from light water reactors. The changes included in this standard should be considered in future updates of these codes.

This standard is Revision 2 of American National Standard for Source Term Specification, N237-1976 (ANS-18.1), and updates the default activity concentrations and adjustment factors associated with Revision 1 (ANSI/ANS-18.1-1984), based on the latest review of data from operating domestic nuclear power plants. The values given in this standard will be revised periodically as additional plant operating data become available.

At the time of approval, members of Working Group ANS-18.1 who developed this standard were:

J. Sejvar, Chairman, *Westinghouse Electric Company*  
M. A. Glissman-Paul, Secretary, *Individual*  
J. Y. Lee, *U.S. Nuclear Regulatory Commission*  
C. Lin, *General Electric Company*  
M. Rutherford, *Framatome Technologies*

The working group also extends special thanks for the contributions from J. D. Cohen, of Westinghouse Savannah River Company, who served as Chair of Subcommittee ANS-5.

The American Nuclear Society's Nuclear Facilities Standards Committee (NFSC) had the following membership at the time of its approval of the standard:

**J. C. Saldarini, Chair**  
**D. J. Spellman, Vice-Chair**  
**S. M. Coyne-Nalbach, Secretary**

R. H. Bryan, Jr. . . . . Tennessee Valley Authority  
T. W. T. Burnett . . . . . Westinghouse Electric Corporation  
H. Chandler . . . . . U.S. Department of Energy  
J. D. Cohen . . . . . Westinghouse Savannah River Company  
W. H. D'Ardenne . . . . . DAE Enterprises  
L. A. Ettlinger . . . . . The Oxford Group  
P. H. Hepner . . . . . ABB/Combustion Engineering, Inc.  
R. A. Hill . . . . . GE Nuclear Energy  
N. P. Kadambi . . . . . U.S. Nuclear Regulatory Commission  
J. E. Love . . . . . Bechtel Power Corporation  
J. T. Luke . . . . . ComEd  
J. F. Mallay . . . . . Siemens Power Corporation  
C. H. Moseley, Jr. . . . . Lockheed Martin Energy Systems  
S. A. Nass . . . . . Duquesne Light Company  
J. A. Nevshemal . . . . . Individual  
W. N. Prillaman . . . . . Framatome Technologies, Inc.  
W. C. Ramsey, Jr. . . . . Southern Nuclear  
W. B. Reuland . . . . . Individual  
M. Ruby . . . . . Rochester Gas & Electric Corporation  
J. C. Saldarini . . . . . Raytheon Nuclear  
(for the American Nuclear Society)  
J. B. Savy . . . . . Lawrence Livermore National Laboratory  
R. E. Scott . . . . . Scott Enterprises  
D. J. Spellman . . . . . Oak Ridge National Laboratory  
S. L. Stamm . . . . . Stone & Webster Engineering Corporation  
J. D. Stevenson . . . . . J. D. Stevenson Consultants  
C. D. Thomas, Jr. . . . . Yankee Atomic Electric Company  
G. P. Wagner . . . . . Individual  
M. J. Wright . . . . . Entergy Operations

<b>Contents</b>	<b>Section</b>	<b>Page</b>
	1. Scope .....	1
	2. Purpose .....	1
	3. Specifications .....	1
	3.1 Specification of Radionuclide Concentration for Reference Plants .....	1
	3.2 Adjustment of the Reference Plant Radionuclide Concentrations to a Specific Plant .....	1
 Appendix		
	Bibliography .....	18
 Tables		
Table 1	Parameters Used to Describe the Reference Boiling Water Reactor .....	2
Table 2	Parameters Used to Describe the Reference Pressurized Water Reactor with U-Tube Steam Generators .....	3
Table 3	Parameters Used to Describe the Reference Pressurized Water Reactor with Once-Through Steam Generators .....	4
Table 4	Description of the Element Classification Used in This Standard .....	4
Table 5	Numerical Values - Concentrations in Principal Fluid Streams of the Reference BWR .....	5
Table 6	Numerical Values - Concentrations in Principal Fluid Streams of the Reference PWR with U-Tube Steam Generators .....	6
Table 7	Numerical Values - Concentrations in Principal Fluid Streams of the Reference PWR with Once-Through Steam Generators .....	7
Table 8	Values Used in Determining Adjustment Factors for BWRs .....	8
Table 9	Values Used in Determining Adjustment Factors for PWRs .....	9
Table 10	Adjustment Factors for BWRs .....	11
Table 11	Adjustment Factors for PWRs with U-Tube Steam Generators ..	12
Table 12	Adjustment Factors for PWRs with Once-Through Steam Generators .....	14
 Figures		
Figure 1	Removal Paths for the Reference BWR .....	15
Figure 2	Removal Paths for the Reference PWR with U-Tube Steam Generators .....	16
Figure 3	Removal Paths for the Reference PWR with Once-Through Steam Generators .....	17

This is a preview of "ANSI/ANS-18.1-1999". [Click here to purchase the full version from the ANSI store.](#)



# Radioactive Source Term for Normal Operation of Light Water Reactors

## 1. Scope

This standard establishes typical long-term concentrations of principal radionuclides in fluid streams of light-water-cooled nuclear power plants for use in estimating the expected release of radioactivity from various effluent streams. These fluid streams are: the coolant of a boiling water reactor (BWR), the coolant of a pressurized water reactor (PWR), and PWR steam generator fluids. The concentrations in fluid streams of BWRs and PWRs are treated in a similar manner, but have different numerical values because of the differences in design.

The numerical values given in this standard are based on available data from operating plants which use zirconium-clad uranium dioxide fuel. The values are given for a set of reference conditions, and criteria are provided for adjusting to other conditions.

## 2. Purpose

The purpose of this standard is to provide a uniform approach, applicable to light-water-cooled nuclear power plants, for the determination of expected concentrations in fluid streams. Through application of this standard, a common basis for the determination of radioactive source terms for normal operating conditions is established, with the goal of providing a consistent approach for those involved in the design of these facilities. Utilization of this standard is expected to aid the licensing process and the public's understanding of the impact of nuclear power relative to radionuclide concentrations and possible releases to the environment.

## 3. Specifications

Parameters that characterize the three types of Nuclear Steam Supply Systems (NSSS) are given in Table 1 (BWR), Table 2 (PWR with U-tube steam generators), and Table 3 (PWR with once-through steam generators). The reference plant values are based on typical systems which are sufficiently general to be applicable to most light-water reactors. The choice of these parameters is not meant to imply a recommendation of

their use in selecting a plant design. Figures 1, 2, and 3 present block diagrams of the reference reactor systems and provide the bases for the removal rate equations and adjustment factors. The various radioactive elements that might be present in fluid streams have been divided into six classes, as shown in Table 4. This division was made to facilitate the adjustment procedure. Except for Class 6, these classes are based on the grouping of elements with reasonably similar chemical and physical properties, or similar behavior during normal operation. Class 6 includes all other elements that could not be classified readily in any of the other classes. The following sections describe how this standard is applied to plants that have the parametric values given in Tables 1, 2, and 3, and how to determine radionuclide concentrations if one or more parameters differ from the reference values.

**3.1 Specification of Radionuclide Concentrations for Reference Plants.** If the parameters of a plant are the same as those given in Tables 1, 2, or 3, the recommended radionuclide concentrations are given in Tables 5, 6, and 7. Table 5 gives the radionuclide concentrations for reactor coolant for the reference BWR. Table 6 gives the radionuclide concentrations for reactor coolant and steam generator fluid for the reference PWR with U-tube steam generators. Table 7 gives the radionuclide concentrations for reactor coolant and secondary steam for the reference PWR with once-through steam generators. These radionuclide concentrations are based on data obtained from operating nuclear plants.

**3.2 Adjustment of the Reference Plant Radionuclide Concentrations to a Specific Plant.** If any parameter, such as power level, flow rate, or fluid quantity, differs from the values given in Tables 1, 2, or 3 (as appropriate), the procedures described in the following paragraphs shall be used to determine the adjustment factors needed to modify the radionuclide concentrations in Tables 5, 6, and 7. Recalculated fluid stream concentrations shall be based on the numerical values provided in Tables 5, 6, and 7, which are given to only one or two significant figures. It is inappropriate to assign a greater accuracy to any fluid stream concentration calculated through