

American Nuclear Society


**determination of steady-state
neutron reaction-rate distributions
and reactivity of nuclear power reactors**

an American National Standard

WITHDRAWN

**August 26, 2011
ANSI/ANS-19.3-2005**

**No longer being maintained as an
American National Standard. This
standard may contain outdated material or
may have been superseded by another
standard. Please contact the ANS
Standards Administrator for details.**



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA

ANSI/ANS-19.3-2005

**American National Standard
Determination of Steady-State
Neutron Reaction-Rate Distributions
and Reactivity of Nuclear Power Reactors**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-19.3**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved September 16, 2005
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA

Copyright © 2005 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-19.3-2005 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword (This Foreword is not a part of American National Standard for the Determination of Steady-State Neutron Reaction-Rate Distributions and Reactivity of Nuclear Power Reactors, ANSI/ANS-19.3-2005.)

It is the intent of this American National Standard to provide guidance for performing and validating the sequence of calculations leading to prediction of steady-state neutron reaction-rate spatial distributions and reactivity of nuclear reactors, and to provide guidelines by which the adequacy of design calculations may be demonstrated. This standard recognizes the diversity of the calculational procedures employed in reactor design. Consequently, the major thrusts of this standard are in the areas of verification, validation, and documentation. This standard is intended to cover reactor-physics calculations for the entire nuclear industry, from fast to thermal power reactors. Since many different kinds of calculations are performed, each having its own requirements for accuracy and validation, it is necessary that this standard be of a general nature. It should be noted that this standard does not endorse or exclude the application of any methodology that has been adequately verified, validated, tested, and demonstrated to yield, within acceptable errors, the desired reactor-physics parameters.

For illustrative purposes, a list of computer codes currently being used throughout the nuclear industry is presented in the Appendix. This Appendix, however, is not part of the Standard.

Compliance with the intent of this standard can be demonstrated for an intended area of applicability of the calculational system used by meeting the following requirements:

- (1) Selection of models and methods.
 - (a) Consideration of all conditions of reactor composition, temperature, and configuration that significantly affect the calculated quantities and justification of the resulting model approximations,
 - (b) Preparation of multigroup constants, if employed, in conformance with American National Standard "Nuclear Data Sets for Reactor Design Calculations," ANSI/ANS-19.1-2002, through the use of an application-dependent energy-spectrum calculation,
 - (c) Justification of geometric and neutronic transport approximations utilized in the spectrum calculation,
 - (d) Inclusion of all important space and energy effects in the calculation utilized for the generation of few-group cross sections, if few-group cross sections are employed,
 - (e) Demonstration of capability, as required by the application, to retrieve required neutron reaction rates in the physical reactor components from the computations and to justify any assumptions that need to be made in order to perform this retrieval,
 - (f) Justification of the spectrum calculation interval used in depletion calculations and justification that the numerical integration time step is sufficiently small to ensure numerical stability and accuracy appropriate to the application;
- (2) Calculational system validation. Establishment of the degree of agreement over a limited area of applicability by correlating experimental results or results of calculations from a more accurate model with results obtained from the system being validated;

- (3) Evaluation of accuracy. Evaluation of accuracy and range of applicability of data and methods by establishment of biases and uncertainties, with confidence levels, for the calculations that include allowance for uncertainties in the comparison data;
- (4) Documentation. Documentation of details of the preceding procedures.

It is the intent of this standard to require the individual to (a) give careful consideration to those physical and numerical effects that may contribute to the validity of results; (b) document the reasons for the choice of calculational path; and (c) validate the calculational system used over the intended range of applicability by testing it against appropriate experiments, numerical benchmarks, or previously validated methods.

The requirement for documentation is a crucial part of this standard and will provide an auditable path. Areas omitted due to proprietary consideration shall be noted where possible.

The most important ways in which this revision differs from its earlier version, ANSI/ANS-19.3-1995, are as follows:

- (1) The passages on common practices for pressurized water reactors, boiling water reactors, and liquid metal reactors have been revised to reflect the significant advances in reactor-physics methods and computer codes made since the last revision. New passages have been added for heavy water reactor and high-temperature gas-cooled reactor methods;
- (2) The Appendix, including the list of commonly used computer codes, has been updated. This revision reflects rapid development in two areas, namely,
 - (a) significant advances in reactor-physics methods and calculational procedures as a result of a rapidly increasing experience base of operating power reactors,
 - (b) computer hardware and operating software developments that have permitted many traditional approximate methods to be placed, with increased performance and user productivity as a result.

This standard for reactor-physics calculations will undergo review and revision within 5 years. Suggestions for the improvement of this standard will be welcome. They should be sent to the attention of the Standards Department, American Nuclear Society, 555 N. Kensington Avenue, La Grange Park, IL 60526. Questions arising from the use of this standard or requests for clarification of portions of the standard should be sent in writing to the above address.

This standard was developed and later revised by Working Group ANS-19.3 of the American Nuclear Society, which at the time of this revision had the participation of the following members:

B. Rouben, *Atomic Energy of Canada Limited*
R.-T. Chiang, *General Electric*
D. M. Cokinos, *Brookhaven National Laboratory*
P. Finck, *Argonne National Laboratory*
G. Hobson, *Framatome Technologies*
B. R. Moore, *General Electric*
R. D. Mosteller, *Los Alamos National Laboratory*
C. T. Rombough, *CTR Technical Services*
Y. Shatilla, *Westinghouse Electric Company*
S. B. Thomas, *Duke Power*

The membership of Subcommittee ANS-19 at the time of its review and approval of this standard was the following:

D. M. Cokinos, Chair, *Brookhaven National Laboratory*
C. T. Rombough, Secretary, *CTR Technical Services*

S. Baker, *Transware Enterprises*
M.C. Brady Raap, *Pacific Northwest National Laboratory*
R. J. Cacciapouti, *Framatome ANP*
Y. A. Chao, *Westinghouse*
W. S. Charlton, *Texas A&M University*
R.-T. Chiang, *GE Nuclear Energy*
D. J. Diamond, *Brookhaven National Laboratory*
J. Katakura, *Japan Atomic Energy Research Institute*
R. Little, *Los Alamos National Laboratory*
L. Lois, *U.S. Nuclear Regulatory Commission*
R. D. McKnight, *Argonne National Laboratory*
R. D. Mosteller, *Los Alamos National Laboratory*
R. T. Perry, *Los Alamos National Laboratory*
B. Rouben, *Atomic Energy of Canada Limited*
A. Weitzberg, *Retired*

Consensus Committee N17, Research Reactors, Reactor Physics, Radiation Shielding, and Computational Methods, had the following membership at the time it reviewed and approved this standard:

T. M. Raby (Chair), *National Institute of Standards and Technology*
A. Weitzberg (Vice Chair), *Individual*

W. H. Bell, *American Institute of Chemical Engineers*
(Alt. R. D. Zimmerman, *American Institute of Chemical Engineers*)
R. E. Carter, *Individual*
D. Cokinos, *Brookhaven National Laboratory*
B. Dodd, *Health Physics Society*
W. A. Holt, *American Public Health Association*
W. C. Hopkins, *Individual*
L. I. Kopp, *Individual*
P. M. Madden, *U.S. Nuclear Regulatory Commission*
(Alt. A. Adams, *U.S. Nuclear Regulatory Commission*)
J. F. Miller, *Institute of Electrical and Electronics Engineers*
J. E. Olhoeft, *Individual*
W. J. Richards, *National Institute of Standards and Technology*
R. Seale, *University of Arizona*
T. R. Schmidt, *Sandia National Laboratories*
A. O. Smetana, *Savannah River National Laboratory*
E. G. Tourigny, *U.S. Department of Energy*
S. H. Weiss, *National Institute of Standards and Technology*
(Alt. T. J. Myers, *National Institute of Standards and Technology*)
W. L. Whittemore, *General Atomics*

This is a preview of "ANSI/ANS-19.3-2005". [Click here to purchase the full version from the ANSI store.](#)

Contents	Section	Page
	1 Introduction	1
	2 Scope	1
	3 Definitions	1
	3.1 Limitations	1
	3.2 Glossary of Terms	1
	3.3 Acronyms	3
	4 Relation to Other Standards	3
	5 Methods of Calculation	3
	5.1 General	3
	5.2 Conditions to be Considered	4
	5.3 Multigroup Cross Sections	4
	5.4 System-Dependent Spectrum Calculations	5
	5.5 Collapse to Few Groups	6
	5.6 Calculation of Reactivity and Neutron Flux Distributions	6
	5.7 Calculation of Reaction Rates in Reactor Components	7
	5.8 Depletion Calculations	7
	5.9 Common Practices	8
	6 Verification and Validation of the Computational System	14
	6.1 Overview	14
	6.2 Verification	14
	6.3 Validation	15
	6.4 Biases and Uncertainties	16
	7 Documentation	16
	8 Summary of Requirements	17
	9 References	17
	Figures	
	Figure 1 General Flow of Data for PWR Physics Calculations	9
	Figure 2 General Flow of Data for BWR Physics Calculations	9
	Figure 3 General Flow of Data for LMR Physics Calculations	11
	Figure 4 General Flow of Data for HWR (CANDU) Physics Calculations	12
	Figure 5 General Flow of Data for HTGR Physics Calculations	13
	Appendix	
	Computer Codes in Common Use	19
	Table	
	Table 1 Computer Codes in Common Use	20

This is a preview of "ANSI/ANS-19.3-2005". [Click here to purchase the full version from the ANSI store.](#)

Determination of Steady-State Neutron Reaction-Rate Distributions and Reactivity of Nuclear Power Reactors

1 Introduction

The design and operation of nuclear reactors require knowledge of the conditions under which a reactor will be critical, as well as the degree of subcriticality or supercriticality when these conditions change. In addition, knowledge is required of the spatial distribution of neutron reaction rates in reactor components as a prerequisite, for example, for inferring temperature distributions and thus the satisfaction of thermal limit requirements. Both reaction-rate spatial distributions and reactivity can be and have been measured by suitable experimental techniques, either in mock-ups or in the operating reactors themselves. These quantities can also be calculated by various techniques. As nuclear cross sections have become more accurate and as calculational methods have been refined, the tendency has been to rely more heavily on calculations. Available reactor experimental data have been used to validate the calculations within reasonable margins.

2 Scope

This standard provides guidance for performing and validating the sequence of steady-state calculations leading to prediction, in all types of commercial nuclear reactors, of

- (1) reaction-rate spatial distributions;
- (2) reactivity;
- (3) change of isotopic compositions with time.

The standard provides

- (1) guidance for the selection of computational methods;

- (2) criteria for verification and validation of calculational methods used by reactor core analysts;

- (3) criteria for evaluation of accuracy and range of applicability of data and methods;

- (4) requirements for documentation of the preceding.

3 Definitions

3.1 Limitations

The following definitions are of a restricted nature for the purpose of this standard. Other specialized terms are defined in *Glossary of Terms in Nuclear Science and Technology* [1]¹⁾ and in the definition sections of standards specified in Section 9, "References."

3.2 Glossary of terms

application-dependent multigroup: A discrete energy-group structure that is intermediate between the application-independent-multigroup structure and a few-group structure. The application-dependent-multigroup structure may be such that the group constants are dependent on reactor composition through an estimated neutron energy spectrum. An application-dependent-multigroup data set is one type of averaged data set.

application-independent multigroup: A discrete energy-group structure that is sufficiently detailed that the group constants may be considered as being independent of reactor composition, geometry, or spectrum for a wide range of reactor analysis. The application-independent-multigroup structure may be employed directly in reactor-design spec-

¹⁾Numbers in brackets refer to corresponding numbers in Section 9, "References."