


American Nuclear Society

**evaluation of subsurface
radionuclide transport at commercial
nuclear power plants**

an American National Standard



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA

ANSI/ANS-2.17-2010

**American National Standard
Evaluation of Subsurface
Radionuclide Transport at Commercial
Nuclear Power Plants**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-2.17**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved December 23, 2010
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Copyright © 2010 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-2.17-2010 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword (This Foreword is not a part of American National Standard "Evaluation of Subsurface Radionuclide Transport at Commercial Nuclear Power Plants," ANSI/ANS-2.17-2010.)

This standard constitutes a major revision of the original standard, ANSI/ANS-2.17-1980, which was adopted on April 9, 1980, reaffirmed on October 3, 1989, and withdrawn on July 28, 2000. A new working group, Working Group ANS-2.17 of ANS-25 Subcommittee (Siting: Environmental & Emergency Preparedness) of the American Nuclear Standards Committee, was constituted November 2005 to revise the original standard.

This standard might reference documents and other standards that have been superseded or withdrawn at the time the standard is applied. A statement has been included in the references section that provides guidance on the use of references.

This standard mentions, but does not exhaustively describe, the concepts of generating risk-informed insights, performance-based requirements, and a graded approach to quality assurance. The user is advised that one or more of these techniques could enhance the application of this standard.

Two appendices are provided to assist practitioners who would implement the guidance in this standard. Appendix A provides information on relevant U.S. Nuclear Regulatory Commission regulatory criteria and guidance, and its Table A provides a listing of standard documents (e.g., ANS, ASTM, ISO, etc.) for conducting subsurface radionuclide transport characterization, monitoring, and modeling programs. Appendix B provides tables that summarize information and parameters identified in the guidance.

The ANS-2.17 Working Group of the Standards Committee of the American Nuclear Society had the following membership:

J. S. Bollinger (Co-chair), *Savannah River National Laboratory*
T. C. Rasmussen (Co-chair), *University of Georgia*

M. J. Barvenik, *GZA GeoEnvironmental, Inc.*
R. L. Beauheim, *Sandia National Laboratories*
G. S. Bodvarsson, *Lawrence Berkeley National Laboratory*¹⁾
J. M. Godfrey, *Southern Nuclear Company, Alabama Power Company*
D. Goswami, *Washington State Department of Ecology*
V. Guvanasen, *HydroGeoLogic, Inc.*
C. D. Martinec, *Duke Energy*
P. D. Meyer, *Pacific Northwest National Laboratory*
F. J. Molz III, *Clemson University*
T. J. Nicholson, *U.S. Nuclear Regulatory Commission*
D. Scott, *Radiation Safety and Control Services, Inc.*
E. P. Weeks, *U.S. Geological Survey*
D. G. Wells, *Washington Savannah River Company*
M. H. Young, *Desert Research Institute*

This standard was prepared under the guidance of Subcommittee ANS-25, Siting: Environmental & Emergency Preparedness, of the American Nuclear Society. At the time of the ballot, Subcommittee ANS-25 was composed of the following members:

K. R. Bryson (Chair), *Shaw Environmental, Inc.*
C. A. Mazzola (Vice Chair), *Shaw Environmental & Infrastructure, Inc.*

J. S. Bollinger, *Savannah River National Laboratory*
C. Costantino, *Individual*

¹⁾ The working group would like to gratefully acknowledge the contributions by G. S. "Bo" Bodvarsson, who died prior to the completion of this standard.

A. N. Findikakis, *Bechtel Corporation*
C. Guggino, *Bechtel Corporation*
D. Hang, *Individual*
K. Hanson, *AMEC Geomatrix*
J. J. Litehiser, *Bechtel Corporation*
T. C. Rasmussen, *University of Georgia*
J. D. Stevenson, *Individual*
L. W. Vail, *Pacific Northwest National Laboratory*
S. A. Vigeant, *Shaw Environmental & Infrastructure*

The standard was processed and approved for submittal to ANSI by the Nuclear Facilities Standards Committee (NFSC) of the American Nuclear Society. At the time it approved this standard, the NFSC had the following membership:

C. A. Mazzola (Chair), *Shaw Environmental & Infrastructure, Inc.*
R. M. Ruby (Vice Chair), *Constellation Energy*

J. K. August, *CORE, Inc.*
W. H. Bell, *South Carolina Electric & Gas Company*
J. R. Brault, *Shaw MOX Project*
C. K. Brown, *Southern Nuclear Operating Company*
R. H. Bryan, *Tennessee Valley Authority*
K. R. Bryson, *Shaw Environmental, Inc.*
C. E. Carpenter, *U.S. Nuclear Regulatory Commission*
D. R. Eggett, *Automated Engineering Services Corporation*
R. W. Englehart, *Individual*
P. Guha, *U.S. Department of Energy*
R. Hall, *Exelon Generation Company, LLC*
P. S. Hastings, *Duke Energy*
R. A. Hill, *ERIN Engineering and Research, Inc.*
N. P. Kadambi, *Individual*
E. M. Lloyd, *Exitech Corporation*
S. A. Lott, *Los Alamos National Laboratory*
J. E. Love, *Bechtel Corporation*
R. H. McFetridge, *Westinghouse Electric Corporation*
C. H. Moseley, *ASME/NQA Liaison (BWXT Y-12)*
D. G. Newton, *AREVA NP*
W. N. Prillaman, *AREVA NP*
W. B. Reuland, *Individual*
D. J. Spellman, *Oak Ridge National Laboratory*
S. L. Stamm, *Shaw Nuclear Services*
J. D. Stevenson, *Individual*
J. A. Wehrenberg, *Southern Nuclear Operating Company*
M. J. Wright, *Entergy Operations, Inc.*

Contents	Section	Page
	1 Scope	1
	2 Definitions	1
	2.1 Acronyms and initialisms	1
	2.2 Definition of terms	1
	3 Performance assessment methodology	5
	3.1 Performance assessment activities	5
	3.2 Performance assessment elements	6
	4 Site characterization	8
	4.1 Conceptual site model	8
	4.2 Facilities characterization	9
	4.3 Hydrogeologic characterization	10
	5 Mathematical modeling	13
	5.1 Model scope	13
	5.2 Calibration, prediction, and updating	16
	5.3 Uncertainty assessment	17
	6 Performance-confirmation monitoring	17
	6.1 Types of monitoring data	17
	6.2 Monitoring methods	18
	6.3 Monitoring locations and frequencies	18
	7 Information management	20
	7.1 Characterization and monitoring data management	20
	7.2 Mathematical model management	21
	8 References	21
Appendices		
	Appendix A Consultation and Coordination	25
	Appendix B Summary of Information and Parameters	31
Table		
	Table 1 Ranked list of radionuclides at commercial nuclear power plants (typical pressurized water reactor) based on their relative abundance, activity, and transport characteristics	7
Figure		
	Figure 1 Flowchart describing performance assessment activities and the relationships among these activities	6

This is a preview of "ANSI/ANS-2.17-2010". [Click here to purchase the full version from the ANSI store.](#)

Evaluation of Subsurface Radionuclide Transport at Commercial Nuclear Power Plants

1 Scope

This national standard establishes the requirements for evaluating the occurrence and movement of radionuclides in the subsurface resulting from abnormal radionuclide releases at commercial nuclear power plants.

This standard applies to abnormal radionuclide releases that affect groundwater, water supplies derived from groundwater, and surface waters affected by subsurface transport, including exposure pathways across the groundwater-surface-water transition zone.

This standard does not apply to the following:

- subsurface occurrence and movement of non-radioactive materials, other than as indicators of subsurface radionuclide occurrence and movement in soil and groundwater;
- surface occurrence and movement of radionuclides, except to the extent that surface radionuclide occurrence and movement might affect, or be affected by, on-site subsurface radionuclide occurrence and movement (e.g., a surface release that subsequently infiltrates and affects groundwater, a subsurface release that affects surface water, including exposure pathways across the groundwater-surface-water transition zone);
- corrective action, which might be required as the result of a subsurface radionuclide release;
- dose calculations to demonstrate compliance with any regulatory requirement.

2 Definitions

2.1 Acronyms and initialisms

ALARA: as low as is reasonably achievable

ANS: American Nuclear Society

ANSI: American National Standards Institute

ASTM: ASTM International, previously known as the American Society for Testing and Materials

CFR: *Code of Federal Regulations*

CRWMS: civilian radioactive waste management system management and operating contractor

CSM: conceptual site model

DQO(s): data quality objective(s)

EIS: Environmental Impact Statement

EPRI: Electric Power Research Institute

FEP(s): feature(s), event(s), and process(es)

IAEA: International Atomic Energy Agency

NEI: Nuclear Energy Institute

NGWA: National Ground Water Association

NRC: National Research Council

REMP: Radiological Environmental Monitoring Program

RETS: Radioactive Effluent Technical Specifications

TEDE: total effective dose equivalent

USEPA: U.S. Environmental Protection Agency

USNRC: U.S. Nuclear Regulatory Commission

2.2 Definition of terms

abnormal radionuclide release: The unplanned or uncontrolled emission of an effluent (i.e., containing plant-related, licensed radioactive material).

as low as is reasonably achievable (ALARA): Every reasonable effort is made to maintain exposures to radiation as far below the dose limits as is practical consistent with the purpose for which the licensed activity is undertaken, taking into account the state of technology, the economics of improvements in relation to state of technology, the economics of improvements in relation to benefits to the public health and