



# Standard Specification for FRP Composite Utility Poles

FIRST EDITION



Published by American Composites Manufacturers Association



This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)

## **Notice and Disclaimer of Liability Concerning the Use of this Standard**

This document “Standard Specification for FRP Composite Utility Poles” was developed through a consensus standards development process approved by the American National Standards Institute, as described on the following page. This process brings together volunteers representing a variety of companies, issues and interests to achieve consensus.

Please note that nothing herein should be viewed as a recommendation by the American Composites Manufacturers Association (ACMA) that any application, technique or process is appropriate in any particular circumstances. Similarly, the fact that a particular application, technique or process is listed in this document should not be viewed as an endorsement by ACMA of such application, technique or process.

ACMA makes no claims concerning the accuracy or applicability of the information contained in the this standard and ACMA is not responsible for the results obtained from the use of such information. Determination of the suitability of the information included is the sole responsibility of the user.

This standard is sold without warranties, express or implied, including but not limited to any implied warranty of merchantability or fitness for a particular purpose. ACMA expressly disclaims all such warranties.

ACMA is not responsible for any damage or loss caused or alleged to be caused by the information contained herein. Accordingly, ACMA shall not be liable for any direct, indirect, incidental, special or consequential damages, resulting from the use of this standard. Additionally, ACMA has no power or ability to enforce, review or make any determination on the compliance with this standard.

Copyright © 2019 by American Composites Manufacturers Association (ACMA)  
All rights reserved. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission of the publisher.

This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)

# American National Standard

---

## Standard Specification for FRP Composite Utility Poles

Larry B. Cox  
Secretariat  
**American Composites Manufacturers Association**

Approved: September 13, 2018

### **American National Standards Institute, Inc.**

Approval of an American National Standard requires review by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made towards their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will under no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right nor authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

**CAUTION NOTICE:** This American National standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

American National Standards Institute, Inc., 25 West 43<sup>rd</sup> Street, New York, NY 10036

This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)

# Standard Specification for FRP Composite Utility Poles

FIRST EDITION

Prepared by  
American Composites Manufacturers Association  
Utility & Communication Structures Council

© 2019 American Composites Manufacturers Association  
2000 N 15<sup>th</sup> Street, Suite 250  
Arlington, VA 22201  
Phone: 703-525-0511  
Fax: 703-525-0743  
www.acmanet.org

All rights reserved.

No part of this book may be reproduced or resold, in any form or by  
any means, without permission from the publisher.

Printed in the United States

This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)



## ACKNOWLEDGEMENTS

The American Composites Manufacturers Association's (ACMA) Utility and Communication Structures Council (UCSC) is a committee of the Composites Growth Initiative program with the mission of improving the power delivery and communications infrastructure by promoting the use and understanding of FRP composite poles and crossarms for electrical distribution, transmission and communication structure applications. The UCSC accomplishes this through the coordination, development, and promotion of composite technologies, materials and products used by the electrical utility market, in addition to the development of codes and standards. This standard specification supports the mission and goals of the Council.

The UCSC thanks the ACMA Composites Growth Initiative and the following distinguished member companies for their support and contribution in the development of this standard.

Andercol S.A.	Lucintel, Inc.
AOC Aliancys	Nippon Electric Glass Co., Ltd.
Ashland, LLC	Owens Corning
Bedford Reinforced Plastics, Inc.	Polynt-Reichhold
Chromaflo Technologies Corp.	RS Technologies Inc.
Composites One, LLC	Strongwell
Creative Pultrusions, Inc.	Trident Industries
GEOTEK, LLC	University of Massachusetts - Lowell
Highland Composites	University of Miami
Jensen Enterprises, Inc.	Valmont Composites Structures

The UCSC acknowledges the valuable work, dedication, and contribution of the following individuals who have provided content and direction for this standard.

Scott Holmes, Highland Composites, UCSC Chair

Dustin Troutman, Creative Pultrusions, Inc., UCSC Vice-Chair

Jim Davidson, PhD, Consultant

Galen Fecht, RS Technologies Inc.

Jim Bob Wiles, Valmont Composite Structures

John P. Busel, F.ACI, ACMA

This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)

## PREFACE

Over the past 25 years, a significant amount of progress has been made toward the integration of Fiber Reinforced Polymer (FRP) composite pole and crossarm products into the electric distribution and transmission infrastructure in North America. FRP composite materials have been demonstrated to have many benefits and advantages such as: lightweight, corrosion resistant, highly reliable, capable of excellent dielectric strength, and long service life. However, despite the advantages and progress toward FRP composite pole adoption in many areas, composites are still not well understood within many standards organizations, utilities and other end-user applications. Another barrier to widespread acceptance of composite poles is the lack of guidance in the form of a national standard, similar to what is used for wood poles and crossarms. Consultation with electric utilities, as well as national electric utility organizations, such as Electric Power Research Institute, Edison Electric Institute, National Utility Regulators Association, Rural Utility Service and American Public Power Association, led to the following conclusion. The lack of a national standard for FRP utility poles is a barrier to further use or implementation. Therefore, a *Standard Specification for FRP Composite Utility Poles* provides information and guidance to end-users at investor-owned, municipal and rural electric utilities, allowing them to readily adopt composite products in response to the use of this specification document.

This standard specification is consistent with the UCSC mission to improve power delivery and communication infrastructure by promoting the use and understanding of composite utility poles and crossarms for electrical distribution, transmission and communication structure applications. This specification focuses on the cradle to grave life cycle of the FRP utility pole; including the design, material properties, manufacturing processes, quality control, assembly, and installation, and inspection parameters of direct embedded FRP utility poles. The objective of the standard is to provide a uniform and consistent reference document for all FRP utility poles, enabling more widespread applications.

End-users will better understand all the facets specific to FRP utility poles to ease the process of approval and implementation within the electric infrastructure. The standard will educate users on the design, materials and processing aspects of FRP utility poles so they can select the best product solution for their application. This standard will help them understand the differences relative to wood, concrete and steel when considering the application and use, as well as the important aspects of attachments and pole installation specific to FRP materials. As a result of studying and applying this standard, the end-user

will be more confident and knowledgeable in the final design decision for FRP utility poles, which will lead to more consistent and proper specification of FRP utility poles. With this new understanding, utilities and end-users will be able to specify composites in applications of benefit, when composites are compared to alternative grid infrastructure materials. A brief summary of FRP utility poles benefits is provided here:

**Alternative to Wood for Making Challenging Installations Safer** – Although wood is the current predominant choice, composites present an alternative for applications where installation, environment or other unfavorable circumstances present challenges for wood. The inherently lightweight FRP utility poles enable faster and safer installations in limited access areas.

**Service Life** – FRP utility poles and crossarms are engineered to last 80+ years on average in the harshest of environments. They will not rot, are impervious to insects and woodpeckers and can withstand severe weather events and environments. FRP utility poles and crossarms typically require no scheduled maintenance. Periodic inspection by utilities should be completed as required, but no treatment or regular maintenance is required for FRP composite utility poles.

**Safety** – FRP utility poles are typically 33 – 50% lighter than steel or wood poles. The lightweight poles are ideal for tight urban installations where limited equipment or manual labor is necessary for project completion. The absence of treatment chemicals from the pole surface make handling, installation, and disposal of FRP utility poles safer and do not require any special handling compared to treated wood poles and cross arms. FRP composites have additional safety benefits over wood including high dielectric strength, reduced worker injury during handling and installation and reduced occupancy hazards due to vehicular pole strikes (Foedinger2002).

**Durability, Reliability, and Resilience** – Engineered FRP utility poles harden the grid by offering improved reliability and resilience in the presence of high-load situations, such as ice storms and high-wind surge events, when compared to traditional pole materials. Due to the high strain capability of FRP utility poles, an increasing amount of FRP utility pole installations have occurred in existing wood pole lines, to mitigate cascade failures and absorb expected shock. FRP utility poles also contribute to increased grid reliability by reducing pole replacement frequencies and implementing improved durability in applications where traditional pole materials are corroding, decaying and are not expected to be functional for the full calculated service length.

**Environmental Sustainability** – FRP composite utility poles benefit the environment by replacing chemically treated wood poles that leach hazardous chemicals into the soil. By using FRP utility poles, there is absolutely no leaching of chemicals into groundwater or watersheds and FRP composite materials are considered inert so they create no adverse impact to the environment where they are installed. This is especially important in environmentally sensitive areas in direct contact with water installations such as wetlands, in and around swamps, streams, coastal areas, playgrounds, and in wild and remote locations that can impact local tributaries and streams. Waste management of dimensional lumber that is treated with chromated copper arsenate (CCA) for residential application is considered hazardous waste, however old wood poles treated with CCA are exempted from management as a hazardous waste under the Resource Conservation and Recovery Act in the United States (Scientific Certification Systems 2013). FRP composite materials are inert and therefore can be disposed in conventional landfills, or can be recycled or repurposed into other products at the end of their service life. FRP composite utility poles reduce greenhouse gas (GHG) emissions and total embodied energy each year over the 60-year life of a composite pole (Wood et al. 2008). That same period will require 2 wood poles to be consumed and hazardous wastes disposed of each time with an average life of only 30 years each. FRP composite poles represent the most environmentally sustainable choice for utility structures.

**Transportation Savings** – Due to the lightweight and/or modular design and configuration of FRP utility poles, more poles can be transported per truck, typically double the quantity of traditional wood poles, thereby reducing transportation costs.

This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)

# TABLE OF CONTENTS

<b>List of Figures</b> . . . . .	xviii
<b>List of Tables</b> . . . . .	xix
<b>1. Scope</b> . . . . .	1
1.1 Scope . . . . .	1
1.2 Definitions . . . . .	1
1.3 Reference Specifications and Standards . . . . .	1
 <b>Part I – General Considerations</b>	
<b>2. Introduction</b> . . . . .	3
2.1 About Fiber Reinforced Polymer Composite Materials . . . . .	3
2.2 Characteristics of FRP Utility Poles . . . . .	3
2.3 Differences Compared to Poles from Other Materials . . . . .	4
2.4 Pole Configuration . . . . .	4
<b>3. Materials</b> . . . . .	7
3.1 Fiber Reinforcements . . . . .	7
3.2 Polymer Resins . . . . .	7
3.3 Fillers and Additives . . . . .	8
3.4 Surface Finish and UV Protection . . . . .	8
<b>4. Manufacturing</b> . . . . .	9
4.1 Overview of Composites Manufacturing Processes . . . . .	9
4.2 Pultrusion . . . . .	9
4.3 Filament Winding . . . . .	10
4.4 Secondary Processes . . . . .	10
<b>5. Quality Control</b> . . . . .	11
5.1 Manufacturers Quality Control Plan . . . . .	11
5.2 Purchasing Process . . . . .	11
5.3 In-process Inspection and Reporting . . . . .	11
5.4 Product Manufacturing Tolerances . . . . .	11

## Part 2 – POLE SPECIFICATIONS

<b>6. Testing</b>	13
6.1 Environmental Service	13
6.2 Pole Testing	14
6.3 Reporting Design Values	18
<b>7. Pole Classification and Serviceability</b>	19
7.1 Pole Classification Comparison to Wood	19
<b>8. Service Loads</b>	22
8.1 Overview of Service Loads	22

## Part 3 – RECOMMENDED CONSTRUCTION GUIDELINES

<b>9. Hardware Attachments</b>	23
9.1 Attachments to FRP Utility Poles	23
9.2 Fasteners	27
9.3 Torque Limits	27
9.4 Self-Drilling Screws	28
9.5 Banding	28
9.6 Step Attachments and Climbing	29
<b>10. Assembly</b>	31
10.1 Modular Pole Assembly	31
10.2 Identification Tags	31
10.3 Top Caps and Base Plates	31
<b>11. Installation</b>	32
11.1 Installation	32
11.2 Picking Poles at Job Site	32
11.3 Foundations and Backfill	33



11.4 Other Considerations . . . . .	.34
11.5 Through-Bolt Torque Limits . . . . .	.35
11.6 Field Drilling . . . . .	.35
11.7 Hardware Mounting . . . . .	.36
11.8 Grounding . . . . .	.36
11.9 Climbing . . . . .	.36
<b>12. Logistics . . . . .</b>	<b>.37</b>
12.1 Shipping . . . . .	.37
12.2 Loading and Unloading . . . . .	.37
12.3 Storage . . . . .	.38
12.4 Disposal . . . . .	.38
<b>13. Field Inspection &amp; Repair . . . . .</b>	<b>.39</b>
13.1 Inspecting FRP Utility Poles . . . . .	.39
13.2 Types of Tests . . . . .	.39
13.3 Field Repair . . . . .	.40
<b>Appendix A - Glossary . . . . .</b>	<b>.41</b>
<b>References . . . . .</b>	<b>.45</b>

## LIST OF FIGURES

Figure 2.4-1	Examples of single section pole . . . . .	5
Figure 2.4-2	Modular poles being staged before assembly of pole, and various pole installation methods . . . . .	5
Figure 2.4-3	Examples of modular poles . . . . .	6
Figure 4.2-1	Schematic of the pultrusion process . . . . .	9
Figure 4.3-1	Schematic of the filament winding process . . . . .	10
Figure 6.1.1	FRP pole exposed to a severe fire test . . . . .	14
Figure 6.2-1	Typical washer pull-through test set up . . . . .	17
Figure 6.2-2	Typical pin bearing strength test in which the pole hardware bolt passes through both walls of the pole . . . . .	17
Figure 7.1-1	FRP utility pole being tested per ANSI O5.1 . . . . .	19
Figure 9.1-1	Example of cleated hardware not be used on FRP utility poles . . . . .	23
Figure 9.1-2	Example of a post insulator gain base that is well matched to the radius of the FRP utility pole . . . . .	24
Figure 9.1-3	Example of a bearing plate on an FRP utility pole . . . . .	24
Figure 9.1-4	Example of a cross arm mounted on a bearing plate on an FRP utility pole . . . . .	25
Figure 9.1.5	Example of a guy mount built into a fiberglass crossarm bracket . . . . .	25
Figure 9.1.6	Example installed guy attachment to crossarm bracket . . . . .	26
Figure 9.1-7	Example of a two bolt guying tee on an FRP utility pole . . . . .	26
Figure 9.1-8	Example of a two bolt guying tee on a three bolt plate . . . . .	26
Figure 9.5-1	Example of a strap style band on an FRP utility pole . . . . .	28
Figure 9.5-2	Example of a continuous strap style band on an FRP utility pole . . . . .	28
Figure 9.6-1	Example of a lineman climbing an FRP utility pole with pole steps . . . . .	29
Figure 9.6-2	Example of lineman working off steps and work platform . . . . .	30
Figure 11.2-1	Workers carrying 10in. (254 mm) diameter 40 ft. (12.2 m) pole in a remote location . . . . .	33
Figure 11.4-1	FRP utility pole set in a blasted rock hole with a corrugated plastic sleeve to protect the pole . . . . .	35
Figure 12.2-1	Example of nested, modular FRP utility poles being unloaded with a boom and a nylon sling . . . . .	37

## LIST OF TABLES

Table 2.3-1	Potential leaching of treatment chemicals . . . . .	4
Table 5.4-1	Tolerances for FRP utility poles . . . . .	11
Table 7.1-1	ANSI O5.1 wood pole class/load definitions . . . . .	20
Table 13.2-1	Utility pole inspection observation . . . . .	40

This is a preview of "ANSI/ACMA/UCSC UP01-...". [Click here to purchase the full version from the ANSI store.](#)

# I. SCOPE

## I.1 Scope

This specification encompasses the design, materials, properties, manufacturing, quality control, assembly and installation, and inspection of directly embedded FRP utility poles. Applications include cantilevered, framed and combined structures. This specification does not cover crossarms, lattice structures, conductors, insulators, stand-offs or other FRP components used in the electrical grid.

For transmission applications, a civil engineer and a geotechnical expert must authorize the foundation requirements for a given loading criteria.

## I.2 Definitions

**Certificate of Conformance** – Test reports, furnished by the Manufacturer that demonstrate the constituent materials used in the FRP utility poles are determined to be in compliance with the applicable material specifications, by the Manufacturer.

**Contract Documents** – Set of documents that provide the basis for a construction project; these documents may include the Owner-Contractor Contract, Project Specifications, Project Drawings and addenda.

**FRP** – Fiber Reinforced Polymer composite or Fiberglass Reinforced Polymer.

**Fiber Reinforcement** – Fiber reinforcing materials are typically E or E-CR Glass manufactured per ASTM D578. The fiber reinforcement can be converted into various forms; including roving, stitched fabrics, continuous filament or woven mats.

**Manufacturer** – The party responsible for producing the FRP utility pole and any associated components.

**Polymer Resin** – The FRP resin system includes the base resin, additives, fillers, catalysts, UV protection agents, fire retardants, pigments, release agents and other compounds added to this resin and used in the manufacturing process. Commonly used thermoset resin systems include polyesters, vinyl esters, phenolic, polyurethane and epoxies that are compatible with the fiber reinforcement to develop desired mechanical and structural properties.

## I.3 Reference Specifications and Standards

### American National Standards Institute (ANSI)

ANSI O5.1 – 2017 American National Standard for Wood Products – Specifications and Dimensions (for Wood Poles)