

American Nuclear Society

REAFFIRMED

October 28, 2008

ANSI/ANS-19.3.4-2002 (R2008)

May 18, 2017


ANSI/ANS-19.3.4-2002 (R2017)

**the determination of thermal energy
deposition rates in nuclear reactors**

an American National Standard

This standard has been reviewed and reaffirmed with the recognition that it may reference other standards and documents that may have been superseded or withdrawn. The requirements of this document will be met by using the version of the standards and documents referenced herein. It is the responsibility of the user to review each of the references and to determine whether the use of the original references or more recent versions is appropriate for the facility. Variations from the standards and documents referenced in this standard should be evaluated and documented.

This standard does not necessarily reflect recent industry initiatives for risk informed decision-making or a graded approach to quality assurance. Users should consider the use of these industry initiatives in the application of this standard.



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA

ANSI/ANS-19.3.4-2002

**American National Standard
The Determination of Thermal Energy
Deposition Rates in Nuclear Reactors**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-19.3.4**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved March 20, 2002
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Copyright © 2003 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-19.3.4-2002 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This Foreword is not a part of American National Standard for the Determination of Thermal Energy Deposition Rates in Nuclear Reactors, ANSI/ANS-19.3.4-2002 [formerly N676-1976].)

It is the intent of this American National Standard to provide guidance for performing and validating the sequence of calculations leading to prediction of thermal energy deposition rates in nuclear reactors and to provide guidelines by which the adequacy of design calculations may be demonstrated. This standard recognizes the diversity of the calculational procedures employed in reactor design. Consequently, the major thrust of this standard is in the areas of verification and documentation. The standard is intended to cover thermal energy deposition calculations for the entire nuclear industry—from fast to thermal reactors, research to power reactors. Since many different kinds of calculations are performed, each having its own requirement for accuracy and verification, it is necessary that this standard be of a general nature.

Compliance with the intent of this standard can be demonstrated for an intended area of applicability of the calculational system used by meeting the following requirements:

- (1) *Source Distribution.* Neutron reaction rate distributions and photon and beta particle emitter distributions are to be obtained from calculations made in accordance with American National Standard “The Determination of Neutron Reaction Rate Distributions and Reactivity of Nuclear Reactors,” ANSI/ANS-19.3-1995, or similar applicable standard. Data are to be found in accordance with American National Standard “Nuclear Data Sets for Reactor Design Calculations,” ANSI/ANS-19.1-1983 (R1989), or equivalent standard.
- (2) *Selection of Models and Methods.* All phenomena listed in Table 1 are to be considered, and their treatment justified. Use of any approximation and application not explicitly permitted in Table 2 is to be justified. Acceptable justification may be degree of rigor, conservatism, or increased margin incorporated in design.
- (3) *Verification.* The method of analysis is to be verified against experiments or more rigorous and well-established analytical methods.
- (4) *Evaluation of Accuracy.* Accuracy and range of applicability of data and methods are to be evaluated by establishment of biases and uncertainties, with degree of confidence, for the calculations including allowance for uncertainties in the comparison data.
- (5) *Documentation.* Details of the above procedures are to be documented.

It is the intent of this standard to require the individual to (1) give careful consideration to those physical and numerical effects that may contribute to the validity of the results, (2) document the reasons for the choice of calculational path, and (3) verify the calculational system used over the intended range of applicability by testing it against appropriate experiments and more rigorous calculations.

The requirement for documentation is a crucial part of this standard and will provide an auditable path. In those instances where the foregoing documentation is proprietary in nature, documentation edited by excluding the proprietary information shall be prepared and be publicly available or available on request. Areas omitted due to proprietary consideration shall be noted where possible. The standard would not require all documentation to be made public, and thus by implication acknowledges the existence of proprietary documentation.

This standard, ANS-19.3.4, as revised, was first approved in 1976. It was reaffirmed in 1983 and again in 1989. This revision now provides better guidance for

the CANDU Reactor, and these changes are mostly reflected in Table 2. There are some minor changes for clarification. Suggestions for improvement should be sent to the American Nuclear Society, 555 N. Kensington Ave., La Grange Park, IL 60526.

This revised standard was developed by Working Group ANS-19.3.4 of the American Nuclear Society, which had the participation of the following members during the period it prepared and approved the standard:

R. T. Perry, Chairman, *Los Alamos National Laboratory*

C. R. Boss, *Atomic Energy of Canada Limited*
W. Charlton, *Los Alamos National Laboratory*
D. Cokinos, *Brookhaven National Laboratory*
M. Houts, *Los Alamos National Laboratory*
A. Jonsson, *ABB-Combustion Engineering*
T. Parish, *Texas A&M University*
R. Rothrock, *Oak Ridge National Laboratory*
B. Rouben, *Atomic Energy of Canada Limited*
W. B. Wilson, *Los Alamos National Laboratory*

The original standard was developed by the following members of Working Group ANS-19.3.4 of the American Nuclear Society:

A. Weitzberg, Chairman, *General Electric Company*

H. S. Bailey, *General Electric Company*
M. Becker, *Rensselaer Polytechnic Institute*
D. Cullen, *Lawrence Livermore National Laboratory*
W. R. D'Angelo, *Niagara Mohawk Power Corporation*
D. J. Denver, *Yankee Atomic Electric Company*
M. J. Driscoll, *Massachusetts Institute of Technology*
W. J. Eich, *Nuclear Associates International, Inc.*
H. J. Fenech, *University of California, Santa Barbara*
G. F. Flanagan, *Oak Ridge National Laboratory*
W. G. Flournoy, *Southern California Edison Company*
J. Folsom, *Middle South Services*
O. H. Gailar, *Purdue University*
W. E. Graves, *Savannah River Laboratory*
C. J. Hamilton, *Gulf General Atomic Company*
R. S. Harding, *Combustion Engineering, Inc.*
R. T. Harris, *Northeast Utilities Service Company*
J. F. Kunze, *Aerojet Nuclear Company*
R. A. Grimesey, *Aerojet Nuclear Company*
D. D. Lanning, *Massachusetts Institute of Technology*
L. K. Mathews, *Southern Services, Inc.*
A. F. McFarlane, *Westinghouse Nuclear Fuels Division*
D. Meneghetti, *Argonne National Laboratory*
J. O. Mingle, *Kansas State University*
J. Nims, *Detroit Edison Company*
E. E. Pilat, *Yankee Atomic Electric Company*
T. Schnatz, *Middle South Services*
R. D. Shamberger, *Gulf United Nuclear Fuels Corporation*
P. Shen, *Southern California Edison Company*
T. M. Wampler, *Babcock and Wilcox Company*
B. D. Webb, *Consumers Power Company*
M. G. Zaalouk, *Carolina Power and Light Company*

Subcommittee ANS-19, Physics of Reactor Design, of the American Nuclear Society Standards Committee had the following members at the time it processed and approved this standard:

D. Cokinos, Chairman, *Brookhaven National Laboratory*

S. Baker, *TWE Software*
A. L. Casadei, *Westinghouse Electric Corporation*
R.-T. Chaing, *General Electric Company*
D. J. Diamond, *Brookhaven National Laboratory*
D. R. Harris, *Rensselaer Polytechnic Institute*
J. Katakura, *Japan Atomic Energy Research Institute*
L. Lois, *U.S. Nuclear Regulatory Commission*
R. D. Mosteller, *Los Alamos National Laboratory*
L. D. Noble, *General Electric Company*
T. A. Parish, *Texas A&M University*
R. T. Perry, *Los Alamos National Laboratory*
R. B. Rothrock, *Oak Ridge National Laboratory*
B. Rouben, *Atomic Energy of Canada Limited*
A. Weitzberg, *NUS Corporation*
W. B. Wilson, *Los Alamos National Laboratory*

The American Nuclear Society Standards Consensus Committee N17, Research Reactors, Reactor Physics, and Radiation Shielding, had the following members at the time it reviewed and approved this standard:

T. M. Raby, Chairman, *National Institute of Standards and Technology*
Suriya Ahmad, Secretary, *American Nuclear Society*

A. D. Callihan, Individual
R. E. Carter, EG&G
D. Cokinos, Brookhaven National Laboratory
A. DeLaPaz, Vista Technologies
B. Dodd, Health Physics Society
C. Duffey, American Institute of Chemical Engineers
W. A. Holt, American Public Health Association
W. C. Hopkins, Bechtel Corporation
L. I. Kopp, Individual
L. B. Marsh, U.S. Nuclear Regulatory Commission
J. Miller, Institute of Electrical and Electronics Engineers
J. E. Oelhoeft, Individual
W. J. Richards, McClellan Air Force Base
R. Seale, University of Arizona
T. Schmidt, Sandia National Laboratories
A. Smetana, Savannah River Laboratory
J. F. Torrence, National Institute of Standards and Technology
E. G. Tourigny, U.S. Department of Energy
D. K. Trubey, Individual
A. Weitzberg, NUS Corporation
W. L. Whittemore, General Atomics

Contents	Section	Page
	1. Introduction	1
	2. Scope	1
	3. Definitions	1
	3.1 Limitations	1
	3.2 Glossary of Terms	1
	4. Relation to Other Standards	1
	5. Energy Deposition	2
	5.1 General	2
	5.2 Local Energy Deposition by Heavy Charged Particles	3
	5.3 Local Energy Deposition by Beta Particles	3
	5.4 Local Energy Deposition by Neutron Slowing Down and Capture	3
	5.5 Photon Heating	4
	5.6 Summary	5
	6. Verification of Computed Results	5
	6.1 General	5
	6.2 Methods of Verification	5
	6.3 Evaluation of Accuracy	7
	7. Documentation	7
	8. Summary of Requirements of This Standard	8
	9. References	8
	Tables	
	Table 1 Phenomena to be Considered	5
	Table 2 Acceptability of Approximation by Application	6

The Determination of Thermal Energy Deposition Rates in Nuclear Reactors

1 Introduction

Establishment of the thermal energy source distribution is essential to the determination of the temperature field within a nuclear reactor, and thus to the calculation of heat transfer and transport, thermal stress, and the many physical and chemical properties of materials that depend upon temperature. The energy of interest is ultimately deposited by charged particles resulting from nuclear or atomic interactions with ambient neutrons and photons. The charged particles are primarily fission products, recoiling nuclei, and electrons. In the general case, nearly all of the many phenomena of atomic and low-energy nuclear physics are involved in the conversion of the energy released by fission into the molecular motion known as thermal energy. Because of this inherent complexity and the importance of the results to the achievement of a safe and reliable reactor design, adherence to good practice in these calculations is important.

2 Scope

It is the purpose of this standard to provide criteria for the following:

- (1) determination of the energy allocation among the principal particles and photons produced in fission, both prompt and delayed;
- (2) adoption of appropriate treatment of heavy charged particle and electron slowing down in matter;
- (3) determination of the spatial energy deposition rates resulting from the interactions of neutrons;
- (4) calculation of the spatial energy deposition rates resulting from the various interactions of photons with matter;
- (5) presentation of the results of such computations, including verification of accuracy and specification of uncertainty.

This standard addresses the energy generation and deposition rates for all types of nuclear reactors where the neutron reaction rate distribution and photon and beta emitter distributions are known. Its scope is limited to the reactor core, including blanket zones, control elements and core internals, pressure vessel, and the thermal and biological shielding.

3 Definitions

3.1 Limitations

The definitions given below are of a restricted nature for the purpose of this standard. Other specialized terms are defined in *Glossary of Terms in Nuclear Science and Technology* [1]¹, or in the definition sections of standards specified in Section 4 of this standard.

3.2 Glossary of Terms

energy deposition rate density. The amount of energy deposited per unit volume per unit time (watts/cm³).

energy generation rate density. The amount of original energy source per unit volume per unit time (watts/cm³).

experimental data. Any experimentally measured quantity or quantities; as such it is applied herein to both energy generation and deposition measurements relevant to this standard.

shall, should, and may. The word "shall" is used to denote a requirement; the word "should," to denote a recommendation; and the word "may," to denote permission, neither a requirement nor a recommendation.

4 Relation to Other Standards

American National Standard for "The Determination of Neutron Reaction Rate Distributions

¹ Numbers in brackets refer to corresponding numbers in Section 9, "References."