



# **A Guide for Acquisition and Documentation of Reference Power Reactor Physics Measurements for Nuclear Analysis Verification**

An American National Standard

Published by the  
American Nuclear Society  
555 N. Kensington Ave  
La Grange Park, IL 60526

ANSI/ANS-19.4-2017



**ANSI/ANS-19.4-2017**

**American National Standard  
a guide for acquisition and documentation  
of reference power reactor physics measurements  
for nuclear analysis verification**

Secretariat  
**American Nuclear Society**

Prepared by the  
**American Nuclear Society  
Standards Committee  
Working Group ANS-19.4**

Published by the  
**American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60526 USA**

Approved August 24, 2017  
by the  
**American National Standards Institute, Inc.**

## American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Inquiries about requirements, recommendations, and/or permissive statements (i.e., "shall," "should," and "may," respectively) should be sent to the Scientific Publications and Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society**  
**555 North Kensington Avenue**  
**La Grange Park, Illinois 60526 USA**



**This document is copyright protected.**

Copyright © 2017 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-19.4-2017 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

## **Inquiry Requests**

The American Nuclear Society (ANS) Standards Committee will provide responses to inquiries about requirements, recommendations, and/or permissive statements (i.e., “shall,” “should,” and “may,” respectively) in American National Standards that are developed and approved by ANS. Responses to inquiries will be provided according to the Policy Manual for the ANS Standards Committee. Nonrelevant inquiries or those concerning unrelated subjects will be returned with appropriate explanation. ANS does not develop case interpretations of requirements in a standard that are applicable to a specific design, operation, facility, or other unique situation only and therefore is not intended for generic application.

Responses to inquiries on standards are published in ANS’s magazine, *Nuclear News*, and are available publicly on the ANS website or by contacting the ANS Scientific Publications and Standards Department.

## **Inquiry Format**

Inquiry requests shall include the following:

- (1) the name, company name if applicable, mailing address, and telephone number of the inquirer;
- (2) reference to the applicable standard edition, section, paragraph, figure, and/or table;
- (3) the purpose(s) of the inquiry;
- (4) the inquiry stated in a clear, concise manner;
- (5) a proposed reply, if the inquirer is in a position to offer one.

Inquiries should be addressed to:

American Nuclear Society  
Scientific Publications and Standards Department  
555 N. Kensington Avenue  
La Grange Park, IL 60526

or [standards@ans.org](mailto:standards@ans.org)

This is a preview of "ANSI/ANS-19.4-2017". [Click here to purchase the full version from the ANSI store.](#)

American National Standard ANSI/ANS-19.4-2017

**Foreword** (This foreword is not a part of American National Standard “A Guide for Acquisition and Documentation of Reference Power Reactor Physics Measurements for Nuclear Analysis Verification,” ANSI/ANS-19.4-2017, but is included for informational purposes.)

It is the purpose of this standard to specify criteria for performing and documenting measurements on light water power reactors that are to be used as reference measurements in the validation of reactor physics computational methods. Considerably more confidence is placed in nuclear analysis methods when they have been successfully used to calculate performance characteristics that have been carefully measured in an actual operating system. The existence of well-documented measurements made in a number of operating power reactors will fill a need on the part of the nuclear designer and reactor operator and will permit the development of increased confidence in the design and performance analysis methods used to predict reactor performance. This standard is not a guide for routine measurement of reactor physics parameters in an operating reactor. The objective of routine measurements carried out on an operating reactor is to satisfy specific operational, licensing, and contractual requirements. In many cases, however, measurements made on a routine basis are of sufficient quality to merit their use as reference measurements, and reporting these measurements in accordance with this guide is encouraged.

In addition, if time, personnel, and instrumentation are available during the course of operation to perform additional measurements not normally required, reactor designers and operators are encouraged to specify, perform, document, and report such measurements for use as reference power reactor physics measurements.

This standard was developed primarily for application to measurements on reactors whose pertinent descriptions are available, or can be made available, to the technical community. This does not preclude its use on reactors for which some reactor information required to simulate the measurement is proprietary. Since performance of reference measurements is not required on any system, application of this standard is not related to the question of what reactor design information should, or should not, be publicly disseminated.

This standard provides criteria for reference reactor physics measurements. As such it specifically considers only those types of reactor physics measurements that experience has shown to be practical and reproducible when carried out in large power reactors. The intended current application of this standard is confined to light water–moderated and light water–cooled power reactors.

This standard is intended primarily for measurements that can be performed at the reactor site; destructive analysis of the spent or partially spent fuel to determine isotopic composition, for example, is not covered. In the event such destructive analysis is carried out, however, its usefulness is increased if it is preceded by a series of reference-quality measurements carried out in accordance with this standard.

As revised, this standard reflects current power reactor terminology and general practices. Guidance on periodic updates of spatial in-core power distributions and reactor core operating history is given in terms of effective full-power months rather than specific megawatt days per metric ton to provide for a common and flexible terminology. Proper axial alignment relative to the core midplane is identified as an important consideration in adjusting raw spatial in-core measurements. Control rod worth measurement using the control group exchange (rod swap) method that is now commonly used in the industry has been added. References to ANSI/ANS-19.6.1-2011 (R2016), “Reload Startup Physics Tests for Pressurized Water Reactors,” and ANSI/ANS-19.11-2017, “Calculation and Measurement of the Moderator Temperature Coefficient of Reactivity for Pressurized Water Reactors,” have

been identified as related standards. Documentation of fuel rod peaking factors as a desirable measurement, identification of radial variation in fuel assembly geometry, and a more detailed organization to the format of reference measurement documentation has been incorporated into the appendices.

This standard was developed by Working Group ANS-19.4 of the American Nuclear Society. The following members contributed to this standard:

E. R. Knuckles (Chair), *Individual*

J. D. Bess, *Idaho National Laboratory*

R. T. Chiang, *Individual*

M. Eckenrode, *AREVA Inc.*

M. Mahgerefteh, *Exelon Corporation*

J. A. Roberts, *Kansas State University*

C. T. Rombough, *CTR Technical Services, Inc.*

B. Rouben, *Individual*

R. W. Sancton, *Individual*

The Reactor Physics Subcommittee had the following membership at the time of its approval of this standard:

D. M. Cokinos (Chair), *Brookhaven National Laboratory*

C. T. Rombough (Secretary), *CTR Technical Services, Inc.*

A. Attard, *U.S. Nuclear Regulatory Commission*

S. P. Baker, *Transware Enterprises*

J. D. Bess, *Idaho National Laboratory*

M. C. Brady Raap, *Individual*

A. Campos, *AREVA Inc.*

R. T. Chiang, *Individual*

M. DeHart, *Idaho National Laboratory*

D. J. Diamond, *Brookhaven National Laboratory*

M. Eckenrode, *AREVA Inc.*

I. C. Gauld, *Oak Ridge National Laboratory*

A. Haghighat, *Virginia Tech Research Center*

J. I. Katakura, *Japan Atomic Energy Agency*

E. R. Knuckles, *Individual*

R. C. Little, *Los Alamos National Laboratory*

M. Mahgerefteh, *Exelon Corporation*

E. M. Nichita, *University of Ontario Institute of Technology*

B. Rouben, *Individual*

A. Weitzberg, *Individual*

W. Wilson, *Individual*

The Safety and Radiological Analysis Consensus Committee had the following membership at the time of its approval of this standard:

A. O. Smetana (Chair), *Savannah River National Laboratory*

J. M. Jarvis (Vice Chair), *Bechtel Corporation*

F. A. Alpan, *Westinghouse Electric Company, LLC*

R. S. Amato, *Individual*

M. C. Brady Raap, *Individual*  
D. M. Cokinos, *Brookhaven National Laboratory*  
D. J. Dudziak, *Los Alamos National Laboratory*  
C. C. Graham, *Health Physics Society Representative (Employed by Ameren)*  
M. K. Gupta, *AECOM-Professional Solutions*  
N. E. Hertel, *Georgia Institute of Technology*  
P. Hulse, *Sellafield Ltd.*  
D. E. Palmrose, *U.S. Nuclear Regulatory Commission*  
C. T. Rombough, *CTR Technical Services, Inc.*  
C. E. Sanders, *University of Nevada, Las Vegas*  
A. Weitzberg, *Individual*

This is a preview of "ANSI/ANS-19.4-2017". [Click here to purchase the full version from the ANSI store.](#)

American National Standard ANSI/ANS-19.4-2017

## Contents

<b>Section</b>	<b>Page</b>
<b>1</b> Introduction .....	1
<b>2</b> Scope .....	1
<b>3</b> Definitions .....	2
3.1 Shall, should, and may .....	2
3.2 Definition of terms .....	2
<b>4</b> Relation to other standards .....	2
<b>5</b> Physical description of reactor.....	3
5.1 Fixed reactor parameters .....	3
5.1.1 Reactor core description.....	3
5.1.2 Fuel assembly description .....	4
5.1.3 Control element description .....	4
5.1.4 Reactor instrumentation .....	4
5.2 Reactor operating history .....	5
<b>6</b> Test description.....	5
6.1 State-point measurements .....	6
6.1.1 Zero-power critical configurations .....	6
6.1.2 At-power critical configurations .....	6
6.1.3 Spatial in-core detector response maps .....	7
6.2 Zero-power differential measurements .....	7
6.2.1 Control rod group worth.....	7
6.2.2 Reactor temperature coefficient .....	8
6.2.3 Soluble poison worth.....	9
6.3 Gamma ray spectrometry .....	9
6.3.1 Specific data requirements .....	10
6.3.2 Additional documentation .....	10
<b>7</b> Summary of reference measurement documentation.....	10
7.1 Abstract .....	11
7.2 Documentation of fixed parameter and operating history .....	11
7.3 Documentation of methods and techniques.....	11
7.4 Documentation of test results .....	11
7.5 On-site retention of backup information .....	12
<b>8</b> References .....	12
 <b>Appendices</b>	
Appendix A Desirable Power Reactor Measurements .....	13
Appendix B Core and Component Description.....	15
Appendix C Suggested Format for Reference Measurement Documentation.....	17
 <b>Table</b>	
Table A.1 Desirable power reactor measurements .....	13

This is a preview of "ANSI/ANS-19.4-2017". [Click here to purchase the full version from the ANSI store.](#)

American National Standard ANSI/ANS-19.4-2017

# A Guide for Acquisition and Documentation of Reference Power Reactor Physics Measurements for Nuclear Analysis Verification

## 1 Introduction

Verification of the calculational system used to predict the nuclear performance characteristics of a power reactor is an essential prerequisite to establishing the reliability of that calculational system. The components of such a system, including the nuclear data sets, neutron spectra calculations, spatial homogenization procedures, and neutron transport models all involve approximations and uncertainties. Because of the inherent physical and geometric complexities of an operating reactor, the effects of these approximations and uncertainties on the accuracy of the results obtained with the calculational system are difficult to evaluate. Experience has shown that a very useful technique for assessing the reliability of a calculational system in evaluating the performance characteristics of a reactor is to use it to calculate the same or similar characteristics in one or a number of similar reactors for which measurements are available. It is the intent of this standard<sup>1)</sup> to establish criteria for the acquisition and documentation of measurements made for this purpose. For the most part, power reactor measurements are of an integral nature and as such could be most valuable in testing an overall prediction. There is also value in having measurements of the same type on several reactors in order to minimize systematic errors that might be attributable to a particular reactor.

It is recognized that the measurements program carried out in any single reactor will probably not produce reference-quality data on all or even the majority of the specific measurements described in Sec. 6. Documentation of even a small part of an overall measurements program can, however, be a valuable contribution to the literature. A list of desirable power reactor measurements is given in Appendix A.

## 2 Scope

This standard specifies and provides requirements for the reference measurements of reactor geometry, reactivity, and operation parameters in light water power reactors. The measurement data are used in the verification of reactor physics computational methods used for nuclear core designs and analyses. This standard identifies the types of parameters, a brief description of test conditions and experimental data required for such reference measurements, problems and concerns that may affect the accuracy or interpretation of the data, and the criteria to be used in documenting the results of reference measurements.

---

<sup>1)</sup>The current standard, ANSI/ANS-19.4-2017, is hereinafter referred to as "this standard."