



Burnup Credit for LWR Fuel

REAFFIRMED

August 7, 2020

ANSI/ANS-8.27-2015 (R2020)

ANSI/ANS-8.27-2015

An American National Standard

This standard has been reviewed and reaffirmed with the recognition that it may reference other standards and documents that may have been superseded or withdrawn. The requirements of this document will be met by using the version of the standards and documents referenced herein. It is the responsibility of the user to review each of the references and to determine whether the use of the original references or more recent versions is appropriate for the facility. Variations from the standards and documents referenced in this standard should be evaluated and documented. This standard does not necessarily reflect recent industry initiatives for risk informed decision-making or a graded approach to quality assurance. Users should consider the use of these industry initiatives in the application of this standard.

Published by the
American Nuclear Society
555 N. Kensington Ave
La Grange Park, IL 60526

ANSI/ANS-8.27-2015

**American National Standard
Burnup Credit for LWR Fuel**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-8.27**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved November 10, 2015
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Inquiries about requirements, recommendations, and/or permissive statements (i.e., "shall," "should," and "may," respectively) should be sent to the Scientific Publications and Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**



This document is copyright protected.

Copyright © 2015 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-8.27-2015 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Inquiry Requests

The American Nuclear Society (ANS) Standards Committee will provide responses to inquiries about requirements, recommendations, and/or permissive statements (i.e., “shall,” “should,” and “may,” respectively) in American National Standards that are developed and approved by ANS. Responses to inquiries will be provided according to the Policy Manual for the ANS Standards Committee. Nonrelevant inquiries or those concerning unrelated subjects will be returned with appropriate explanation. ANS does not develop case interpretations of requirements in a standard that are applicable to a specific design, operation, facility, or other unique situation only and therefore is not intended for generic application.

Responses to inquiries on standards are published in ANS’s magazine, *Nuclear News*, and are available publicly on the ANS Web site or by contacting the ANS Scientific Publications and Standards Department.

Inquiry Format

Inquiry requests shall include the following:

- (1) the name, company name if applicable, mailing address, and telephone number of the inquirer;
- (2) reference to the applicable standard edition, section, paragraph, figure, and/or table;
- (3) the purpose(s) of the inquiry;
- (4) the inquiry stated in a clear, concise manner;
- (5) a proposed reply, if the inquirer is in a position to offer one.

Inquiries should be addressed to

American Nuclear Society
ATTN: Scientific Publications and Standards Department
555 N. Kensington Avenue
La Grange Park, IL 60526

or standards@ans.org

This is a preview of "ANSI/ANS-8.27-2015 (...". [Click here to purchase the full version from the ANSI store.](#)

American National Standard ANSI/ANS-8.27-2015

Foreword

(This foreword is not a part of American National Standard “Burnup Credit for LWR Fuel,” ANSI/ANS-8.27-2015.)

Burnup credit is a term commonly used to account for an overall negative reactivity effect resulting from irradiation. In order to apply burnup credit, there needs to be both supporting analyses and implementation steps (such as procedures, burnup assignments, and verification techniques).

Including burnup credit in the design and operation enables much improved flexibility (e.g., wider range of acceptable fuel) and efficiency (e.g., higher loading capacities), as compared to spent fuel system designs based on unirradiated fuel without credit for fixed burnable absorbers. These advantages have encouraged burnup credit to be applied in the nuclear criticality safety evaluation of storage, transportation, and disposal systems containing irradiated fuel. The scope of this standard is restricted to burnup credit for commercial light water reactor fuel applications.

Burnup credit requires evaluation of the effect of irradiation on the fuel composition, which increases the *computation* complexity. However, the negative reactivity determined through burnup credit may be used to reduce the *overall* complexity of maintaining criticality safety. Several American National Standards Institute/American Nuclear Society (ANSI/ANS) standards provide guidance that is relevant to burnup credit. This standard supplements the guidance given in those standards and provides requirements and recommendations for handling the unique issues associated with the implementation of burnup credit.

The 2015 revision to this standard was limited to two clarifications in the text of the standard. First, it clarified the combined validation approach given in Sec. 5.2 by adding a second paragraph which introduces a new term, Δk_d , which is an allowance for the bias and uncertainty in bias of the change in k with irradiation. Second, the 2015 revision makes it clear that the burnup uncertainty can be statistically combined with other uncertainties. In addition to these clarifications, an appendix on boiling water reactor pool burnup credit was added.

This standard might reference documents and other standards that have been superseded or withdrawn at the time the standard is applied. A statement has been included in the reference section that provides guidance on the use of references.

Working Group ANS-8.27 of ANS Subcommittee 8, Fissionable Materials Outside Reactors, drafted this standard. The following members participated in the preparation:

D. B. Lancaster (Chair), *NuclearConsultants.com*
C. T. Rombough (Secretary), *CTR Technical Services, Inc.*

S. Anton, *Holtec International*
S. P. Baker, *TransWare Enterprises, Inc.*
A. Barto, *U.S. Nuclear Regulatory Commission*
K. L. Bennett, *GE Hitachi Nuclear Energy*
M. C. Brady Raap, *Pacific Northwest National Laboratory*
J. P. Coletta, *Duke Energy*
J. C. Hannah, *Global Nuclear Fuel*
E. Knuckles, *Individual*
Z. Martin, *Tennessee Valley Authority*
J. R. Massari, *Constellation Energy*

D. Mennerdahl, *Individual–Sweden*
W. A. Metwally, *University of Sharjah–United Arab Emirates*
D. Mueller, *Oak Ridge National Laboratory*
P. Narayanan, *TransNuclear, Inc.*
C. V. Parks, *Oak Ridge National Laboratory*
H. Pfeifer, *Nuclear Analysis Company International*
M. Rahimi, *U.S. Nuclear Regulatory Commission*
D. A. Thomas, *AREVA Inc.*
K. Wood, *U.S. Nuclear Regulatory Commission*
A. Zimmer, *General Atomics*
J. F. Zino, *GE Nuclear Energy*

The following is a list of people who supported the working group but were not able to actively participate throughout the entire process:

A. Attard, R. Beall, J. Boshoven, D. Cacciapouti, K. Cummings, M. DeHart, M. DeVoe, J. Dunlap, D. Galvin, J. Gulliford, R. Hall, L. Hassler, R. Hommerson, D. Hutson, R. Jones, J. Kessler, L. Kopp, V. Kucukboyaci, R. Kunita, A. Machiels, L. Markova, W. Marshall, M. Mason, R. McKnight, V. Mills, S. Mitake, G. O’Connor, P. O’Donnell, H. Toffer, S. Turner, J. Wagner, G. Walden, C. Walker, A. H. Wells, B. Wilson, C. Withee

This standard was prepared under the guidance of ANS Subcommittee 8, which had the following membership at the time of its approval:

L. E. Paulson (Chair), *GE Hitachi Nuclear Energy*
M. Crouse (Secretary), *Link Solutions, Inc.*

J. S. Baker, *Savannah River Nuclear Solutions*
E. Elliott, *Los Alamos National Laboratory*
D. Erickson, *Savannah River Nuclear Solutions*
A. S. Garcia, *U.S. Department of Energy*
B. O. Kidd, *Babcock & Wilcox Nuclear Operations Group*
K. Kimball, *B&W Y-12, LLC*
D. Kupferer, *Defense Facilities Nuclear Safety Board*
T. P. McLaughlin, *Individual*
S. Monahan, *Sandia National Laboratories*
J. A. Morman, *Argonne National Laboratory*
T. A. Reilly, *Individual*
H. Toffer, *Individual*
C. Tripp, *U.S. Nuclear Regulatory Commission*
D. Winstanley, *Sellafield Sites–United Kingdom*

The membership of the Nuclear Criticality Safety Consensus Committee, which reviewed and approved this standard in 2015, had the following membership:

R. D. Busch (Chair), *University of New Mexico*
L. L. Wetzel (Vice Chair), *Babcock & Wilcox Nuclear Operations Group*
W. R. Shackelford (Secretary Pro Tem), *Nuclear Fuel Services, Inc.*

R. Bartholomay, *URS Professional Solutions, LLC*
L. Berg, *U.S. Department of Energy*
W. Doane, *AREVA Inc.*
R. S. Eby, *American Institute of Chemical Engineers (Employed by USEC, Inc.)*
C. M. Hopper, *Individual*

B. O. Kidd, *Babcock & Wilcox Nuclear Operations Group*
R. Knief, *Institute of Nuclear Materials Management (Employed by Sandia National Laboratories)*
T. Marenchin, *U.S. Nuclear Regulatory Commission*
S. P. Murray, *Health Physics Society (Employed by General Electric)*
W. R. Shackelford, *Nuclear Fuel Services, Inc.*
R. G. Taylor, *INM Nuclear Safety Services*
R. M. Westfall, *Oak Ridge National Laboratory*
R. E. Wilson, *U.S. Department of Energy*

This is a preview of "ANSI/ANS-8.27-2015 (...". [Click here to purchase the full version from the ANSI store.](#)

American National Standard ANSI/ANS-8.27-2015

Contents

Section	Page
1 Introduction.....	1
2 Scope.....	1
3 Definitions	2
3.1 Shall, should, and may	2
3.2 Limitations	2
3.3 Glossary of terms	2
4 Criteria to establish subcriticality	3
5 Validation for burnup credit.....	4
5.1 Validation of analysis components.....	5
5.1.1 Validation of the nuclide composition analysis	5
5.1.2 Validation of the analysis used to determine k_p	5
5.2 Combined validation approach.....	5
5.3 Analysis of trends	5
6 Burnup credit analysis	5
6.1 Calculation of the nuclide composition.....	6
6.2 Calculation of the system k_p	6
6.3 Generation of loading constraints.....	6
7 Operational considerations.....	7
7.1 Administrative and operating procedures.....	7
7.2 Burnup assignment.....	7
7.3 Independent verification.....	7
8 References.....	7
Appendix	
Appendix Some Considerations in Performing Nuclear Criticality Safety Evaluations for Storage of Irradiated BWR Fuel Using Peak Reactivity.....	9

This is a preview of "ANSI/ANS-8.27-2015 (...". [Click here to purchase the full version from the ANSI store.](#)

American National Standard ANSI/ANS-8.27-2015

Burnup Credit for LWR Fuel

1 Introduction

The purpose of this standard¹⁾ is to provide guidance for criticality safety control (by analysis and implementation) that accounts for reactivity effects of fuel burnup in a UO₂-fueled light water reactor (LWR). ANSI/ANS-8.1-2014, "Nuclear Criticality Safety in Operations with Fissionable Materials Outside Reactors," [1],²⁾ provides broad guidance for administrative and technical practices for the prevention of criticality accidents in the handling, storing, processing, and transporting of fissionable material outside reactors. Generalized basic criteria are presented, and some single-unit limits are specified. This standard is intended to provide specific guidance relative to burnup credit and not to replace the criteria of ANSI/ANS-8.1-2014 [1].

It has often been a practice to base the criticality safety control of systems with irradiated fuel on fresh fuel conditions. Accounting for a reduction in k_{eff} due to irradiation is called "burnup credit."

Systems with fuel containing fixed burnable absorbers can increase in reactivity with irradiation. Therefore, credit for the presence of a burnable absorber must account for the change in reactivity with irradiation. This standard considers such credit for irradiated burnable absorbers a subset of burnup credit. This subset of burnup credit is often called "burnable absorber credit" (e.g., gadolinium credit). Other aspects of accounting for fixed neutron absorbers are addressed in ANSI/ANS-8.21-1995 (R2011), "Use of Fixed Neutron Absorbers in Nuclear Facilities Outside Reactors" [2].

Two additional American National Standards provide guidance relevant to validating burnup credit methods. ANSI/ANS-8.24-2007 (R2012), "Validation of Neutron Transport Methods for Nuclear Criticality Safety Calculations," [3] provides criteria for establishing the validation applicability, estimating the biases and uncertainties, and selecting appropriate subcritical margins, both within and beyond the established benchmark applicability. This standard provides additional requirements for establishing benchmarks for burnup credit applications. ANSI/ANS-19.4-1976 (R2000) (withdrawn), "A Guide for Acquisition and Documentation of Reference Power Reactor Physics Measurements for Nuclear Analysis Verification" [4], provides guidance by which reactor physics measurements from power reactors can be evaluated to determine the appropriateness of their use as reference measurements. This standard provides additional requirements for using the data from power reactors for verification and validation of burnup credit parameters and methods.

The body of this standard is broad to cover all LWR (non-mixed oxide) fuel. In order to focus on specific issues related to boiling water reactor (BWR) analysis, an appendix is attached.

2 Scope

This standard provides criteria for accounting for reactivity effects of fuel irradiation and radioactive decay in criticality safety control of storage, transportation, and disposal of commercial LWR UO₂ fuel assemblies.

¹⁾ The current standard, ANSI/ANS-8.27-2015, is herein referred to as "this standard."

²⁾ Numbers in brackets refer to corresponding numbers in Sec. 8, "References."