

# **2002 STANDARD for**

# **COMMERCIAL AND INDUSTRIAL UNITARY AIR- CONDITIONING CONDENSING UNITS**



**Standard 365**

## **IMPORTANT**

### ***SAFETY DISCLAIMER***

ARI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

ARI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. ARI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

### **ARI CERTIFICATION PROGRAM PROVISIONS**

#### **Scope of the Certification Program**

The Certification Program includes Commercial and Industrial Unitary Air-Conditioning Condensing Units rated at or above 135,000 Btu/h [39,600 W] but below 250,000 Btu/h [73,200 W] at the ARI Standard Rating Conditions (Cooling).

#### **Certified Ratings**

The following Certification Program ratings are verified by test:

1. Single Number Rating Cooling Capacity, Btu/h [W]
2. Single Number Rating Energy Efficiency Ratio, EER, Btu/(W·h)
3. Integrated Part-Load Value, IPLV, Btu/(W·h)

Conformance to the requirements of the Maximum Operating Conditions Tests (Section 8) is also verified by test.

Note:

This standard supersedes ARI Standard 365-94.

## TABLE OF CONTENTS

SECTION	PAGE
Section 1. Purpose .....	1
Section 2. Scope .....	1
Section 3. Definitions .....	1
Section 4. Classifications.....	2
Section 5. Test Requirements .....	2
Section 6. Rating Requirements .....	2
Section 7. Minimum Data Requirements for Published Ratings.....	4
Section 8. Operating Requirements.....	4
Section 9. Marking and Nameplate Data.....	6
Section 10. Conformance Conditions.....	6

## TABLES

Table 1. Classifications of Commercial and Industrial Air-Conditioning Condensing Units .....	2
Table 2. Standard Rating Conditions.....	3

## FIGURE

Figure 1. Part-Load Factor Curve .....	5
--	---

## APPENDICES

Appendix A. References - Normative.....	7
Appendix B. References - Informative.....	7
Appendix C. Method and Example of Calculating Integrated Part-Load Values (IPLV) - Normative .....	8

**TABLE FOR APPENDICES**

Table C1.      Example IPLV Calculation.....10

**FIGURE FOR APPENDICES**

Figure C1.      Part-Load Factor Example.....9

# COMMERCIAL AND INDUSTRIAL UNITARY AIR-CONDITIONING CONDENSING UNITS

## Section 1. Purpose

**1.1 Purpose.** The purpose of this standard is to establish for Commercial and Industrial Unitary Air-Conditioning Condensing Units: definitions; classifications; test requirements; rating requirements; minimum data requirements for Published Ratings; operating requirements; marking and nameplate data; and conformance conditions.

**1.1.1 Intent.** This standard is intended for the guidance of the industry, including manufacturers, engineers, installers, contractors and users.

**1.1.2 Review and Amendment.** This standard is subject to review and amendment as technology advances.

## Section 2. Scope

**2.1 Scope.** This standard applies to factory-made Commercial and Industrial Unitary Air-Conditioning Condensing Units greater than or equal to 135,000 Btu/h [39.6 kW] as defined in Section 3.

**2.1.1 Energy Source.** This standard applies only to electrically-driven, mechanical compression-type condensing units.

**2.2 Exclusions.** This standard does not apply to the testing and rating of condensing units for refrigeration purposes, as defined in ARI Standard 520.

## Section 3. Definitions

All terms in this document shall follow the standard industry definitions in the current edition of ASHRAE *Terminology of Heating, Ventilation, Air-Conditioning and Refrigeration* unless otherwise defined in this section.

**3.1 Commercial and Industrial Unitary Air-Conditioning Condensing Unit.** A factory-made assembly of refrigerating components designed to compress and liquefy a specific refrigerant. It consists of one or more refrigerant compressors, refrigerant condensers (air-cooled, evaporative – cooled, and/or water-cooled), condenser fans and motors (where used) and factory-supplied accessories.

**3.2 Cooling Capacity.** Cooling capacity is the capacity in Btu/h [W] obtained at specific conditions. It is equal to the increase in total enthalpy between the liquid refrigerant entering the expansion valve and superheated return gas multiplied by the mass flow rate of the refrigerant.

**3.3 Dew Point.** Refrigerant vapor saturation temperature at a specified pressure.

**3.4 Energy Efficiency Ratio (EER).** A ratio of the Cooling Capacity in Btu/h to the power input values in watts at any given set of Rating Conditions expressed in Btu/(W·h).

**3.5 Integrated Part-Load Value (IPLV).** A single number part-load efficiency figure of merit calculated per the method described in this standard and expressed in Btu/(W·h).

**3.6 Published Rating.** A statement of the assigned values of those performance characteristics, under stated Rating Conditions, by which a unit may be chosen to fit its application. These values apply to all units of like nominal size and type (identification) produced by the same manufacturer. As used herein, the term Published Rating includes the rating of all performance characteristics shown on the unit or published in specifications, advertising, or other literature controlled by the manufacturer, at stated Rating Conditions.

**3.6.1 Application Rating.** A rating based on tests performed at Application Rating conditions (other than Standard Rating Conditions).

**3.6.2 Standard Rating.** A rating based on tests performed at Standard Rating Conditions.

**3.7 Rating Conditions.** Any set of operating conditions under which a single level of performance results and which causes only that level of performance to occur.

**3.7.1 Standard Rating Conditions.** Rating Conditions used as the basis of comparison for performance characteristics.

**3.8 "Shall" or "Should."** "Shall" or "should" shall be interpreted as follows:

**3.8.1 Shall.** Where "shall" or "shall not" is used for a provision specified, that provision is mandatory if compliance with the standard is claimed.

**3.8.2 Should.** "Should" is used to indicate provisions which are not mandatory but which are desirable as good practice.

**3.9 Single Number Rating.** The Cooling Capacity and EER determined by averaging the results of the tests at Rating Conditions No. 1 and No. 2 for air-cooled and evaporative-cooled condensing units and at Rating