

## ANSI/AHRI Standard 910 (I-P)

# 2014 Standard for Performance Rating of Indoor Pool Dehumidifiers



Approved by ANSI on September 27, 2016



we make life better™

2111 Wilson Boulevard, Suite 500  
Arlington, VA 22201, USA  
[www.ahrinet.org](http://www.ahrinet.org)  
PH 703.524.8800  
FX 703.562.1942

## **IMPORTANT**

### ***SAFETY DISCLAIMER***

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

Note:

This standard supersedes AHRI Standard 910-2011.

For SI ratings, see ANSI/AHRI Standard 911 (SI)-2014.

## **AHRI CERTIFICATION PROGRAM PROVISIONS**

### **Scope of the Certification Program**

This program applies to all production line OEM and PBM production models of residential, commercial, and industrial Indoor Pool Dehumidifiers and rated below a Moisture Removal Capacity (MRC) of 55.0 lb/h at Standard Rating Conditions per Table 2 of ANSI/AHRI Standard 910 (I-P).

### **Certified Ratings**

The following Certification Program ratings are verified by test at the Standard Rating Conditions:

- a. Moisture Removal Capacity, lb of moisture/h
- b. Moisture Removal Efficiency, lb of moisture/kWh
- c. Total Cooling Capacity, Btu/h
- d. Net Sensible Cooling Capacity (if applicable), Btu/h
- e. Total Heat of Rejection to Indoor Air, Btu/h
- f. Total Heat of Rejection to Outdoor Air (if applicable), Btu/h
- g. Total Heat of Rejection to Liquid (if applicable), Btu/h
- h. Total Input Power, Btu/h

## TABLE OF CONTENTS

| SECTION                                                         | PAGE |
|-----------------------------------------------------------------|------|
| Section 1. Purpose .....                                        | 1    |
| Section 2. Scope.....                                           | 1    |
| Section 3. Definitions .....                                    | 1    |
| Section 4. Classification .....                                 | 2    |
| Section 5. Test Requirements .....                              | 3    |
| Section 6. Rating Requirements.....                             | 4    |
| Section 7. Minimum Data Requirements for Published Ratings..... | 7    |
| Section 8. Operating Requirements .....                         | 7    |
| Section 9. Marking and Nameplate Data .....                     | 8    |
| Section 10. Conformance Conditions .....                        | 8    |

## TABLES

|                                                                                |   |
|--------------------------------------------------------------------------------|---|
| Table 1. Classification of Indoor Pool Dehumidifiers .....                     | 2 |
| Table 2. Conditions for Standard Rating Tests and Operating Requirements ..... | 5 |
| Table 3. Minimum External Resistance .....                                     | 6 |
| Table 4. Basic Pumping Penalty ( $PP_B$ ) vs. Liquid Flow Rate (WF) .....      | 6 |

## APPENDICES

|                                           |   |
|-------------------------------------------|---|
| Appendix A. References – Normative.....   | 9 |
| Appendix B. References - Informative..... | 9 |

# PERFORMANCE RATING OF INDOOR POOL DEHUMIDIFIERS

## Section 1. Purpose

**1.1** *Purpose.* The purpose of this standard is to establish for Indoor Pool Dehumidifiers: definitions; classifications; test requirements; rating requirements; minimum data requirements for Published Ratings; operating requirements; marking and nameplate data; and conformance conditions.

**1.1.1** *Intent.* This standard is intended for the guidance of the industry, including manufacturers, engineers, installers, contractors and users.

**1.1.2** *Review and Amendment.* This standard is subject to review and amendment as technology advances.

## Section 2. Scope

**2.1** *Scope.* This standard applies to factory-made residential, commercial and industrial Indoor Pool Dehumidifiers, as defined in Section 3.

**2.1.1** *Energy Source.* This standard applies to electrically operated, vapor-compression refrigeration systems.

**2.2** *Exclusions.* This standard does not apply to the rating and testing of individual assemblies for separate use.

## Section 3. Definitions

All terms in this document will follow the standard industry definitions in the *ASHRAE Terminology* website (<https://www.ashrae.org/resources--publications/free-resources/ashrae-terminology>) unless otherwise defined in this section.

**3.1** *Economizer.* Factory-made assembly installed in an electrically operated, vapor compression refrigeration system that takes advantage of favorable weather conditions to reduce cooling and thereby improve a building's energy performance by introducing up to 100% outside air into a building.

**3.2** *Indoor Pool Dehumidifier.* A type of air-cooled or water-cooled electrically operated, vapor compression refrigeration system; factory assembled as a single package or split system, which includes an indoor cooling/dehumidifying coil, an air reheat coil, compressor(s) and an air moving device. It may also include a Refrigerant Heat Recovery Unit, an auxiliary refrigerant condenser, Economizer, and an air-to-air heat recovery device. It shall provide the function of dehumidifying, air circulation, air reheating and may include the function of air-cooling, air-cleaning, pool water heating and air-to-air heat recovery.

**3.3** *Moisture Removal Capacity (MRC).* The amount of condensate produced by the unit which includes the effects of reheat coils, circulating fans and other components in the air stream; excluding supplementary heating, cooling or outdoor air; and expressed in lb of moisture/h.

**3.4** *Moisture Removal Efficiency (MRE).* A ratio of the MRC in lb of moisture/h to the power input values in kW at any given set of Rating Conditions expressed in lb of moisture/kWh.

**3.5** *Published Rating.* A statement of the assigned values of those performance characteristics, under stated Rating Conditions, by which a unit may be chosen to fit its application. These values apply to all units of like nominal size and type (identification) produced by the same manufacturer. As used herein, the term Published Rating includes the rating of all performance characteristics shown on the unit or published in specifications, advertising or other literature controlled by the manufacturer, at stated Rating Conditions.

**3.5.1** *Application Rating.* A rating based on tests performed at application Rating Conditions (other than Standard Rating Conditions).