

ANSI/ASA S2.75-2017/Part 2

**Reaffirmed by ANSI
June 19, 2020**

AMERICAN NATIONAL STANDARD

Shaft Alignment Methodology, Part 2: Vocabulary

ANSI/ASA S2.75-2017/Part 2

Accredited Standards Committee S2, Mechanical Vibration and Shock

Standards Secretariat
Acoustical Society of America
300 Walt Whitman Road, Suite 300
Melville, NY 11747

The American National Standards Institute, Inc. (ANSI) is the national coordinator of voluntary standards development and the clearinghouse in the U.S.A. for information on national and international standards.

The Acoustical Society of America (ASA) is an organization of scientists and engineers formed in 1929 to increase and diffuse the knowledge of acoustics and to promote its practical applications.



ANSI/ASA S2.75-2017/Part 2

AMERICAN NATIONAL STANDARD
**Shaft Alignment Methodology,
Part 2: Vocabulary**

Secretariat:

Acoustical Society of America

Approved on June 6, 2017, by:

American National Standards Institute, Inc.

Abstract

The purpose of this standard is to define terminology unique to the alignment of machinery that has been in common use among engineers and technicians working in the field. Words and phrases are presented in alphabetical order. This vocabulary is intended to be used with the ANSI/ASA S2.75 series *Shaft Alignment Methodology*.

AMERICAN NATIONAL STANDARDS ON ACOUSTICS

The Acoustical Society of America (ASA) provides the Secretariat for Accredited Standards Committees S1 on Acoustics, S2 on Mechanical Vibration and Shock, S3 on Bioacoustics, S3/SC 1 on Animal Bioacoustics, and S12 on Noise. These committees have wide representation from the technical community (manufacturers, consumers, trade associations, organizations with a general interest, and government representatives). The standards are published by the Acoustical Society of America through the American Institute of Physics as American National Standards after approval by their respective Standards Committees and the American National Standards Institute (ANSI).


These standards are developed and published as a public service to provide standards useful to the public, industry, and consumers, and to Federal, State, and local governments.

Each of the accredited Standards Committees (operating in accordance with procedures approved by ANSI) is responsible for developing, voting upon, and maintaining or revising its own Standards. The ASA Standards Secretariat administers Committee organization and activity and provides liaison between the Accredited Standards Committees and ANSI. After the Standards have been produced and adopted by the Accredited Standards Committees, and approved as American National Standards by ANSI, the ASA Standards Secretariat arranges for their publication and distribution.

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered and that a concerted effort be made towards their resolution.

The use of an American National Standard is completely voluntary. Their existence does not in any respect preclude anyone, whether he or she has approved the Standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the Standards.

NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this Standard.



Acoustical Society of America
Standards Secretariat
1305 Walt Whitman Road, Suite 300
Melville, New York 11747
Telephone: 1 (631) 390-0215
Fax: 1 (631) 923-2875
E-mail: asastds@acousticalsociety.org

© 2017 by Acoustical Society of America. This standard may not be reproduced in whole or in part in any form for sale, promotion, or any commercial purpose, or any purpose not falling within the provisions of the U.S. Copyright Act of 1976, without prior written permission of the publisher. For permission, address a request to the Standards Secretariat of the Acoustical Society of America.

Contents

1	Scope	1
2	Terms and definitions.....	1
	Bibliography	16

Foreword

[This Foreword is for information only, and is not a part of ANSI/ASA S2.75-2017/Part 2 American National Standard Shaft Alignment Methodology, Part 2: Vocabulary. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the standard.]

This standard comprises a part of a group of definitions, standards, and specifications for use in mechanical vibration and shock. It was developed and approved by Accredited Standards Committee S2 Mechanical Vibration and Shock, under its approved operating procedures. Those procedures have been accredited by the American National Standards Institute (ANSI). The Scope of Accredited Standards Committee S2 is as follows:

Standards, specification, methods of measurement and test, and terminology in the field of mechanical vibration and shock, and condition monitoring and diagnostics of machines, including the effects of exposure to mechanical vibration and shock on humans, including those aspects which pertain to biological safety, tolerance and comfort.

This standard is not comparable to any existing ISO Standard.

This proposed standard was compiled to provide a common understanding of words and phrases used in machinery alignment. This standard is intended to be used by persons engaged in the installation, commissioning, and repair of machines. This is a new standard that does not duplicate definitions provided in other vocabulary standards.

At the time this Standard was submitted to Accredited Standards Committee S2, Mechanical Vibration and Shock for approval, the membership was as follows:

C.F. Gaumont, *Chair*
J.T. Nelson, *Vice-Chair*

N.B. Stremmel, *Secretary*

Acoustical Society of America	C.F. Gaumont
.....	J.T. Nelson
American Industrial Hygiene Association	D. Driscoll
Association of American Railroads	J. Moller
.....	N. Cooperrider (Alt.)
Bose Corporation	J. Parison
Calnetix	L.A. Hawkins
.....	P. McMullen (Alt.)
Caterpillar, Inc.	D.G. Roley
Duke University Dept. of Biomedical Engineering	C.R. Bass
Eckardt Johanning, MD, P.C.	E. Johanning
Emerson Electric – Copeland Corporation	A.T. Herfat
Engineering Dynamics, Inc.	S. McGregor
FLIR Systems	G.L. Orlove

Fokus Reliability	Ó.G. Hakansson
G.E. Energy	R. Bankert
John Deere	L. DeVries
Logan Mullinix Consulting	L. Mullinix
Mechanical Solutions, Inc.	W.D. Marscher
.....	M. Onari (Alt.)
National Institute for Occupational Safety and Health (NIOSH)	R. Dong
.....	T.W. McDowell (Alt.)
National Institute of Standards & Technology	M. Gaitan
PCB Group	R.D. Sill
.....	C.M. Walber (Alt.)
Power Tool Institute, Inc.	W.D. Spencer
.....	M. Hickok (Alt.)
Schenck Trebel Corp.	M. Schonfeld
.....	R. Kewitsch (Alt.)
Shock and Vibration Exchange	V.I. Bateman
.....	J.E. Howell (Alt.)
Siemens Power Generation, Inc.	M. L'vov
UE Systems, Inc.	M. Goodman
U.S. Air Force	S.D. Smith
U.S. Army Aeromedical Research Laboratory	R. Kinsler
U.S. Army Public Health Command	S. Chervak
.....	J. Clasing (Alt.)
U.S. Naval Surface Warfare Center – Carderock	K. Wu
.....	D. Gilmer (Alt.)
U.S. Naval Surface Warfare Center – Panama City	B.L. Price
University of Iowa	D. Wilder
.....	S. Rahmatalla (Alt.)
University of Washington, Dept. of Environmental and Occupational Health Sciences	P.W. Johnson
Vibration Institute	R.L. Eshleman
.....	B. Biby (Alt.)
Waukesha Magnetic Bearings	K. Bornstein
.....	R. Shultz (Alt.)

Individual Experts of Accredited Standards Committee S2, Mechanical Vibration and Shock, were:

A.J. Brammer
R.J. Peppin
D.D. Reynolds
D.E. Wasserman

Working Group S2/WG 15, Shaft Alignment Methodology, which assisted Accredited Standards Committee S2, Mechanical Vibration and Shock, in the development of this standard, had the following membership.

B. Biby, Chair
G. Vogel, Vice-Chair

E.M. Arteaga	J. Hanks	C. Martinez
T. Barham	C. Hildebrand	M. McMahan
C. Barnett	R. Jagessar	A. Miller
K. Bond	M. Keohane	M. Olszewski
T. Broussard	J. Lambert	G. Patrick
G. Buscarello	A. Locke	J. Piotrowski
C. Callaway	A. Luedeking	A. Plymon
P. Casanova	T.R. Lyke	B. Pryor
D. Corelli	K. Mack	P. Schmidt
A. DeVaux	A. Mackley	C. Scott
R. Enos	J. Madison	L. Shull, IV
R.L. Eshleman	H. Maple	M. Williams
B. Evans	J. Marconi	M. Wortman
W.C. Foiles	D. Markeson	

Suggestions for improvements to this standard will be welcomed. They should be sent to Accredited Standards Committee S2, Mechanical Vibration and Shock, in care of the Standards Secretariat of the Acoustical Society of America, 1305 Walt Whitman Road, Suite 300, Melville, New York 11747. Telephone: 631-390-0215; FAX: 631-923-2875; E-mail: asastds@acousticalsociety.org.

American National Standard

Shaft Alignment Methodology, Part 2: Vocabulary

1 Scope

The words and phrases provided here are descriptive of the instruments and methods in common use for shaft alignment of industrial and utility machines. The machines have rotating shafts at speeds of several hundred revolutions per minute and higher. The machines are typically stationary, being attached to a fixed location on a structure, but could also be on a vehicle, such as a watercraft.

The definitions are intended to be used in other standards for shaft alignment and general machinery servicing.

2 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

2.1

air gap

the internal open space in an electrical machine between the stationary and movable components that transmits energy via the magnetic field

NOTE In a motor or generator, this is the radial space between the rotor and stator.

2.2

alignment, machinery

the relative orientation of components which results in the least amount of vibration or wear

NOTE See "shaft alignment."

2.3

alignment tolerance

the maximum allowable deviation, plus or minus, from desired values

NOTE In machinery, perfect alignment is not achievable. This tolerance provides a range that is economically achievable within a reasonable time and will not cause premature wear or excessive vibration.

2.4

anchor bolts

fasteners embedded in concrete used to secure a machine to a foundation

NOTE 1 Also known as a "J-bolt."

NOTE 2 The fasteners could be male or female threaded.

NOTE 3 See "base" and "foundation."