

# Design of Steel Transmission Pole Structures

This document uses both the  
International System of Units (SI)  
and customary units

**American Society of Civil Engineers**

# **Design of Steel Transmission Pole Structures**

**ASCE/SEI 48-11**

This document uses both the International System of Units (SI)  
and customary units.



**STRUCTURAL  
ENGINEERING  
INSTITUTE**

**Published by the American Society of Civil Engineers**

Design of steel transmission pole structures: standard 48-11.

p. cm. – (ASCE standard)

“ASCE/SEI 48-11.”

“This document uses both the International System of Units (SI) and customary units.”

Includes bibliographical references and index.

ISBN 978-0-7844-1181-0 (alk. paper)

1. Electric lines—Poles and towers—Design and construction. I. American Society of Civil Engineers.

TK3242.D475 2011

621.319'22—dc23

2011031788

Published by American Society of Civil Engineers

1801 Alexander Bell Drive

Reston, Virginia 20191

[www.pubs.asce.org](http://www.pubs.asce.org)

This standard was developed by a consensus standards development process which has been accredited by the American National Standards Institute (ANSI). Accreditation by ANSI, a voluntary accreditation body representing public and private sector standards development organizations in the U.S. and abroad, signifies that the standards development process used by ASCE has met the ANSI requirements for openness, balance, consensus, and due process.

While ASCE's process is designed to promote standards that reflect a fair and reasoned consensus among all interested participants, while preserving the public health, safety, and welfare that is paramount to its mission, it has not made an independent assessment of and does not warrant the accuracy, completeness, suitability, or utility of any information, apparatus, product, or process discussed herein. ASCE does not intend, nor should anyone interpret, ASCE's standards to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this standard.

ASCE has no authority to enforce compliance with its standards and does not undertake to certify products for compliance or to render any professional services to any person or entity.

ASCE disclaims any and all liability for any personal injury, property damage, financial loss or other damages of any nature whatsoever, including without limitation any direct, indirect, special, exemplary, or consequential damages, resulting from any person's use of, or reliance on, this standard. Any individual who relies on this standard assumes full responsibility for such use.

ASCE and American Society of Civil Engineers—Registered in U.S. Patent and Trademark Office.

*Photocopies and reprints.* You can obtain instant permission to photocopy ASCE publications by using ASCE's online permission service (<http://pubs.asce.org/permissions/requests/>). Requests for 100 copies or more should be submitted to the Reprints Department, Publications Division, ASCE (address above); e-mail: [permissions@asce.org](mailto:permissions@asce.org). A reprint order form can be found at <http://pubs.asce.org/support/reprints/>.

Copyright © 2012 by the American Society of Civil Engineers.

All Rights Reserved.

ISBN 978-0-7844-1181-0

Manufactured in the United States of America.

18 17 16 15 14 13 12 11      1 2 3 4 5

In 2006, the Board of Direction approved the revision to the ASCE Rules for Standards Committees to govern the writing and maintenance of standards developed by the Society. All such standards are developed by a consensus standards process managed by the Society's Codes and Standards Committee (CSC). The consensus process includes balloting by a balanced standards committee made up of Society members and nonmembers, balloting by the membership of the Society as a whole, and balloting by the public. All standards are updated or reaffirmed by the same process at intervals not exceeding five years.

The following standards have been issued:

- ANSI/ASCE 1-82 N-725 Guideline for Design and Analysis of Nuclear Safety Related Earth Structures
- ASCE/EWRI 2-06 Measurement of Oxygen Transfer in Clean Water
- ANSI/ASCE 3-91 Standard for the Structural Design of Composite Slabs and ANSI/ASCE 9-91 Standard Practice for the Construction and Inspection of Composite Slabs
- ASCE 4-98 Seismic Analysis of Safety-Related Nuclear Structures
- Building Code Requirements for Masonry Structures (ACI 530-02/ASCE 5-02/TMS 402-02) and Specifications for Masonry Structures (ACI 530.1-02/ASCE 6-02/TMS 602-02)
- ASCE/SEI 7-10 Minimum Design Loads for Buildings and Other Structures
- SEI/ASCE 8-02 Standard Specification for the Design of Cold-Formed Stainless Steel Structural Members
- ANSI/ASCE 9-91 listed with ASCE 3-91
- ASCE 10-97 Design of Latticed Steel Transmission Structures
- SEI/ASCE 11-99 Guideline for Structural Condition Assessment of Existing Buildings
- ASCE/EWRI 12-05 Guideline for the Design of Urban Subsurface Drainage
- ASCE/EWRI 13-05 Standard Guidelines for Installation of Urban Subsurface Drainage
- ASCE/EWRI 14-05 Standard Guidelines for Operation and Maintenance of Urban Subsurface Drainage
- ASCE 15-98 Standard Practice for Direct Design of Buried Precast Concrete Pipe Using Standard Installations (SIDD)
- ASCE 16-95 Standard for Load Resistance Factor Design (LRFD) of Engineered Wood Construction
- ASCE 17-96 Air-Supported Structures
- ASCE 18-96 Standard Guidelines for In-Process Oxygen Transfer Testing
- ASCE/SEI 19-10 Structural Applications of Steel Cables for Buildings
- ASCE 20-96 Standard Guidelines for the Design and Installation of Pile Foundations
- ANSI/ASCE/T&DI 21-05 Automated People Mover Standards—Part 1
- ANSI/ASCE/T&DI 21.2-08 Automated People Mover Standards—Part 2
- ANSI/ASCE/T&DI 21.3-08 Automated People Mover Standards—Part 3
- ANSI/ASCE/T&DI 21.4-08 Automated People Mover Standards—Part 4
- SEI/ASCE 23-97 Specification for Structural Steel Beams with Web Openings
- ASCE/SEI 24-05 Flood Resistant Design and Construction
- ASCE/SEI 25-06 Earthquake-Actuated Automatic Gas Shutoff Devices
- ASCE 26-97 Standard Practice for Design of Buried Precast Concrete Box Sections
- ASCE 27-00 Standard Practice for Direct Design of Precast Concrete Pipe for Jacking in Trenchless Construction
- ASCE 28-00 Standard Practice for Direct Design of Precast Concrete Box Sections for Jacking in Trenchless Construction
- ASCE/SEI/SFPE 29-05 Standard Calculation Methods for Structural Fire Protection
- SEI/ASCE 30-00 Guideline for Condition Assessment of the Building Envelope
- SEI/ASCE 31-03 Seismic Evaluation of Existing Buildings
- SEI/ASCE 32-01 Design and Construction of Frost-Protected Shallow Foundations
- EWRI/ASCE 33-09 Comprehensive Transboundary International Water Quality Management Agreement
- EWRI/ASCE 34-01 Standard Guidelines for Artificial Recharge of Ground Water
- EWRI/ASCE 35-01 Guidelines for Quality Assurance of Installed Fine-Pore Aeration Equipment
- CI/ASCE 36-01 Standard Construction Guidelines for Microtunneling
- SEI/ASCE 37-02 Design Loads on Structures during Construction
- CI/ASCE 38-02 Standard Guideline for the Collection and Depiction of Existing Subsurface Utility Data
- EWRI/ASCE 39-03 Standard Practice for the Design and Operation of Hail Suppression Projects
- ASCE/EWRI 40-03 Regulated Riparian Model Water Code
- ASCE/SEI 41-06 Seismic Rehabilitation of Existing Buildings
- ASCE/EWRI 42-04 Standard Practice for the Design and Operation of Precipitation Enhancement Projects
- ASCE/SEI 43-05 Seismic Design Criteria for Structures, Systems, and Components in Nuclear Facilities
- ASCE/EWRI 44-05 Standard Practice for the Design and Operation of Supercooled Fog Dispersal Projects
- ASCE/EWRI 45-05 Standard Guidelines for the Design of Urban Stormwater Systems
- ASCE/EWRI 46-05 Standard Guidelines for the Installation of Urban Stormwater Systems
- ASCE/EWRI 47-05 Standard Guidelines for the Operation and Maintenance of Urban Stormwater Systems
- ASCE/SEI 48-11 Design of Steel Transmission Pole Structures
- ASCE/EWRI 50-08 Standard Guideline for Fitting Saturated Hydraulic Conductivity Using Probability Density Functions
- ASCE/EWRI 51-08 Standard Guideline for Calculating the Effective Saturated Hydraulic Conductivity
- ASCE/SEI 52-10 Design of Fiberglass-Reinforced Plastic (FRP) Stacks

This is a preview of "ASCE/SEI 48-11". [Click here to purchase the full version from the ANSI store.](#)

ASCE/EWRI 34-10 Standard Guide for the Geostatistical Estimation and Block-Averaging of Homogeneous and Isotropic Saturated Hydraulic Conductivity  
ASCE/SEI 55-10 Tensile Membrane Structures  
ANSI/ASCE/EWRI 56-10 Guidelines for the Physical Security of Water Utilities

or wastewater/Stormwater Utilities  
ASCE/T&DI/ICPI 58-10 Structural Design of Interlocking Concrete Pavement for Municipal Streets and Roadways

This Standard includes commentary and appendices that are furnished as supplemental information. The commentary and appendices are not mandatory.

Before the initial publication of this Standard in 2005, most electric transmission design professionals used ASCE's Engineering Manual and Report on Engineering Practice No. 72, titled Design of Steel Transmission Pole Structures, as their primary reference for providing a uniform basis for designing, fabricating, testing, assembling, and erecting steel transmission pole structures. The second edition of Manual 72 served as the primary resource document for the development of the original version of this Standard, ASCE 48-05. This book is the first

revision to this Standard and is intended to replace ASCE 48-05 in its entirety.

This Standard has been prepared in accordance with recognized engineering principles and should not be used without the user's competent knowledge for a given application. The publication of this Standard by ASCE is not intended as a warrant that the information contained herein is suitable for any general or specific use, and the Society takes no position with regard to the validity of patent rights. Users are advised that the determination of patent rights or risk of infringement is entirely their own responsibility.

*This page intentionally left blank*

This Standard was prepared through the consensus standards process by balloting in compliance with procedures of the ASCE Code and Standards Committee. Those individuals who serve on the Design of Steel Transmission Pole Structures Standards Committee are

Richard F. Aichinger, P.E.  
J. Kelly Bledsoe, P.E.  
Gary E. Bowles, P.E.  
David G. Brinker, P.E., S.E.  
Michael D. Brown, P.E.  
Jerry G. Crawford, P.E.  
Dana R. Crissey, P.E.  
Martin L. de la Rosa, P.E.  
Joel G. Dembowski  
David Endorf, P.E.  
Michael R. Gall, P.E.  
Lewis H. Grant, P.E.  
Nicholas Grossenbach, P.E.  
Bobby G. Hagler, P.E.  
James A Hamraie, P.E.  
Henry W. Ho, P.E.  
Magdi F. Ishac, Ph.D., P.Eng.  
Leon Kempner, Jr., Ph.D., P.E.  
Massoud Khavari, P.E.  
Fred H. Kulhawy, Ph.D., P.E., G.E.

Brian Lacoursiere, P.Eng.  
Paul M. Legrand II, P.E.  
Otto J. Lynch, P.E.  
William L. Magee, P.E., Vice-Chair  
Terry C. McAnnally, P.E.  
William B. Mills, P.E.  
Michael R. Morel, P.E.  
George E. Murray Jr., P.E.  
David Nahlen, P.E.  
Robert E. Nickerson, P.E.  
Garold D. Oberlender, Ph.D., P.E.  
Robert L. Patterson, P.E.  
Ronald E. Randle, P.E., Chair  
Pedram Sadr, P.E.  
Majed J. Saleh  
Randall L. Samson, P.E.  
Karnik M. Seferian, P.E.  
Kenneth L. Sharpless, P.E.  
Marlon W. Vogt, P.E., Secretary  
Jim Walker, P.E.



*This page intentionally left blank*

The Design of Steel Transmission Pole Structures Standard applies to cold-formed single- and multiple-pole tubular steel structures that support overhead electrical transmission lines. Design parameters are applicable to guyed and self-supporting structures using a variety of foundation types, including concrete caissons, steel piling, and direct embedment. The Standard outlines key criteria that must be considered in the structural design, detailing, fabrication, testing, assembly, and erection of these structures. This Standard is a revision of ASCE/SEI 48-05 and provides some revisions to formulas based on other current industry standards. In addition, the Standard includes a detailed commentary and appendices with explanatory and supplementary information designed to provide the user with clarification and reference information.

The information presented has been prepared in accordance with established engineering principles using state-of-the-art information and is intended for general information. Whereas every effort has been made to ensure its accuracy, the information should not be relied upon for any specific application without the consultation of a competent engineer to determine its suitability. Nothing in the Standard shall be construed to alter or subvert the requirements of any existing code or authority having jurisdiction over the facility. Furthermore, alternate methods and materials to those herein indicated may be used, provided that the engineer can demonstrate their suitability to all agencies and authorities.

*This page intentionally left blank*

	Page
1 Scope . . . . .	1
2 Applicable Documents . . . . .	3
3 Definitions . . . . .	5
4 Loading, Geometry, and Analysis . . . . .	7
4.1 Introduction . . . . .	7
4.2 Loading . . . . .	7
4.2.1 Factored Design Loads . . . . .	7
4.2.2 Loading Considerations . . . . .	7
4.2.3 Load Expression . . . . .	7
4.3 Geometric Configurations . . . . .	7
4.3.1 Configuration Considerations . . . . .	7
4.3.2 Structure Types . . . . .	7
4.4 Methods of Analysis . . . . .	7
4.4.1 Structural Analysis Methods . . . . .	7
4.4.2 Analysis of Connections . . . . .	7
4.5 Additional Considerations . . . . .	7
4.5.1 Structural Support . . . . .	7
4.5.2 Design Restrictions . . . . .	7
4.5.3 Climbing and Maintenance Provisions . . . . .	7
4.5.4 Pre-engineered Steel Poles (“Wood Pole Equivalents”) . . . . .	7
5 Design of Members . . . . .	9
5.1 Introduction . . . . .	9
5.2 Members . . . . .	9
5.2.1 Materials . . . . .	9
5.2.1.1 Specifications . . . . .	9
5.2.1.2 Material Properties . . . . .	9
5.2.1.3 Energy-Impact Properties . . . . .	9
5.2.2 Tension . . . . .	9
5.2.3 Compression . . . . .	9
5.2.3.1 Truss Members . . . . .	9
5.2.3.2 Beam Members . . . . .	10
5.2.4 Shear . . . . .	10
5.2.5 Bending . . . . .	11
5.2.6 Combined Stresses . . . . .	11
5.3 Guys . . . . .	11
5.3.1 Material Properties . . . . .	11
5.3.2 Tension . . . . .	11
5.4 Test Verification . . . . .	11
6 Design of Connections . . . . .	13
6.1 Introduction . . . . .	13
6.2 Bolted and Pinned Connections . . . . .	13
6.2.1 Materials . . . . .	13
6.2.2 Shear Stress in Bearing Connections . . . . .	13
6.2.3 Bolts Subject to Tension . . . . .	13
6.2.4 Bolts Subject to Combined Shear and Tension . . . . .	13
6.2.5 Bearing Stress in Bolted Connections . . . . .	13
6.2.6 Minimum Edge Distances and Bolt Spacing for Bolted Connections . . . . .	14
6.2.7 Bearing Stress in Pinned Connections . . . . .	14

	6.2.9	Connection Elements and Members . . . . .	14
6.3		Welded Connections . . . . .	14
	6.3.1	Material Properties . . . . .	14
	6.3.2	Effective Area . . . . .	14
	6.3.3	Design Stresses . . . . .	15
	6.3.3.1	Through-Thickness Stress . . . . .	15
	6.3.4	Circumferential Welded Splices. . . . .	15
	6.3.5	Flange and Base Plate to Pole Shaft Welds. . . . .	15
	6.3.6	T-Joints . . . . .	15
6.4		Field Connections of Members . . . . .	15
	6.4.1	Slip Joints . . . . .	15
	6.4.2	Base and Flange Plate Connections . . . . .	16
6.5		Test Verification . . . . .	16
7		Detailing and Fabrication . . . . .	17
	7.1	Detailing . . . . .	17
	7.1.1	Drawings . . . . .	17
	7.1.2	Drawing Review. . . . .	17
	7.1.3	Erection Drawings. . . . .	17
	7.1.4	Shop Detail Drawings. . . . .	17
	7.1.4.1	Material. . . . .	17
	7.1.4.2	Dimensions and Tolerances . . . . .	17
	7.1.4.3	Welding. . . . .	17
	7.1.4.4	Corrosion and Finish Considerations . . . . .	17
	7.1.4.5	Other Requirements . . . . .	17
	7.2	Fabrication . . . . .	17
	7.2.1	Material . . . . .	17
	7.2.2	Material Preparation. . . . .	17
	7.2.2.1	Cutting . . . . .	17
	7.2.2.2	Forming. . . . .	17
	7.2.2.3	Holes . . . . .	17
	7.2.2.4	Identification . . . . .	17
	7.2.3	Welding . . . . .	17
8		Testing . . . . .	19
	8.1	Introduction . . . . .	19
	8.2	Foundations . . . . .	19
	8.3	Material . . . . .	19
	8.4	Fabrication . . . . .	19
	8.5	Strain Measurements . . . . .	19
	8.6	Assembly and Erection . . . . .	19
	8.7	Test Loads . . . . .	19
	8.8	Load Application . . . . .	19
	8.9	Loading Procedure. . . . .	19
	8.10	Load Measurement . . . . .	19
	8.11	Deflections . . . . .	19
	8.12	Failures. . . . .	19
	8.13	Post-Test Inspection . . . . .	19
	8.14	Disposition of Prototype. . . . .	19
	8.15	Report . . . . .	19
9		Structural Members and Connections Used in Foundations . . . . .	21
	9.1	Introduction . . . . .	21
	9.2	General Considerations . . . . .	21
	9.3	Anchor Bolts. . . . .	21
	9.3.1	Bolts Subject to Tension . . . . .	21
	9.3.2	Shear Stress . . . . .	21
	9.3.3	Combined Shear and Tension. . . . .	21
	9.3.4	Development Length . . . . .	21
	9.4	Direct-Embedded Poles . . . . .	21

9.0	Test Verification . . . . .	22
10	Quality Assurance/Quality Control . . . . .	23
10.1	Introduction . . . . .	23
10.2	Quality Assurance . . . . .	23
10.2.1	Design and Drawings . . . . .	23
10.2.2	Materials . . . . .	23
10.2.3	Welding . . . . .	23
10.2.4	Nondestructive Testing . . . . .	23
10.2.5	Tolerances . . . . .	23
10.2.6	Surface Coatings . . . . .	23
10.2.7	Shipping . . . . .	23
10.3	Quality Control . . . . .	23
10.3.1	Materials . . . . .	23
10.3.2	Visual Inspection . . . . .	23
10.3.3	Dimensional Inspection . . . . .	23
10.3.4	Surface Coating Inspection . . . . .	23
10.3.5	Weld Inspection . . . . .	23
10.3.6	Shipment and Storage . . . . .	24
11	Assembly and Erection . . . . .	25
11.1	Introduction . . . . .	25
11.2	Handling . . . . .	25
11.3	Single-Pole Structures . . . . .	25
11.3.1	Slip Joints . . . . .	25
11.3.2	Bolted Flange Joints . . . . .	25
11.3.3	Attachments to Pole Sections . . . . .	25
11.3.4	Erection of Assembled Structures . . . . .	25
11.4	Frame-Type Structures . . . . .	25
11.4.1	Slip Joints in Frames . . . . .	25
11.4.2	Erection . . . . .	25
11.4.3	Bolted Frame Connections . . . . .	25
11.5	Installation on Foundation . . . . .	25
11.5.1	Anchor Bolt and Base Plate Installation . . . . .	25
11.5.2	Direct-Embedded Poles . . . . .	25
11.6	Guying . . . . .	25
11.6.1	Guy Anchor Location . . . . .	25
11.6.2	Guy Installation . . . . .	25
11.7	Posterection Procedures . . . . .	25
11.7.1	Inspection . . . . .	25
11.7.2	Grounding . . . . .	25
11.7.3	Coating Repair . . . . .	25
11.7.4	Unloaded Arms . . . . .	26
11.7.5	Hardware Installation . . . . .	26
	COMMENTARY . . . . .	27
C4	Loading, Geometry, and Analysis . . . . .	29
C4.2	Loading . . . . .	29
C4.2.1	Factored Design Loads . . . . .	29
C4.2.2	Loading Considerations . . . . .	29
C4.2.3	Load Expression . . . . .	29
C4.3	Geometric Configurations . . . . .	30
C4.3.1	Configuration Considerations . . . . .	30
C4.3.2	Structure Types . . . . .	30
C4.4	Methods of Analysis . . . . .	30
C4.4.1	Structural Analysis Methods . . . . .	30
C4.5	Additional Considerations . . . . .	31
C4.5.1	Structural Support . . . . .	31

	C4.5.3	Climbing and Maintenance Provisions . . . . .	31
	C4.5.4	Pre-engineered Steel Poles (“Wood Pole Equivalents”) . . . . .	31
C5	Design of Members . . . . .		33
	C5.1	Introduction . . . . .	33
	C5.2	Members . . . . .	33
		C5.2.1 Materials . . . . .	33
		C5.2.1.1 Specifications . . . . .	33
		C5.2.1.2 Material Properties . . . . .	33
		C5.2.1.3 Energy-Impact Properties . . . . .	33
	C5.2.2	Tension . . . . .	33
	C5.2.3	Compression . . . . .	33
		C5.2.3.1 Truss Members . . . . .	33
		C5.2.3.2 Beam Members . . . . .	34
	C5.2.4	Shear . . . . .	36
	C5.2.5	Bending . . . . .	36
	C5.2.6	Combined Stresses . . . . .	36
	C5.3	Guys . . . . .	36
		C5.3.1 Material Properties . . . . .	36
		C5.3.2 Tension . . . . .	36
		References . . . . .	36
C6	Design of Connections . . . . .		39
	C6.1	Introduction . . . . .	39
	C6.2	Bolted and Pinned Connections . . . . .	39
		C6.2.1 Materials . . . . .	39
		C6.2.2 Shear Stress in Bearing Connections . . . . .	39
		C6.2.3 Bolts Subject to Tension . . . . .	39
		C6.2.5 Bearing Stress in Bolted Connections . . . . .	39
		C6.2.6 Minimum Edge Distances and Bolt Spacing for Bolted Connections . . . . .	39
		C6.2.7 Bearing Stress in Pinned Connections . . . . .	39
		C6.2.8 Minimum Edge Distances for Pinned Connections . . . . .	40
		C6.2.9 Connection Elements and Members . . . . .	40
	C6.3	Welded Connections . . . . .	40
		C6.3.3 Design Stresses . . . . .	40
		C6.3.3.1 Through-Thickness Stress . . . . .	40
	C6.4	Field Connections of Members . . . . .	40
		C6.4.1 Slip Joints . . . . .	40
		C6.4.2 Base and Flange Plate Connections . . . . .	41
	C6.5	Test Verification . . . . .	41
C7	Detailing and Fabrication . . . . .		43
	C7.1	Detailing . . . . .	43
		C7.1.1 Drawings . . . . .	43
		C7.1.2 Drawing Review . . . . .	43
		C7.1.3 Erection Drawings . . . . .	43
		C7.1.4 Shop Detail Drawings . . . . .	43
		C7.1.4.2 Dimensions and Tolerances . . . . .	43
		C7.1.4.4 Corrosion and Finish Considerations . . . . .	43
		C7.1.4.5 Other Requirements . . . . .	43
	C7.2	Fabrication . . . . .	43
		C7.2.1 Material . . . . .	43
		C7.2.2 Material Preparation . . . . .	43
		C7.2.2.1 Cutting . . . . .	43
		C7.2.2.2 Forming . . . . .	43
		C7.2.2.3 Holes . . . . .	44
		C7.2.2.4 Identification . . . . .	44
	C7.2.3	Welding . . . . .	44

C8.1	Introduction . . . . .	45
C8.2	Foundations . . . . .	45
C8.3	Material . . . . .	45
C8.4	Fabrication . . . . .	45
C8.5	Strain Measurements . . . . .	45
C8.6	Assembly and Erection . . . . .	45
C8.7	Test Loads . . . . .	46
C8.8	Load Application . . . . .	46
C8.9	Loading Procedure. . . . .	46
C8.10	Load Measurement . . . . .	46
C8.11	Deflections. . . . .	46
C8.12	Failures. . . . .	46
C8.13	Post-Test Inspection . . . . .	46
C8.14	Disposition of Prototype. . . . .	46
C8.15	Report . . . . .	46
C9	Structural Members and Connections Used in Foundations . . . . .	47
C9.1	Introduction . . . . .	47
C9.2	General Considerations . . . . .	47
C9.3	Anchor Bolts. . . . .	48
	C9.3.3 Combined Shear and Tension. . . . .	48
	C9.3.4 Development Length . . . . .	48
C9.4	Direct-Embedded Poles . . . . .	49
C9.5	Embedded Casings. . . . .	49
C10	Quality Assurance/Quality Control . . . . .	51
C10.1	Introduction . . . . .	51
C10.2	Quality Assurance . . . . .	51
	C10.2.1 Design and Drawings . . . . .	51
	C10.2.4 Nondestructive Testing . . . . .	51
	C10.2.5 Tolerances . . . . .	51
	C10.2.6 Surface Coatings . . . . .	51
	C10.2.7 Shipping . . . . .	51
C10.3	Quality Control . . . . .	51
	C10.3.1 Materials. . . . .	51
	C10.3.3 Dimensional Inspection . . . . .	51
	C10.3.4 Surface Coating Inspection . . . . .	51
	C10.3.5 Weld Inspection . . . . .	51
	C10.3.6 Shipment and Storage. . . . .	52
C11	Assembly and Erection . . . . .	53
C11.1	Introduction . . . . .	53
C11.2	Handling . . . . .	53
C11.3	Single-Pole Structures. . . . .	53
	C11.3.1 Slip Joints . . . . .	53
	C11.3.2 Bolted Flange Joints. . . . .	53
	C11.3.3 Attachments to Pole Sections. . . . .	54
	C11.3.4 Erection of Assembled Structures. . . . .	54
C11.4	Frame-Type Structures. . . . .	54
	C11.4.1 Slip Joints in Frames . . . . .	54
	C11.4.2 Erection . . . . .	54
C11.5	Installation on Foundation. . . . .	54
	C11.5.1 Anchor Bolt and Base Plate Installation . . . . .	54
	C11.5.2 Direct-Embedded Poles . . . . .	54
C11.6	Guying . . . . .	54
	C11.6.1 Guy Anchor Location . . . . .	54
	C11.6.2 Guy Installation . . . . .	54
C11.7	Posterection Procedures . . . . .	55
	C11.7.1 Inspection . . . . .	55
	C11.7.2 Grounding . . . . .	55
	C11.7.3 Coating Repair . . . . .	55
	C11.7.4 Unloaded Arms . . . . .	55
	C11.7.5 Hardware Installation . . . . .	55



Appendix II Properties of Various Tubular Sections . . . . .	59
Notation for Appendix II . . . . .	59
Appendix III Horizontal Testing . . . . .	63
Test Equipment. . . . .	63
Test Procedure for Pole Test. . . . .	63
Appendix IV Headed Anchor Bolts . . . . .	65
Development Length. . . . .	65
Background . . . . .	65
Appendix V Assembly and Erection. . . . .	67
Introduction . . . . .	67
Helicopter Erection . . . . .	67
In-Service Structure Maintenance and Inspection. . . . .	67
Wind-Induced Vibration . . . . .	67
Appendix VI Shaft-to-Foundation Connection . . . . .	69
Base Plates—Analysis Considerations . . . . .	69
Calculation of Anchor Bolt Load . . . . .	71
Appendix VII Corrosion Protection and Finish Considerations. . . . .	73
Introduction . . . . .	73
Corrosion Mechanisms. . . . .	73
Corrosion Protection and Finish Options . . . . .	73
Paint and Coating Systems . . . . .	73
Above-Grade Protection. . . . .	74
Below-Grade Protection. . . . .	74
Surface Preparation . . . . .	74
Application . . . . .	74
Inspection . . . . .	74
Paint or Coating Over Galvanizing . . . . .	74
Galvanizing . . . . .	74
Protection Provided . . . . .	74
Appearance . . . . .	75
Special Design Considerations . . . . .	75
Application . . . . .	76
Repair . . . . .	76
Weathering Steel . . . . .	77
Metalizing . . . . .	78
References . . . . .	78
Appendix VIII Arm-to-Shaft Connection Analysis Considerations . . . . .	81
General Load, Dimension, and Material Specifications. . . . .	81
INDEX . . . . .	83

## Chapter 1

### SCOPE

*Design of Steel Transmission Pole Structures* specifies requirements for the design, fabrication, testing, assembly, and erection of cold-formed tubular members and connections for steel electrical transmission pole structures. Structure components (members, connections, guys) are selected to resist factored design loads at stresses approaching yielding, buckling, fracture, or any other limiting condition specified in this standard. Distribution, substation, communication, and railroad electric traction structures are not included within the scope of this standard.

Before the initial publication of this standard in 2005, most electric transmission design professionals used ASCE's Engineering Manual and Report on Engineering Practice No. 72 titled

*Design of Steel Transmission Pole Structures* as their primary reference for providing a uniform basis for designing, fabricating, testing, assembling, and erecting steel transmission pole structures. The second edition of Manual 72 served as the primary resource document for the development of the original version of this standard, ASCE 48-05. This document is the first revision to this standard and is intended to replace ASCE 48-05 in its entirety.

Units of measurement herein are expressed first in English units followed by the Systems International (SI) units in parentheses. Formulae are based on English units, and, thus, some formulae require a conversion factor to use SI units. The appropriate conversion factor is given after each formula.