

ASCE STANDARD

ASCE/EWRI

18-18

Standard Guidelines for In-Process Oxygen Transfer Testing

ASCE STANDARD

ASCE/EWRI

18-18

**Standard Guidelines
for In-Process Oxygen
Transfer Testing**



PUBLISHED BY THE AMERICAN SOCIETY OF CIVIL ENGINEERS

Library of Congress Cataloging-in-Publication Data

Library of Congress in Publication Control Number: 2018037192

Published by American Society of Civil Engineers
1801 Alexander Bell Drive
Reston, Virginia, 20191-4382
www.asce.org/bookstore | ascelibrary.org

This standard was developed by a consensus standards development process that has been accredited by the American National Standards Institute (ANSI). Accreditation by ANSI, a voluntary accreditation body representing public and private sector standards development organizations in the United States and abroad, signifies that the standards development process used by ASCE has met the ANSI requirements for openness, balance, consensus, and due process.

While ASCE's process is designed to promote standards that reflect a fair and reasoned consensus among all interested participants, while preserving the public health, safety, and welfare that is paramount to its mission, it has not made an independent assessment of and does not warrant the accuracy, completeness, suitability, or utility of any information, apparatus, product, or process discussed herein. ASCE does not intend, nor should anyone interpret, ASCE's standards to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this standard.

ASCE has no authority to enforce compliance with its standards and does not undertake to certify products for compliance or to render any professional services to any person or entity.

ASCE disclaims any and all liability for any personal injury, property damage, financial loss, or other damages of any nature whatsoever, including without limitation any direct, indirect, special, exemplary, or consequential damages, resulting from any person's use of, or reliance on, this standard. Any individual who relies on this standard assumes full responsibility for such use.

ASCE and American Society of Civil Engineers—Registered in U.S. Patent and Trademark Office.

Photocopies and permissions. Permission to photocopy or reproduce material from ASCE publications can be requested by sending an e-mail to permissions@asce.org or by locating a title in ASCE's Civil Engineering Database (<http://cedb.asce.org>) or ASCE Library (<http://ascelibrary.org>) and using the "Permissions" link.

Errata: Errata, if any, can be found at <http://dx.doi.org/10.1061/9780784414958>.

Copyright © 2018 by the American Society of Civil Engineers.
All Rights Reserved.
ISBN 978-0-7844-1495-8 (soft cover)
ISBN 978-0-7844-8186-8 (PDF)
Manufactured in the United States of America.

24 23 22 21 20 19 18 1 2 3 4 5

ASCE STANDARDS

In 2014, the Board of Direction approved revisions to the ASCE Rules for Standards Committees to govern the writing and maintenance of standards developed by ASCE. All such standards are developed by a consensus standards process managed by the ASCE Codes and Standards Committee (CSC). The consensus process includes balloting by a balanced standards committee and reviewing during a public comment period. All standards are updated or reaffirmed by the same process every five to ten years. Requests for formal interpretations shall be processed in accordance with Section 7 of ASCE Rules for Standards Committees, which are available at www.asce.org. Errata, addenda, supplements, and interpretations, if any, for this standard can also be found at www.asce.org.

This standard has been prepared in accordance with recognized engineering principles and should not be used without the user's competent knowledge for a given application. The publication of this standard by ASCE is not intended to warrant that the information contained therein is suitable for any general or specific use, and ASCE takes no position respecting the validity of patent rights. The user is advised that the determination of patent rights or risk of infringement is entirely their own responsibility.

A complete list of current standards is available in the ASCE Library (<http://ascelibrary.org/page/books/s-standards>).

This page intentionally left blank

CONTENTS

ASCE STANDARDS.		iii
PREFACE		vii
ACKNOWLEDGMENTS		ix
1	SCOPE	1
2	NONSTEADY-STATE METHOD.	3
	2.1 Objective	3
	2.2 Theoretical Basis	3
	2.3 Assumptions and Limitations	3
	2.4 Procedure	4
	2.4.1 The H ₂ O ₂ Technique.	5
	2.5 Sample Calculation.	6
	2.6 Quality Control.	7
	2.7 Test Variability.	8
3	OFF-GAS METHOD.	13
	3.1 Objective	13
	3.2 Theoretical Basis	13
	3.3 Assumptions and Limitations	14
	3.4 Apparatus and Supplies	15
	3.4.1 Off-Gas Analyzer	15
	3.4.2 Off-Gas Collection System	15
	3.5 General Requirements of the Apparatus.	15
	3.5.1 Off-Gas Collection System	15
	3.5.2 Off-Gas Analyzer Capabilities.	15
	3.5.3 Liquid-Phase DO Hardware	16
	3.5.4 Miscellaneous Equipment	16
	3.6 Procedure.	16
	3.6.1 Conduct of Test	16
	3.6.2 Analyzer Operation	16
	3.6.3 Sampling Criteria.	16
	3.6.4 Recorded Data	16
	3.7 Off-Gas Calculations.	17
	3.7.1 General.	17
	3.7.2 Summary Data Sheet.	17
	3.7.3 Ancillary Information	17
	3.7.4 Report of Results.	17
	3.8 Quality Assurance/Quality Control Procedures	17
	3.8.1 Leak Test Analyzer Module and Conduit Hose.	17
	3.8.2 Oxygen Sensor Calibration	17
	3.8.3 Sampling Plan Adequacy	18
	3.8.4 Conversion of OTE _f to SOTE _{pw} .	18
	3.9 Accuracy and Precision	18
4	TRACER MEASUREMENT OF OXYGEN TRANSFER	19
	4.1 Objective	19
	4.2 Theoretical Basis	19
	4.3 Assumptions and Limitations	20

4.4	Apparatus	20
4.4.1	Liquid Scintillation Spectrophotometer	20
4.4.2	Grab Sampling Device	20
4.4.3	Alternate Continuous-Flow Sampling Arrangement	20
4.5	Procedures	20
4.5.1	Tracer Quantities	20
4.5.2	Tracer Release	21
4.5.3	Sampling Locations, Test Duration, and Sampling Frequency	21
4.5.4	Sample Collection, Storage, and Shipment	21
4.5.4.1	Grab Sampling	21
4.5.4.2	Continuous Flow Sampling	21
4.5.5	Laboratory Analysis	21
4.6	Calculations	21
4.6.1	General	21
4.6.2	Example	22
4.7	Quality Assurance and Quality Control Procedures	23
4.8	Accuracy and Precision	23
5	COMPARISONS AMONG FIELD OXYGEN TRANSFER TECHNIQUES	25
APPENDIX A	OFF-GAS ANALYZER	29
A.1	Capabilities	29
APPENDIX B	SAMPLE CALCULATION FOR OFF-GAS TECHNIQUE	31
B.1	Example 1—Standard Oxygen Transfer Efficiency	31
B.2	Example 2—Computing the Mean Weighted Average (MWA) OTE_f and $SOTE_{pw}$	34
APPENDIX C	CORRECTIONS TO THE K_{Kr}/K_{La} RATIO FOR KRYPTON STRIPPING	35
APPENDIX D	OTHER METHODS	37
D.1	Steady-State Oxygen Uptake Rate (R) Technique	37
D.1.1	Objective	37
D.1.2	Theoretical Basis	37
D.1.3	Assumptions and Limitations	37
D.1.4	Procedure	37
D.1.4.1	General	37
D.1.4.2	Oxygen Uptake Rates—Ex Situ	38
D.1.4.3	Ex Situ Oxygen Uptake Test Accuracy	38
D.1.4.4	Other Methods—Off-Gas Column Test for Alpha Determinations	38
D.1.4.5	Sample Calculation	40
D.1.4.6	Quality Control	40
D.1.4.7	Test Variability and Accuracy	40
D.2	Mass Balance Oxygen Transfer Determination in Process Water	40
D.2.1	Objective	40
D.2.2	Theoretical Basis	41
D.2.3	Assumptions and Limitations	41
D.2.4	Procedures	41
D.2.4.1	Driving Force Factor	42
D.2.4.2	Saturation and Temperature Correction	42
D.2.4.3	Nitrification–Denitrification Factor	42
D.2.4.4	Benthic Oxygen Demand	42
D.2.4.5	Surface Reaeration	42
D.2.4.6	Photosynthetic Factor	42
D.2.5	Example Calculation	43
D.2.6	Accuracy and Precision	44
D.2.7	Activated Sludge Systems	45
APPENDIX E	ABBREVIATIONS AND NOTATION	47
APPENDIX F	REFERENCES	49
INDEX		51

PREFACE

These guidelines for testing oxygen transfer devices in process water are the result of field testing by the ASCE Oxygen Transfer Standards Committee since about 1979. A significant portion of the early work by the Committee was supported by grants from the US Environmental Protection Agency.

Preparation of these guidelines was difficult. Side-by-side testing of a number of methods was used to verify reproducibility of the techniques and has led to substantial refinement in procedures and rejection of some techniques. The methods selected have proven to be most reliable under rigorous field conditions. The technology continues to remain dynamic, however, and modifications and/or new procedures are likely to occur in the future.

It is intended that these guidelines be used by engineers, owners, and manufacturers in evaluating the performance of aeration devices under process conditions. They are not intended for compliance testing of aeration devices insofar as performance under process conditions is affected by a large number of process variables and wastewater characteristics that are not easily controlled. In-process testing does provide the engineer with useful information that can be used in future design. It provides the owner with data that can be used for operation and

maintenance of the aeration equipment. These procedures provide manufacturers with a useful research and development tool for their equipment development and design.

The procedures as a whole are applicable for all oxygen transfer devices in suspended growth systems. They may also be applicable to testing oxygen transfer devices in lakes and streams. They are not applicable to fixed-film reactors, although modification of some of the methods might serve to provide data on these processes as well. The substance of the guidelines is based on the report, "Development of Standard Procedures for Evaluating Oxygen Transfer Devices," EPA 600/2-83-102, October 1983; however, other pertinent references are provided throughout this document dealing with more detail about the techniques. Section 5.0 provides a discussion on the comparison of the methods.

Since the original publication in 1996, the procedure that has gained the widest acceptance and use is the off-gas method detailed in Chapter 3. While still considered an accurate and reliable method for measuring oxygen transfer in process systems, the tracer technique described in Chapter 4 has not been used in recent years.

This page intentionally left blank

ACKNOWLEDGMENTS

The American Society of Civil Engineers acknowledges the devoted efforts of the Oxygen Transfer Standards Committee of the EWRI Standards Development Council. The committee comprises individuals from many backgrounds, including consulting engineering, research, education, wastewater equipment manufacturing, government, industry, and private practice.

The contributions of the EPA for workshops, laboratory, and field studies that support the development and refinement of these guidelines are gratefully acknowledged.

This standard was formulated through the consensus standards process by balloting in compliance with the procedures of the ASCE Codes and Standards Activity Council. Those individuals who serve on the EWRI Oxygen Transfer Standards Committee are

James J Marx, *Chair*
Michael K. Stenstrom, *Vice-Chair*
Michael G. Rieth, *Secretary*
Roel Boussemaere

Randy Chann
Randolph Charette
David A. Clidence
Findley G. Edwards
Sylvie Gillot
Jesse Jones
Johnny Lee
Frederick K. Marotte
Randall Marx
Henryk Melcer
James A. Mueller
David Redmon
Robert Sheker
Michael L. Smith
Berrin Tansel
Ian Trillo
Martin Wagner
Robert S. Watral

This page intentionally left blank

CHAPTER 1

SCOPE

The methods described under these standard guidelines, which were first developed by ASCE (1996), provide several proven techniques for measuring oxygen transfer under process conditions. Nonsteady-state, off-gas, and inert gas tracer methods are described in Chapters 2, 3, and 4. Chapter 5 is a brief comparison among methods. The methods presented are considered to be well developed and provide satisfactory precision for a wide range of aeration processes in suspended-growth biological systems.

Because a wide range of process variables and wastewater characteristics that affect the precision (and accuracy) of these methods are difficult to control, the methods are offered as standard guidelines and are not recommended for compliance testing of aeration equipment. These guidelines use both the Système International (SI) units and common units. Symbols and nomenclature are defined in Appendix E. ASCE (1996) can still be obtained from the American Society of Civil Engineers in Reston, VA.