

ASCE STANDARD

ASCE/SEI

48-19

Design of Steel Transmission Pole Structures

ASCE STANDARD

ASCE/SEI

48-19

Design of Steel Transmission Pole Structures



PUBLISHED BY THE AMERICAN SOCIETY OF CIVIL ENGINEERS

Library of Congress Cataloging-in-Publication Data

Names: American Society of Civil Engineers, author.

Title: Design of transmission pole structures, ASCE 48-19 / American Society of Civil Engineers.

Description: Reston, Virginia : American Society of Civil Engineers, [2020] | Includes bibliographical references and index. | Summary: "This standard provides a uniform basis for the design, detailing, fabrication, testing, assembly, and erection of steel tubular structures for electrical transmission poles. These guidelines apply to cold-formed single- and multipole tubular steel structures that support overhead transmission lines" – Provided by publisher.

Identifiers: LCCN 2020001997 | ISBN 9780784415078 (paperback) | ISBN 9780784482254 (pdf)

Subjects: LCSH: Electric lines—Poles and towers—Design and construction—Standards.

Classification: LCC TK3242 .A515 2020 | DDC 621.319/22—dc23

LC record available at <https://lccn.loc.gov/2020001997a>

Published by American Society of Civil Engineers

1801 Alexander Bell Drive

Reston, Virginia 20191

www.asce.org/pubs

This standard was developed by a consensus standards development process which has been accredited by the American National Standards Institute (ANSI). Accreditation by ANSI, a voluntary accreditation body representing public and private sector standards development organizations in the United States and abroad, signifies that the standards development process used by ASCE has met the ANSI requirements for openness, balance, consensus, and due process.

While ASCE's process is designed to promote standards that reflect a fair and reasoned consensus among all interested participants, while preserving the public health, safety, and welfare that is paramount to its mission, it has not made an independent assessment of and does not warrant the accuracy, completeness, suitability, or utility of any information, apparatus, product, or process discussed herein. ASCE does not intend, nor should anyone interpret, ASCE's standards to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this standard.

ASCE has no authority to enforce compliance with its standards and does not undertake to certify products for compliance or to render any professional services to any person or entity.

ASCE disclaims any and all liability for any personal injury, property damage, financial loss, or other damages of any nature whatsoever, including without limitation any direct, indirect, special, exemplary, or consequential damages, resulting from any person's use of, or reliance on, this standard. Any individual who relies on this standard assumes full responsibility for such use.

ASCE and American Society of Civil Engineers—Registered in US Patent and Trademark Office.

Photocopies and permissions. Permission to photocopy or reproduce material from ASCE publications can be requested by sending an email to permissions@asce.org or by locating a title in ASCE's Civil Engineering Database (<http://cedb.asce.org>) or ASCE Library (<http://ascelibrary.org>) and using the "Permissions" link.

Errata: Errata, if any, can be found at <https://doi.org/10.1061/9780784415078>.

Copyright © 2020 by the American Society of Civil Engineers.

All Rights Reserved.

ISBN 978-0-7844-1507-8 (print)

ISBN 978-0-7844-8225-4 (PDF)

Manufactured in the United States of America.

ASCE STANDARDS

In 2014, the Board of Direction approved revisions to the ASCE Rules for Standards Committees to govern the writing and maintenance of standards developed by ASCE. All such standards are developed by a consensus standards process managed by the ASCE Codes and Standards Committee (CSC). The consensus process includes balloting by a balanced standards committee and reviewing during a public comment period. All standards are updated or reaffirmed by the same process every five to ten years. Requests for formal interpretations shall be processed in accordance with Section 7 of ASCE Rules for Standards Committees, which are available at www.asce.org. Errata, addenda, supplements, and interpretations, if any, for this standard can also be found at www.asce.org.

The provisions of this document are written in permissive language and, as such, offer the user a series of options or instructions but do not prescribe a specific course of action. Significant judgment is left to the user of this document.

This standard has been prepared in accordance with recognized engineering principles and should not be used without the user's competent knowledge for a given application. The publication of this standard by ASCE is not intended to warrant that the information contained therein is suitable for any general or specific use, and ASCE takes no position respecting the validity of patent rights. The user is advised that the determination of patent rights or risk of infringement is entirely their own responsibility.

A complete list of currently available standards is available in the ASCE Library (<https://ascelibrary.org/page/books/s-standards>).

This is a preview of "ASCE/SEI 48-2019". [Click here to purchase the full version from the ANSI store.](#)

CONTENTS

PREFACE		xiii
ACKNOWLEDGMENTS		xv
1 SCOPE		1
2 APPLICABLE DOCUMENTS.		3
3 DEFINITIONS		5
4 LOADING, GEOMETRY, AND ANALYSIS		7
4.1 Introduction.		7
4.2 Loading.		7
4.2.1 Factored Design Loads.		7
4.2.2 Loading Considerations		7
4.2.3 Load Expression		7
4.3 Geometric Configurations		7
4.3.1 Configuration Considerations		7
4.3.2 Structure Types.		7
4.4 Methods of Analysis		7
4.4.1 Structural Analysis Methods.		7
4.4.2 Analysis of Connections		7
4.5 Additional Considerations		7
4.5.1 Structural Support		7
4.5.2 Design Restrictions.		7
4.5.3 Climbing and Maintenance Provisions		7
4.5.4 Pre-Engineered Steel Poles (Wood Pole Equivalents)		7
5 DESIGN OF MEMBERS		9
5.1 Introduction.		9
5.2 Members		9
5.2.1 Material.		9
5.2.1.1 Specifications.		9
5.2.1.2 Material Properties.		9
5.2.1.3 Energy-Impact Properties		9
5.2.2 Tension.		9
5.2.3 Compression		9
5.2.3.1 Truss Members.		9
5.2.3.2 Beam Members.		10
5.2.4 Shear		11
5.2.5 Bending.		11
5.2.6 Combined Stresses		11
5.3 Guys		11
5.3.1 Material Properties		11
5.3.2 Tension.		11
5.4 Test Verification		11
6 DESIGN OF CONNECTIONS		13
6.1 Introduction.		13
6.2 Bolted and Pinned Connections		13
6.2.1 Material.		13

6.2.2	Shear Stress in Bearing Connections	13
6.2.3	Bolts Subject to Tension.	13
6.2.4	Bolts Subject to Combined Shear and Tension	13
6.2.5	Bearing Stress in Bolted Connections	13
6.2.6	Minimum Edge Distances and Bolt Spacing for Bolted Connections	14
6.2.7	Bearing Stress in Pinned Connections.	14
6.2.8	Minimum Edge Distances for Pinned Connections	14
6.2.9	Connection Elements and Members	14
6.3	Welded Connections	14
6.3.1	Material Properties	14
6.3.2	Effective Area	14
6.3.3	Design Stresses.	14
6.3.3.1	Through-Thickness Stress	15
6.3.4	Circumferential Welded Splices	15
6.3.5	Flange and Base Plate to Pole Shaft Welds.	16
6.3.6	T-Joints.	16
6.4	Field Connections of Members	16
6.4.1	Slip Joints	16
6.4.2	Base and Flange Plate Connections	16
6.5	Test Verification	16
7	DETAILING AND FABRICATION	17
7.1	Detailing	17
7.1.1	Drawings	17
7.1.2	Drawing Review	17
7.1.3	Erection Drawings	17
7.1.4	Shop Detail Drawings	17
7.1.4.1	Material.	17
7.1.4.2	Dimensions and Tolerances	17
7.1.4.3	Welding	17
7.1.4.4	Corrosion and Finish Considerations	17
7.1.4.5	Other Requirements	17
7.2	Fabrication	17
7.2.1	Material.	17
7.2.2	Material Preparation	17
7.2.2.1	Cutting	17
7.2.2.2	Forming	17
7.2.2.3	Holes	17
7.2.2.4	Identification	17
7.2.3	Welding	18
8	TESTING.	19
8.1	Introduction.	19
8.2	Foundations.	19
8.3	Material.	19
8.4	Fabrication	19
8.5	Strain Measurements	19
8.6	Assembly and Erection.	19
8.7	Test Loads	19
8.8	Load Application.	19
8.9	Loading Procedure	19
8.10	Load Measurement.	19
8.11	Deflections	19
8.12	Failures	20
8.13	Post-Test Inspection	20
8.14	Disposition of Prototype.	20
8.15	Report	20
9	STRUCTURAL MEMBERS AND CONNECTIONS USED IN FOUNDATIONS	21
9.1	Introduction.	21
9.2	General Considerations.	21
9.3	Anchor Bolts	21

9.3.1	Bolts Subject to Tension	21
9.3.2	Shear Stress	21
9.3.3	Combined Shear and Tension	21
9.3.4	Development Length	21
9.4	Direct-Embedded Poles	21
9.5	Embedded Casings	22
9.6	Test Verification	22
10	QUALITY ASSURANCE/QUALITY CONTROL	23
10.1	Introduction	23
10.2	Quality Assurance	23
10.2.1	Design and Drawings	23
10.2.2	Material	23
10.2.3	Welding	23
10.2.4	Nondestructive Testing	23
10.2.5	Tolerances	23
10.2.6	Surface Coatings	23
10.2.7	Shipping	23
10.3	Quality Control	23
10.3.1	Material	23
10.3.2	Visual Inspection	23
10.3.3	Dimensional Inspection	23
10.3.4	Surface Coating Inspection	23
10.3.5	Weld Inspection	23
10.3.6	Shipment and Storage	24
11	ASSEMBLY AND ERECTION	25
11.1	Introduction	25
11.2	Handling	25
11.3	Single-Pole Structures	25
11.3.1	Slip Joints	25
11.3.2	Bolted Flange Joints	25
11.3.3	Attachments to Pole Sections	25
11.3.4	Erection of Assembled Structures	25
11.4	Frame-Type Structures	25
11.4.1	Slip Joints in Frames	25
11.4.2	Erection	25
11.4.3	Bolted Frame Connections	25
11.5	Installation on Foundation	25
11.5.1	Anchor Bolt and Base Plate Installation	25
11.5.2	Direct-Embedded Poles	26
11.5.3	Embedded Casings	26
11.6	Guying	26
11.6.1	Guy Anchor Location	26
11.6.2	Guy Installation	26
11.7	Post-Erection Procedures	26
11.7.1	Inspection	26
11.7.2	Grounding	26
11.7.3	Coating Repair	26
11.7.4	Unloaded Arms	26
11.7.5	Hardware Installation	26
	COMMENTARY	27
C4	LOADING, GEOMETRY, AND ANALYSIS	29
C4.2	Loading	29
C4.2.1	Factored Design Loads	29
C4.2.2	Loading Considerations	29
C4.2.3	Load Expression	29
C4.3	Geometric Configurations	30
C4.3.1	Configuration Considerations	30

	C4.3.2	Structure Types	30
C4.4		Methods of Analysis	30
	C4.4.1	Structural Analysis Methods	30
C4.5		Additional Considerations	31
	C4.5.1	Structural Support	31
	C4.5.2	Design Restrictions.	31
	C4.5.3	Climbing and Maintenance Provisions	31
	C4.5.4	Pre-Engineered Steel Poles (Wood Pole Equivalents)	31
C5		DESIGN OF MEMBERS	33
	C5.1	Introduction.	33
	C5.2	Members	33
		C5.2.1 Material.	33
		C5.2.1.1 Specifications.	33
		C5.2.1.2 Material Properties	33
		C5.2.1.3 Energy-Impact Properties	33
	C5.2.2	Tension.	33
	C5.2.3	Compression	33
		C5.2.3.1 Truss Members.	33
		C5.2.3.2 Beam Members.	34
	C5.2.4	Shear	35
	C5.2.5	Bending.	35
	C5.2.6	Combined Stresses	35
	C5.3	Guys	35
		C5.3.1 Material Properties	35
		C5.3.2 Tension.	35
	References	36
C6		DESIGN OF CONNECTIONS	39
	C6.1	Introduction.	39
	C6.2	Bolted and Pinned Connections	39
		C6.2.1 Material.	39
		C6.2.2 Shear Stress in Bearing Connections	39
		C6.2.3 Bolts Subject to Tension.	39
		C6.2.5 Bearing Stress in Bolted Connections	39
		C6.2.6 Minimum Edge Distances and Bolt Spacing for Bolted Connections	39
		C6.2.7 Bearing Stress in Pinned Connections.	39
		C6.2.8 Minimum Edge Distances for Pinned Connections.	40
		C6.2.9 Connection Elements and Members	40
	C6.3	Welded Connections	40
		C6.3.3 Design Stresses.	40
		C6.3.3.1 Through-Thickness Stress	40
	C6.4	Field Connections of Members	40
		C6.4.1 Slip Joints	40
		C6.4.2 Base and Flange Plate Connections	41
	C6.5	Test Verification	41
C7		DETAILING AND FABRICATION	43
	C7.1	Detailing	43
		C7.1.1 Drawings	43
		C7.1.2 Drawing Review	43
		C7.1.3 Erection Drawings	43
		C7.1.4 Shop Detail Drawings	43
		C7.1.4.2 Dimensions and Tolerances	43
		C7.1.4.4 Corrosion and Finish Considerations	43
		C7.1.4.5 Other Requirements	43
	C7.2	Fabrication	43
		C7.2.1 Material.	43
		C7.2.2 Material Preparation	43
		C7.2.2.1 Cutting	43
		C7.2.2.2 Forming	44

	C7.2.2.3	Holes	44
	C7.2.2.4	Identification	44
	C7.2.3	Welding	44
C8	TESTING		45
	C8.1	Introduction.	45
	C8.2	Foundations.	45
	C8.3	Material.	45
	C8.4	Fabrication	45
	C8.5	Strain Measurements	45
	C8.6	Assembly and Erection.	45
	C8.7	Test Loads	46
	C8.8	Load Application.	46
	C8.9	Loading Procedure	46
	C8.10	Load Measurement.	46
	C8.11	Deflections	46
	C8.12	Failures	46
	C8.13	Post-Test Inspection	46
	C8.14	Disposition of Prototype.	46
C9	STRUCTURAL MEMBERS AND CONNECTIONS USED IN FOUNDATIONS		47
	C9.1	Introduction.	47
	C9.2	General Considerations.	47
	C9.3	Anchor Bolts	48
		C9.3.3 Combined Shear and Tension	49
		C9.3.4 Development Length.	49
	C9.4	Direct-Embedded Poles	49
	C9.5	Embedded Casings	49
C10	QUALITY ASSURANCE/QUALITY CONTROL		51
	C10.1	Introduction.	51
	C10.2	Quality Assurance	51
		C10.2.1 Design and Drawings	51
		C10.2.4 Nondestructive Testing.	51
		C10.2.5 Tolerances	51
		C10.2.6 Surface Coatings	51
		C10.2.7 Shipping	51
	C10.3	Quality Control.	51
		C10.3.1 Material.	51
		C10.3.3 Dimensional Inspection	51
		C10.3.4 Surface Coating Inspection	51
		C10.3.5 Weld Inspection	51
		C10.3.6 Shipment and Storage	52
C11	ASSEMBLY AND ERECTION		53
	C11.1	Introduction.	53
	C11.2	Handling	53
	C11.3	Single-Pole Structures	53
		C11.3.1 Slip Joints	53
		C11.3.2 Bolted Flange Joints	54
		C11.3.3 Attachments to Pole Sections	54
		C11.3.4 Erection of Assembled Structures	54
	C11.4	Frame-Type Structures	54
		C11.4.1 Slip Joints in Frames.	54
		C11.4.2 Erection.	54
		C11.4.3 Bolted Frame Connections.	55
	C11.5	Installation on Foundation	55
		C11.5.1 Anchor Bolt and Base Plate Installation.	55
		C11.5.2 Direct-Embedded Poles	55
		C11.5.3 Embedded Casings	56
	C11.6	Guying	56

	C11.6.1	Guy Anchor Location	56
	C11.6.2	Guy Installation	56
C11.7		Post-Erection Procedures.	56
	C11.7.1	Inspection.	56
	C11.7.2	Grounding	56
	C11.7.3	Coating Repair	56
	C11.7.4	Unloaded Arms	56
	C11.7.5	Hardware Installation	57
APPENDIX A NOTATION			59
APPENDIX B PROPERTIES OF VARIOUS TUBULAR SECTIONS.			61
	Notation.		62
APPENDIX C RESERVED FOR FUTURE EDITIONS			63
APPENDIX D HEADED ANCHOR BOLTS			65
	Material Specifications		65
	Design Considerations		65
	Other Considerations		66
APPENDIX E ASSEMBLY AND ERECTION			67
	Introduction.		67
	Structure Assembly.		67
	Arm Connection Assembly		67
	Helicopter Erection.		67
	Maintenance and Inspection		68
	Wind-Induced Vibration		68
	Structures and Members		68
	Attached Conductors and Static Wires		69
APPENDIX F SHAFT-TO-FOUNDATION CONNECTION			71
	Base Plates: Analysis Considerations		71
	Calculation of Anchor Bolt Load		74
APPENDIX G CORROSION PROTECTION AND FINISH CONSIDERATIONS			75
	Introduction.		75
	Corrosion Mechanisms		75
	Galvanic Corrosion.		75
	Corrosion Protection and Finish Options		76
	Paint and Coating Systems.		76
	Above-Grade Protection		76
	Below-Grade Protection		76
	Surface Preparation.		76
	Application		76
	Inspection.		76
	Paint or Coating Over Galvanizing		76
	Galvanizing.		76
	Protection Provided.		76
	Appearance		76
	Special Design Considerations.		77
	Application		78
	Repair.		78
	Weathering Steel		79
	Metalizing		80
	References		80

APPENDIX H ARM-TO-SHAFT CONNECTION ANALYSIS CONSIDERATIONS	83
General Load, Dimension, and Material Specifications	83
APPENDIX I FLANGE AND BASE PLATE CONNECTIONS	85
Introduction	85
Description	85
Considerations	85
Material	85
Welding	85
Welding Procedure Qualification	85
Backing Bars	85
UT Inspection	85
Toe Cracks	86
Base and Flange Plate Thickness	86
Center Openings	86
Bolt Patterns	86
APPENDIX J FORGED/ROLLED RING BASE PLATES AND FLANGE PLATES	87
Background	87
Manufacturing Process	87
Advantages and Disadvantages	87
Specifying Forged/Rolled Ring Base Plates	89
Summary	89
INDEX	91

This is a preview of "ASCE/SEI 48-2019". [Click here to purchase the full version from the ANSI store.](#)

PREFACE

This standard includes informative commentaries and appendixes that are not a mandatory part of the standard. The commentary is numbered to correspond to the sections of the standard to which they refer. The appendixes provide additional information that is not necessarily related to specific sections of the standard.

Before the initial publication of this standard in 2005, most electric transmission design professionals used ASCE's Engineering Manual and Report on Engineering Practice No. 72, *Design of Steel Transmission Pole Structures*, as their primary reference for providing a uniform basis for designing, fabricating, testing, assembling, and erecting steel transmission pole structures. The second edition of MOP 72 served as the primary

resource document for the development of the original version of Standard ASCE/SEI 48-05. The first revision was Standard ASCE/SEI 48-11. This document is the second revision to this standard and is intended to replace ASCE 48-11 in its entirety.

This standard has been prepared in accordance with recognized engineering principles and should not be used without the user's competent knowledge for a given application. The publication of this standard by ASCE is not intended as a warrant that the information contained herein is suitable for any general or specific use, and ASCE takes no position regarding the validity of patent rights. Users are advised that the determination of patent rights or risk of infringement is entirely their own responsibility.

This is a preview of "ASCE/SEI 48-2019". [Click here to purchase the full version from the ANSI store.](#)

ACKNOWLEDGMENTS

ASCE and its Structural Engineering Institute (SEI) gratefully acknowledge the devoted efforts of the Design of Steel Transmission Pole Structures Standards Committee. This committee comprises individuals from many backgrounds. This standard was prepared through ASCE's consensus standardization process in compliance with the ASCE Rules for Standards Committees and the procedures of ASCE's Codes and Standards Committee (CSC). ASCE's standardization process is accredited by the American National Standards Institute (ANSI).

Committee Members

Kenneth L. Sharpless, P.E., F.ASCE, F.SEI, *Chair*
J. Kelly Bledsoe, P.E., M.ASCE, *Secretary*
Ronald E. Randle, P.E., M.ASCE, F.SEI, *Past Chair*
John P. Koprucki, P.E., S.E., M.ASCE, *Secretariat*
Richard F. Aichinger, P.E., M.ASCE
Gary E. Bowles, P.E., F.SEI, M.ASCE
David G. Brinker, P.E., S.E., M.ASCE
Michael D. Brown, P.E., M.ASCE
Jerry G. Crawford, P.E., M.ASCE
Dana R. Crissey, P.E., M.ASCE
Martin L. de la Rosa, P.E., F.ASCE
David Endorf, P.E., M.ASCE
Michael R. Gall, P.E.
Lewis H. Grant, P.E., P.Eng., M.ASCE
Nicholas Grossenbach, P.E., M.ASCE
James A. Hamraie, P.E., M.ASCE

Henry W. Ho, P.E., M.ASCE
Magdi F. Ishac, Ph.D., P.E., P.Eng., F.SEI, F.ASCE
Leon Kempner Jr., Ph.D., P.E., M.ASCE, F.SEI
Massoud Khavari, P.E., M.ASCE
Paul M. Legrand II, P.E., M.ASCE
Otto J. Lynch, P.E., F.SEI, F.ASCE
William L. Magee, P.E., M.ASCE
William B. Mills, P.E., M.ASCE
Michael R. Morel, P.E., M.ASCE
George E. Murray Jr., P.E., M.ASCE
David Nahlen, P.E., M.ASCE
Robert E. Nickerson, P.E., M.ASCE, F.SEI
Majed J. Saleh, M.ASCE
Richard M. Slocum, P.E., S.E., M.ASCE
Marlon W. Vogt, P.E., M.ASCE, F.SEI

Associate Members

Majid R. J. Farahani, P.E., M.ASCE
Jonathan P. Girard, P.E., M.ASCE
Michael C. Heikens, P.E., M.ASCE
Robert W. Kruse, P.E.
Ajay K. Mallik, P.E., M.ASCE
Wesley J. Oliphant, P.E., F.ASCE, F.SEI
Michael J. Paharik, P.E.
William J. Reisdorff Jr., P.E., M.ASCE
Randall L. Samson, P.E., M.ASCE
Stacey Sheffield, P.E., M.ASCE

This is a preview of "ASCE/SEI 48-2019". [Click here to purchase the full version from the ANSI store.](#)

CHAPTER 1

SCOPE

Design of Steel Transmission Pole Structures specifies requirements for the design, fabrication, testing, assembly, and erection of cold-formed tubular members and connections for steel electrical transmission pole structures. Structure components (members, connections, guys) are selected to resist factored design loads at stresses approaching yielding, buckling, fracture, or any other limiting condition specified in this standard. Communication and railroad electric traction structures are not included within the scope of this standard.

Overhead line structures, including steel transmission poles, are inherently different from buildings and most other structures. Overhead lines are a complex structural system composed of foundations, structures, conductors, and cables. A significant portion of the load on the structure is imposed by the conductors and other cables strung between the structures and is concentrated at specific points on the structure. The conductors and cables are subjected to extremes of temperature, wind, ice, and other phenomena not typical to other structures such as buildings and bridges. The tensions in these conductors and cables change with temperature, wind, and ice loads, and

the temperatures of the conductors can be significantly higher than ambient temperature. Another significant difference between overhead line structures and other types of structures is that they are designed for a different life cycle than buildings, bridges, and other occupied structures. The structure designer shall clearly understand these differences and the unique behavior of overhead lines.

One advantage of this cable system is the combination of its ability to absorb dynamic energy and the very low relative mass of the steel pole structures. As a result, the design of overhead lines, including steel transmission poles, is not normally controlled by seismic loads. In general, large structure deflections are acceptable provided such deflections are accounted for in the analysis of the structures and their effects on the positions of the connected conductors and cables are considered.

Units of measurement herein are expressed first in US customary units followed by the Système International (SI) units in parentheses. Formulas are based on US customary units, and thus, some formulas require a conversion factor to use SI units. The appropriate conversion factor is given after each formula.