


ANSI/ASHRAE Standard 135-2004
(Including ANSI/ASHRAE addenda listed in the History of Revisions)



ASHRAE STANDARD



A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee on October 5, 2003; by the ASHRAE Board of Directors on January 29, 2004; and by the American National Standards Institute on February 25, 2004. See "History of Revisions" section for approval dates of addenda.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site, <http://www.ashrae.org>, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2004 ASHRAE, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE STANDING STANDARD PROJECT COMMITTEE 135
Cognizant TC: TC 1.4, Control Theory and Applications
SPLS Liaison: Frank E. Jakob

Steven T. Bushby, *Chair**
William O. Swan III, *Vice-Chair*
Carl Neilson, *Secretary**
Barry B. Bridges*
James F. Butler*
A. J. Capowski*
Keith A. Corbett
Jeffery Cosiol

Troy D. Cowan*
Daniel P. Giorgis
Thomas S. Ertsgaard*
Craig P. Gemmill*
Robert L. Johnson
Stephen T. Karg*
J. Damian Ljungquist*
Jerald P. Martocci

Mark A. Railsback
David W. Robin
Ernest L. Senior
Daniel A. Traill*
J. Michael Whitcomb*
David F. White
Grant N. Wichenko

**Denotes members of voting status when this standard was approved for publication.*

The following persons served as consultants to the project committee:

Andrey Golovin
David G. Holmberg

H. Michael Newman
René Quirighetti

David H. Ritter
Takeji Toyoda

ASHRAE STANDARDS COMMITTEE 2003-2004

Van D. Baxter, *Chair*
Davor Novosel, *Vice-Chair*
Donald B. Bivens
Dean S. Borges
Paul W. Cabot
Charles W. Coward, Jr.
Hugh F. Crowther
Brian P. Dougherty
Hakim Elmahdy

Matt R. Hargan
Richard D. Hermans
John F. Hogan
Frank E. Jakob
Stephen D. Kennedy
David E. Knebel
Frederick H. Kohloss
Merle F. McBride
Mark P. Modera

Cyrus H. Nasseri
Gideon Shavit
David R. Tree
Thomas H. Williams
James E. Woods
Kent W. Peterson, CO
Ross D. Montgomery, BOD ExO

Claire B. Ramspeck, Manager of Standards

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other members may or may not be members of ASHRAE, all must be technically qualified in the subject area of the standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate standards for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, designed, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its standards will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this standard and marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

FOREWORD	vii
1 PURPOSE	1
2 SCOPE	1
3 DEFINITIONS	1
3.1 Terms Adopted from International Standards	1
3.2 Terms Defined for this Standard.....	2
3.3 Abbreviations and Acronyms Used in this Standard.....	5
4 BACnet PROTOCOL ARCHITECTURE	8
4.1 The BACnet Collapsed Architecture	9
4.2 BACnet Network Topology.....	11
4.3 Security	13
5 THE APPLICATION LAYER	14
5.1 The Application Layer Model.....	14
5.2 Segmentation of BACnet Messages.....	18
5.3 Transmission of BACnet APDUs.....	19
5.4 Application Protocol State Machines.....	23
5.5 Application Protocol Time Sequence Diagrams.....	37
5.6 Application Layer Service Conventions	45
6 THE NETWORK LAYER.....	47
6.1 Network Layer Service Specification	47
6.2 Network Layer PDU Structure.....	48
6.3 Messages for Multiple Recipients.....	53
6.4 Network Layer Protocol Messages	54
6.5 Network Layer Procedures	56
6.6 BACnet Routers	58
6.7 Point-To-Point Half-Routers.....	63
7 DATA LINK/PHYSICAL LAYERS: ISO 8802-3 ("Ethernet") LAN	68
7.1 The Use of ISO 8802-2 Logical Link Control (LLC).....	68
7.2 Parameters Required by the LLC Primitives	68
7.3 Parameters Required by the MAC Primitives.....	68
7.4 Physical Media.....	68
8 DATA LINK/PHYSICAL LAYERS: ARCNET LAN	70
8.1 The Use of ISO 8802-2 Logical Link Control (LLC).....	70
8.2 Parameters Required by the LLC Primitives	70
8.3 Mapping the LLC Services to the ARCNET MAC Layer.....	70
8.4 Parameters Required by the MAC Primitives.....	70
8.5 Physical Media.....	70
9 DATA LINK/PHYSICAL LAYERS: MASTER-SLAVE/TOKEN PASSING (MS/TP) LAN	72
9.1 Service Specification	72
9.2 Physical Layer.....	74
9.3 MS/TP Frame Format	76
9.4 Overview of the MS/TP Network	77
9.5 MS/TP Medium Access Control.....	78
9.6 Cyclic Redundancy Check (CRC)	94
9.7 Interfacing MS/TP LANs with Other BACnet LANs	95
9.8 Responding BACnet User Processing of Messages from MS/TP	95
9.9 Repeaters.....	95
10 DATA LINK/PHYSICAL LAYERS: POINT-TO-POINT (PTP)	97
10.1 Overview.....	97
10.2 Service Specification	97
10.3 Point-to-Point Frame Format	102
10.4 PTP Medium Access Control Protocol.....	104
11 DATA LINK/PHYSICAL LAYERS: EIA/CEA-709.1 ("LonTalk") LAN.....	125
11.1 The Use of ISO 8802-2 Logical Link Control (LLC).....	125
11.2 Parameters Required by the LLC Primitives	125

11.3	Mapping the LLC Services to the LonTalk Application Layer.....	125
11.4	Parameters Required by the Application Layer Primitives	125
11.5	Physical Media.....	126
12	MODELING CONTROL DEVICES AS A COLLECTION OF OBJECTS	127
12.1	Accumulator Object Type.....	130
12.2	Analog Input Object Type	138
12.3	Analog Output Object Type.....	143
12.4	Analog Value Object Type	148
12.5	Averaging Object Type.....	153
12.6	Binary Input Object Type	156
12.7	Binary Output Object Type.....	161
12.8	Binary Value Object Type	167
12.9	Calendar Object Type	172
12.10	Command Object Type.....	174
12.11	Device Object Type	178
12.12	Event Enrollment Object Type	185
12.13	File Object Type	190
12.14	Group Object Type	192
12.15	Life Safety Point Object Type	194
12.16	Life Safety Zone Object Type.....	200
12.17	Loop Object Type	206
12.18	Multi-state Input Object Type.....	213
12.19	Multi-state Output Object Type.....	217
12.20	Multi-state Value Object Type.....	221
12.21	Notification Class Object Type.....	226
12.22	Program Object Type.....	229
12.23	Pulse Converter Object Type.....	234
12.24	Schedule Object Type.....	241
12.25	Trend Log Object Type.....	246
13	ALARM AND EVENT SERVICES.....	252
13.1	Change of Value Reporting	253
13.2	Intrinsic Reporting	255
13.3	Algorithmic Change Reporting.....	258
13.4	Alarm and Event Occurrence and Notification.....	266
13.5	AcknowledgeAlarm Service	269
13.6	ConfirmedCOVNotification Service	271
13.7	UnconfirmedCOVNotification Service	273
13.8	ConfirmedEventNotification Service.....	274
13.9	UnconfirmedEventNotification Service.....	277
13.10	GetAlarmSummary Service.....	279
13.11	GetEnrollmentSummary Service	281
13.12	GetEventInformation Service	284
13.13	LifeSafetyOperation Service.....	286
13.14	SubscribeCOV Service	288
13.15	SubscribeCOVProperty Service.....	290
14	FILE ACCESS SERVICES	293
14.1	AtomicReadFile Service	294
14.2	AtomicWriteFile Service	297
15	OBJECT ACCESS SERVICES	299
15.1	AddListElement Service	299
15.2	RemoveListElement Service.....	301
15.3	CreateObject Service	303
15.4	DeleteObject Service	305
15.5	ReadProperty Service.....	306
15.6	ReadPropertyConditional Service.....	308
15.7	ReadPropertyMultiple Service.....	313
15.8	ReadRange Service	316

15.9	WriteProperty Service.....	320
15.10	WritePropertyMultiple Service.....	322
16	REMOTE DEVICE MANAGEMENT SERVICES.....	325
16.1	DeviceCommunicationControl Service.....	325
16.2	ConfirmedPrivateTransfer Service.....	327
16.3	UnconfirmedPrivateTransfer Service.....	329
16.4	ReinitializeDevice Service.....	330
16.5	ConfirmedTextMessage Service.....	332
16.6	UnconfirmedTextMessage Service.....	334
16.7	TimeSynchronization Service.....	335
16.8	UTCTimeSynchronization Service.....	336
16.9	Who-Has and I-Have Services.....	337
16.10	Who-Is and I-Am Services.....	339
17	VIRTUAL TERMINAL SERVICES.....	341
17.1	Virtual Terminal Model.....	341
17.2	VT-Open Service.....	345
17.3	VT-Close Service.....	347
17.4	VT-Data Service.....	348
17.5	Default-terminal Characteristics.....	350
18	ERROR, REJECT, and ABORT CODES.....	354
18.1	Error Class - DEVICE.....	354
18.2	Error Class - OBJECT.....	354
18.3	Error Class - PROPERTY.....	354
18.4	Error Class - RESOURCES.....	355
18.5	Error Class - SECURITY.....	355
18.6	Error Class - SERVICES.....	356
18.7	Error Class - VT.....	357
18.8	Reject Reason.....	357
18.9	Abort Reason.....	358
19	BACnet PROCEDURES.....	359
19.1	Backup and Restore.....	359
19.2	Command Prioritization.....	362
20	ENCODING BACnet PROTOCOL DATA UNITS.....	366
20.1	Encoding the Fixed Part of BACnet APDUs.....	366
20.2	Encoding the Variable Part of BACnet APDUs.....	376
21	FORMAL DESCRIPTION OF APPLICATION PROTOCOL DATA UNITS.....	390
22	CONFORMANCE AND INTEROPERABILITY.....	434
22.1	Conformance to BACnet.....	434
22.2	BACnet Interoperability.....	435
23	EXTENDING BACnet TO ACCOMMODATE VENDOR PROPRIETARY INFORMATION.....	437
23.1	Extending Enumeration Values.....	437
23.2	Using the PrivateTransfer Services to Invoke Non-Standardized Services.....	437
23.3	Adding Proprietary Properties to a Standardized Object.....	438
23.4	Adding Proprietary Object Types to BACnet.....	438
23.5	Restrictions on Extending BACnet.....	439
24	NETWORK SECURITY.....	440
24.1	Security Architecture.....	440
24.2	Authentication Mechanisms.....	441
24.3	Data Confidentiality Mechanism.....	443
24.4	RequestKey Service.....	444
24.5	Authenticate Service.....	445
25	REFERENCES.....	448
	ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE).....	450
	ANNEX B - GUIDE TO SPECIFYING BACnet DEVICES (INFORMATIVE).....	452
	ANNEX C - FORMAL DESCRIPTION OF OBJECT TYPE STRUCTURES (INFORMATIVE).....	453
	ANNEX D - EXAMPLES OF STANDARD OBJECT TYPES (INFORMATIVE).....	465
D.1	Example of an Accumulator Object.....	465

D.2	Example of an Analog Input Object	465
D.3	Example of an Analog Output Object.....	466
D.4	Example of an Analog Value Object	466
D.5	Example of an Averaging Object.....	467
D.6	Example of a Binary Input Object	467
D.7	Example of a Binary Output Object.....	468
D.8	Example of a Binary Value Object	469
D.9	Example of a Calendar Object	470
D.10	Example of a Command Object.....	470
D.11	Example of a Device Object	471
D.12	Example of an Event Enrollment Object.....	473
D.13	Example of a File Object	475
D.14	Example of a Group Object	475
D.15	Example of a Life Safety Point Object	475
D.16	Example of a Life Safety Zone Object	476
D.17	Example of a Loop Object	477
D.18	Example of a Multi-state Input Object	478
D.19	Example of a Multi-state Output Object.....	479
D.20	Example of a Multi-state Value Object	480
D.21	Example of a Notification Class Object	480
D.22	Example of a Program Object.....	480
D.23	Example of a Pulse Converter Object.....	482
D.24	Example of a Schedule Object.....	482
D.25	Example of a Trend Log Object.....	483
ANNEX E	- EXAMPLES OF BACnet APPLICATION SERVICES (INFORMATIVE)	485
E.1	Alarm and Event Services.....	485
E.2	File Access Services	489
E.3	Object Access Services	491
E.4	Remote Device Management Services	498
E.5	Virtual Terminal Services	501
E.6	Security Services.....	502
ANNEX F	- EXAMPLES OF APDU ENCODING (INFORMATIVE).....	504
F.1	Example Encodings for Alarm and Event Services.....	504
F.2	Example Encodings for File Access Services.....	513
F.3	Example Encodings for Object Access Services	515
F.4	Example Encodings for Remote Device Management Services	529
F.5	Example Encodings for Virtual Terminal Services	534
F.6	Example Encodings for Security Services.....	536
ANNEX G	- CALCULATION OF CRC (INFORMATIVE).....	538
G.1	Calculation of the Header CRC	538
G.2	Calculation of the Data CRC	544
ANNEX H	- COMBINING BACnet NETWORKS WITH NON-BACnet NETWORKS (NORMATIVE)	549
H.1	Mapping Non-BACnet Networks onto BACnet Routers	549
H.2	Multiple 'Virtual' BACnet Devices in a Single Physical Device.....	549
H.3	Using BACnet with the DARPA Internet Protocols.....	549
H.4	Using BACnet with the IPX Protocol.....	550
H.5	Using BACnet with EIB/KNX.....	552
ANNEX I	- COMMANDABLE PROPERTIES WITH MINIMUM ON AND OFF TIMES (INFORMATIVE).....	563
ANNEX J	- BACnet/IP (NORMATIVE)	565
J.1	General	565
J.2	BACnet Virtual Link Layer	565
J.3	BACnet/IP Directed Messages	569
J.4	BACnet/IP Broadcast Messages	569
J.5	Addition of Foreign B/IP Devices to an Existing B/IP Network.....	571
J.6	Routing Between B/IP and non-BP/IP BACnet Networks.....	572
J.7	Routing Between Two B/IP BACnet Networks	573
J.8	Use of IP Multicast within BACnet/IP	575

J.9	Sources for Internet Information.....	576
ANNEX K	- BACnet INTEROPERABILITY BUILDING BLOCKS (BIBBs) (NORMATIVE).....	577
K.1	Data Sharing BIBBs.....	577
K.1.1	BIBB - Data Sharing - ReadProperty - A (DS-RP-A).....	577
K.1.2	BIBB-Data Sharing-ReadProperty-B (DS-RP-B).....	577
K.1.3	BIBB - Data Sharing-ReadPropertyMultiple-A (DS-RPM-A).....	577
K.1.4	BIBB - Data Sharing-ReadPropertyMultiple-B (DS-RPM-B).....	577
K.1.5	BIBB - Data Sharing-ReadPropertyConditional-A (DS-RPC-A).....	577
K.1.6	BIBB - Data Sharing-ReadPropertyConditional-B (DS-RPC-B).....	578
K.1.7	BIBB - Data Sharing-WriteProperty-A (DS-WP-A).....	578
K.1.8	BIBB - Data Sharing-WriteProperty-B (DS-WP-B).....	578
K.1.9	BIBB - Data Sharing-WritePropertyMultiple-A (DS-WPM-A).....	578
K.1.10	BIBB - Data Sharing-WritePropertyMultiple-B (DS-WPM-B).....	578
K.1.11	BIBB - Data Sharing-COV-A (DS-COV-A).....	578
K.1.12	BIBB - Data Sharing-COV-B (DS-COV-B).....	579
K.1.13	BIBB - Data Sharing-COVP-A (DS-COVP-A).....	579
K.1.14	BIBB - Data Sharing-COVP-B (DS-COVP-B).....	579
K.1.15	BIBB - Data Sharing-COV-Unsolicited-A (DS-COVU-A).....	579
K.1.16	BIBB - Data Sharing-COV-Unsolicited-B (DS-COVU-B).....	579
K.2	Alarm and Event Management BIBBs.....	579
K.2.1	BIBB - Alarm and Event-Notification-A (AE-N-A).....	580
K.2.2	BIBB - Alarm and Event-Notification Internal-B (AE-N-I-B).....	580
K.2.3	BIBB - Alarm and Event-Notification External-B (AE-N-E-B).....	580
K.2.4	BIBB - Alarm and Event-ACK-A (AE-ACK-A).....	580
K.2.5	BIBB - Alarm and Event-ACK-B (AE-ACK-B).....	580
K.2.6	BIBB - Alarm and Event-Alarm Summary-A (AE-ASUM-A).....	580
K.2.7	BIBB - Alarm and Event-Alarm Summary-B (AE-ASUM-B).....	581
K.2.8	BIBB - Alarm and Event-Enrollment Summary-A (AE-ESUM-A).....	581
K.2.9	BIBB - Alarm and Event-Enrollment Summary-B (AE-ESUM-B).....	581
K.2.10	BIBB - Alarm and Event-Information-A (AE-INFO-A).....	581
K.2.11	BIBB - Alarm and Event-Information-B (AE-INFO-B).....	581
K.2.12	BIBB - Alarm and Event-LifeSafety-A (AE-LS-A).....	581
K.2.13	BIBB - Alarm and Event-LifeSafety-B (AE-LS-B).....	581
K.3	Scheduling BIBBs.....	582
K.3.1	BIBB - Scheduling-A (SCHED-A).....	582
K.3.2	BIBB - Scheduling-Internal-B (SCHED-I-B).....	582
K.3.3	BIBB - Scheduling-External-B (SCHED-E-B).....	582
K.4	Trending BIBBs.....	582
K.4.1	BIBB - Trending-Viewing and Modifying Trends-A (T-VMT-A).....	582
K.4.2	BIBB - Trending-Viewing and Modifying Trends Internal-B (T-VMT-I-B).....	582
K.4.3	BIBB - Trending-Viewing and Modifying Trends External-B (T-VMT-E-B).....	582
K.4.4	BIBB - Trending-Automated Trend Retrieval-A (T-ATR-A).....	583
K.4.5	BIBB - Trending-Automated Trend Retrieval-B (T-ATR-B).....	583
K.5	Device and Network Management BIBBs.....	583
K.5.1	BIBB - Device Management-Dynamic Device Binding-A (DM-DDB-A).....	583
K.5.2	BIBB - Device Management-Dynamic Device Binding-B (DM-DDB-B).....	583
K.5.3	BIBB - Device Management-Dynamic Object Binding-A (DM-DOB-A).....	584
K.5.4	BIBB - Device Management-Dynamic Object Binding-B (DM-DOB-B).....	584
K.5.5	BIBB - Device Management-DeviceCommunicationControl-A (DM-DCC-A).....	584
K.5.6	BIBB - Device Management-DeviceCommunicationControl-B (DM-DCC-B).....	584
K.5.7	BIBB - Device Management-Private Transfer-A (DM-PT-A).....	584
K.5.8	BIBB - Device Management-Private Transfer-B (DM-PT-B).....	584
K.5.9	BIBB - Device Management-Text Message-A (DM-TM-A).....	585
K.5.10	BIBB - Device Management-Text Message-B (DM-TM-B).....	585
K.5.11	BIBB - Device Management-TimeSynchronization-A (DM-TS-A).....	585
K.5.12	BIBB - Device Management-TimeSynchronization-B (DM-TS-B).....	585
K.5.13	BIBB - Device Management-UTCTimeSynchronization-A (DM-UTC-A).....	585

K.5.14	BIBB - Device Management-UTCTimeSynchronization-B (DM-UTC-B)	586
K.5.15	BIBB - Device Management-ReinitializeDevice-A (DM-RD-A)	586
K.5.16	BIBB - Device Management-ReinitializeDevice-B (DM-RD-B).....	586
K.5.17	BIBB - Device Management-Backup and Restore-A (DM-BR-A).....	586
K.5.18	BIBB - Device Management-Backup and Restore-B (DM-BR-B)	586
K.5.19	BIBB - Device Management-Restart-A (DM-R-A).....	587
K.5.20	BIBB - Device Management-Restart-B (DM-R-B).....	587
K.5.21	BIBB - Device Management-List Manipulation-A (DM-LM-A).....	587
K.5.22	BIBB - Device Management-List Manipulation-B (DM-LM-B)	587
K.5.23	BIBB - Device Management-Object Creation and Deletion-A (DM-OCD-A)	587
K.5.24	BIBB - Device Management-Object Creation and Deletion-B (DM-OCD-B)	588
K.5.25	BIBB - Device Management-Virtual Terminal-A (DM-VT-A).....	588
K.5.26	BIBB - Device Management-Virtual Terminal-B (DM-VT-B).....	588
K.5.27	BIBB - Network Management-Connection Establishment-A (NM-CE-A).....	588
K.5.28	BIBB - Network Management-Connection Establishment-B (NM-CE-B).....	588
K.5.29	BIBB - Network Management-Router Configuration-A (NM-RC-A)	589
K.5.30	BIBB - Network Management-Router Configuration-B (NM-RC-B).....	589
ANNEX L - DESCRIPTIONS AND PROFILES OF STANDARDIZED BACnet DEVICES (NORMATIVE).....		590
L.1	BACnet Operator Workstation (B-OWS).....	590
L.2	BACnet Building Controller (B-BC).....	590
L.3	BACnet Advanced Application Controller (B-AAC).....	591
L.4	BACnet Application Specific Controller (B-ASC)	591
L.5	BACnet Smart Actuator (B-SA).....	592
L.6	BACnet Smart Sensor (B-SS).....	592
L.7	Profiles of the Standard BACnet Devices.....	593
ANNEX M – GUIDE TO EVENT NOTIFICATION PRIORITY ASSIGNMENTS (INFORMATIVE)		594
M.1	Life Safety Message Group (0-31)	594
M.2	Property Safety Message Group (32-63)	595
M.3	Supervisory Message Group (64-95).....	595
M.4	Trouble Message Group (96-127).....	596
M.5	Miscellaneous Higher Priority Message Group (128-191).....	597
M.5	Miscellaneous Lower Priority Message Group (192-255)	597
HISTORY OF REVISIONS		598

FOREWORD

BACnet, the ASHRAE building automation and control networking protocol, has been designed specifically to meet the communication needs of building automation and control systems for applications such as heating, ventilating, and air-conditioning control, lighting control, access control, and fire detection systems. The BACnet protocol provides mechanisms by which computerized equipment of arbitrary function may exchange information, regardless of the particular building service it performs. As a result, the BACnet protocol may be used by head-end computers, general-purpose direct digital controllers, and application specific or unitary controllers with equal effect.

The motivation for this Standard was the widespread desire of building owners and operators for "interoperability," the ability to integrate equipment from different vendors into a coherent automation and control system - and to do so competitively. To accomplish this, the Standard Project Committee (SPC) solicited and received input from dozens of interested firms and individuals; reviewed all relevant national and international data communications standards, whether de facto or the result of committee activity; and spent countless hours in debate and discussion of the pros and cons of each element of the protocol.

What has emerged from the committee deliberations is a network protocol model with these principal characteristics:

(a) All network devices (except MS/TP slaves) are peers, but certain peers may have greater privileges and responsibilities than others.

(b) Each network device is modeled as a collection of network-accessible, named entities called "objects." Each object is characterized by a set of attributes or "properties." While this Standard prescribes the most widely applicable object types and their properties, implementors are free to create additional object types if desired. Because the object model can be easily extended, it provides a way for BACnet to evolve in a backward compatible manner as the technology and building needs change.

(c) Communication is accomplished by reading and writing the properties of particular objects and by the mutually acceptable execution of other protocol "services." While this Standard prescribes a comprehensive set of services, mechanisms are also provided for implementors to create additional services if desired.

(d) Because of this Standard's adherence to the ISO concept of a "layered" communication architecture, the same messages may be exchanged using various network access methods and physical media. This means that BACnet networks may be configured to meet a range of speed and throughput requirements with commensurately varying cost. Multiple BACnet networks can be interconnected within the same system forming an internetwork of arbitrarily large size. This flexibility also provides a way for BACnet to embrace new networking technologies as they are developed.

BACnet was designed to gracefully improve and evolve as both computer technology and demands of building automation systems change. Upon its original publication in 1995, a Standing Standards Project Committee was formed to deliberate enhancements to the protocol under ASHRAE rules for "continuous maintenance." Much has happened since the BACnet standard was first promulgated. BACnet has been translated into Chinese, Japanese, and Korean, and embraced across the globe. BACnet devices have been designed, built and deployed on all seven continents. Suggestions for enhancements and improvements have been continually received, deliberated, and, ultimately, subjected to the same consensus process that produced the original standard. This publication is the result of those deliberations and brings together all of the corrections, refinements, and improvements that have been adopted.

Among the features that have been added to BACnet are: increased capabilities to interconnect systems across wide area networks using internet protocols, new objects and services to support fire detection and other life safety applications, capabilities to backup and restore devices, standard ways to collect trend data, new tools to make specifying BACnet systems easier, a mechanism for making interoperable extensions to the standard visible, and many others. The successful addition of these features demonstrates that the concept of a protocol deliberately crafted to permit extension of its capabilities over time as technology and needs change is viable and sound.

All communication protocols are, in the end, a collection of arbitrary solutions to the problems of information exchange and all are subject to change as time and technology advance. BACnet is no exception. Still, it is the hope of those who have contributed their time, energies, and talents to this work that BACnet will help to fulfill, in the area of building automation and control, the promise of the information age for the public good!

This is a preview of "ANSI/ASHRAE 135-2004". [Click here to purchase the full version from the ANSI store.](#)

1 PURPOSE

The purpose of this standard is to define data communication services and protocols for computer equipment used for monitoring and control of HVAC&R and other building systems and to define, in addition, an abstract, object-oriented representation of information communicated between such equipment, thereby facilitating the application and use of digital control technology in buildings.

2 SCOPE

2.1 This protocol provides a comprehensive set of messages for conveying encoded binary, analog, and alphanumeric data between devices including, but not limited to:

- (a) hardware binary input and output values,
- (b) hardware analog input and output values,
- (c) software binary and analog values,
- (d) text string values,
- (e) schedule information,
- (f) alarm and event information,
- (g) files, and
- (h) control logic.

2.2 This protocol models each building automation and control computer as a collection of data structures called "objects," the properties of which represent various aspects of the hardware, software, and operation of the device. These objects provide a means of identifying and accessing information without requiring knowledge of the details of the device's internal design or configuration.

3 DEFINITIONS

3.1 Terms Adopted from International Standards

The following terms used in this standard are defined by international standards or draft standards for open system interconnection (OSI). The definitions are repeated here and a reference to the appropriate standard is provided. Clause 25 contains the titles of all national and international standards referenced in this clause and elsewhere in this standard. Words or phrases in italics refer to terms defined elsewhere in this clause.

3.1.1 abstract syntax: the specification of application layer data or *application-protocol-control-information* by using notation rules which are independent of the encoding technique used to represent them (ISO 8822).

3.1.2 application: a set of a USER's information processing requirements (ISO 8649).

3.1.3 application-entity: the aspects of an *application-process* pertinent to OSI (ISO 7498).

3.1.4 application-process: an element within a *real open system* which performs the information processing for a particular *application* (ISO 7498).

3.1.5 application-protocol-control-information: information exchanged between *application-entities*, using presentation services, to coordinate their joint operation (ISO 9545).

3.1.6 application-protocol-data-unit: a unit of data specified in an application protocol and consisting of *application-protocol-control-information* and possibly application-user-data (ISO 9545).

3.1.7 application-service-element: that part of an *application-entity* which provides an OSI environment capability, using underlying services when appropriate (ISO 7498).

3.1.8 concrete syntax: those aspects of the rules used in the formal specification of data which embody a specific representation of that data (ISO 7498).

3.1.9 peer-entities: *entities* within the same layer (ISO 7498).