


ANSI/ASHRAE Standard 136-1993 (RA 2006)
Reaffirmation of ANSI/ASHRAE Standard 136-1993



ASHRAE STANDARD

A Method of Determining Air Change Rates in Detached Dwellings

Approved by the ASHRAE Standards Committee on June 30, 1993, and reaffirmed on January 21, 2006; by the ASHRAE Board of Directors on July 1, 1993, and reaffirmed on January 26, 2006; and by the American National Standards Institute on August 18, 1993, and reaffirmed on January 27, 2006.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2006 ASHRAE, Inc.

ISSN 1041-2336

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at <http://www.ashrae.org>.



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE Standing Standard Project Committee 136
Cognizant TC: TC 4.03, Ventilation Requirements and Infiltration

David E. Knebel, Chair

Amanda K. Meitz

Richard A. Evans

Joseph A. Pietsch

John F. Hogan

J. Richard Wright

ASHRAE STANDARDS COMMITTEE 2005-2006

Richard D. Hermans, *Chair*
David E. Knebel, *Vice-Chair*
Donald L. Brandt
Steven T. Bushby
Paul W. Cabot
Hugh F. Crowther
Samuel D. Cummings, Jr.
Robert G. Doerr
Hakim Elmahdy
Roger L. Hedrick
John F. Hogan
Frank E. Jakob
Stephen D. Kennedy

Jay A. Kohler
James D. Lutz
Merle F. McBride
Mark P. Modera
Cyrus H. Nasser
Stephen V. Santoro
Stephen V. Skalko
David R. Tree
Jerry W. White, Jr.
James E. Woods
William E. Murphy, *BOD ExO*
Ronald E. Jarnagin, *CO*

Claire B. Ramspeck, *Assistant Director of Technology for Standards and Special Projects*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 136-1993 (RA 2006) A Method of Determining Air Change Rates in Detached Dwellings

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Determination of Effective Air Change Rate.....	2
5 References	6
Appendix A: Determination of Capacities of Supply and Exhaust Fans	6
Appendix B: Example Calculations.....	8
Appendix C: Bibliography	10

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at <http://www.ashrae.org>.

© Copyright 2006 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org

All rights reserved.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process.)

FOREWORD

This is a reaffirmation of ASHRAE Standard 136-1993. This standard falls under the Standards Committee classification of Standard Method of Measurement. This standard was prepared under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform standards throughout the industry.

The changes made for the 2006 reaffirmation were updates to the references.

1. PURPOSE

The purpose of this standard is to provide a procedure for determining effective outdoor air change rates in detached dwellings. This procedure is intended for use in evaluating the impact of these air change rates on indoor air quality.

2. SCOPE

2.1 The effective outdoor air change rates calculated by use of this standard

- a. are based on the use of measured air leakage data,
- b. include the effects of infiltration and mechanical ventilation,
- c. are annual average values, and
- d. apply only to detached single-family dwellings.

2.2 The effective outdoor air change rates determined by the use of this standard are not appropriate for use in estimating peak pollutant levels or energy loss due to infiltration.

2.3 This standard does not specify required air change rates nor take into account the additional infiltration that may result from opening windows and doors or the unintentional ventilation caused by operation of heating and cooling equipment.

3. DEFINITIONS

air change rate: the ratio of the volumetric rate at which air enters or leaves a building to the building volume with identical volume units (normally expressed in units of air changes per hour).

building volume: the volume of a building that exchanges air with outdoor (ambient) air. For the purposes of this standard, the building volume is the space that is deliberately conditioned for human comfort.

detached dwelling: a separate building composed of an interconnected series of rooms operated under a single tenancy, used as a domicile by one or more persons and containing cooking, eating, living, sleeping, and sanitary facilities.

effective air change rate: the constant outdoor air change rate that would result in the same average pollutant concentration

over the same period of time as actually occurs under varying conditions.

infiltration: the uncontrolled inward airflow through cracks and openings in the building envelope, caused by the pressure effects of wind and/or differences in indoor and outdoor air density. These openings in the building envelope may be intentional or unintentional, but flow through window and door openings is excluded.

mechanical ventilation: the process of supplying or removing air by mechanical means to or from any space. Such air may or may not have been conditioned. Mechanical means shall include ducts and vents driven by fans and/or blowers but shall exclude any device driven directly by wind action, such as turbine ventilators.

natural ventilation: ventilation using only natural motive forces, such as wind pressure or differences in air density. This takes into account airflow through all openings, including window and door openings.

normalized leakage: the dimensionless value calculated from the leakage area, building height, and floor area (using the method of ANSI/ASHRAE 119, *Air Leakage Performance for Detached Single-Family Residential Buildings*¹) that describes the relative tightness of the envelope.

outdoor air: air outside a building or taken from the external atmosphere and, therefore, not previously circulated through the ventilation system.

outdoor air change rate: the ratio of the volumetric rate at which outdoor air enters a building space to the building volume with identical volume units (normally expressed in units of air changes per hour).

ventilation: the process of supplying or removing air by natural or mechanical means to or from any space. Such air may or may not have been conditioned. For the purposes of this standard, ventilation shall be taken to mean the process of supplying outdoor air to or removing indoor air from a dwelling by natural or mechanical means.

4. DETERMINATION OF EFFECTIVE AIR CHANGE RATE

4.1 **Procedure for Calculation of Effective Air Change Rate.** The effective air change rate shall be calculated according to the procedures outlined in 4.2, 4.3, and 4.4.

4.2 **Ventilation by Infiltration.** The normalized leakage, L_n , shall be determined using the method of ANSI/ASHRAE 119, *Air Leakage Performance for Detached Single-Family Residential Buildings*.¹

The component of the effective air change rate due to infiltration, A_I (air changes per hour), shall be calculated using

$$A_I = L_n \times W$$

where W is a factor accounting for the effect of local weather. W is in air changes per hour.

Values of W are listed in Table 1 for many North American cities. For cities not included in Table 1, values of W may be estimated by using the value for the nearest location.