



STANDARD

ANSI/ASHRAE Standard 138-2013 (RA 2016)
(Reaffirmation of ANSI/ASHRAE Standard 138-2013)

Method of Testing for Rating Ceiling Panels for Sensible Heating and Cooling

Approved by ASHRAE on November 30, 2016, and by the American National Standards Institute on November 30, 2016.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2016 ASHRAE

ISSN 1041-2336



ASHRAE Standards Project Committee 138
Cognizant TC: 6.5, Radiant and In-Space Convective Heating and Cooling
SPLS Liaison: Roger L. Hedrick

Lawrence V. Drake, *Chair**
Mark Y. Ackerman*
Robert Bean
Kirby Chapman
Tylan H. Draper

Helmut E. Fuestel
Jaap Hogeling
Bírol I. Kilkis*
Michael P. O'Rourke*
William Shelley

Daniel Twa
Preston M. Twa
Richard D. Watson*

** Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2016–2017

Rita M. Harrold, *Chair*
Steven J. Emmerich, *Vice-Chair*
James D. Aswegan
Niels Bidstrup
Donald M. Brundage
Drury B. Crawley
John F. Dunlap,
James W. Earley, Jr.
Keith I. Emerson
Julie M. Ferguson

Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson
Roger L. Hedrick
Rick M. Heiden
Srinivas Katipamula
Cesar L. Lim
Arsen K. Melikov
R. Lee Millies, Jr.

Cyrus H. Nasser
David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Jack H. Zarour
William F. Walter, *BOD ExO*
Patricia Graef, *CO*

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 138-2013 (RA 2016), Method of Testing for Rating Ceiling Panels for Sensible Heating and Cooling

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Units of Measurement	2
4 Symbols.....	3
5 Definitions.....	5
6 Instruments and Measuring Standards.....	5
7 Standard Test Setup and the Equipment	6
8 Method of Conducting a Standard Test.....	10
9 Processing Test Data	12
10 Acceptance Criteria for the Standard Test.....	13
11 Reporting Standard Test Results.....	13
12 References	15
Normative Annex A—Adjustment of Panel Heat Flux.....	16
Normative Annex B—Line Fitting by the Method of Least Squares.....	17
Informative Annex C—Uncertainty Analysis of Panel Heat Flux	18
Informative Annex D—Calculating the Approximate Thermal Efficiency of the Test Panel.....	19
Informative Annex E—Provisions for Electric Panels and Calibration of the Test Chamber	20

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2016 ASHRAE

1791 Tullie Circle NE • Atlanta, GA 30329 • www.ashrae.org • All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Standard 138 establishes uniform methods of laboratory testing for rating the thermal performance of ceiling panels manufactured for radiant panel heating and cooling of indoor spaces. This standard covers steady-state testing of ceiling panels at panel surface temperatures from 24°C to 65°C (75°F to 149°F) for nonmetal heat transfer elements in the ceiling panel or from 24°C to 150°C (75°F to 302°F) for metal heat transfer elements in the ceiling panel. Sensible cooling ceiling panels are tested from 14°C to 24°C (57°F to 75°F). This standard provides correction factors with respect to defined test conditions for the size of the test room, barometric pressure in the test location, and average air velocity in the vicinity of the test panels in order to ensure repeatable test results.

This is a reaffirmation of Standard 138-2013. This standard was prepared under the auspices of ASHRAE. It may be used in whole or in part by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interest of obtaining uniform guidelines throughout the industry. This version of the reaffirmation has no changes.

1. PURPOSE

This standard establishes uniform methods of laboratory testing for rating steady-state thermal performance of ceiling panels used in indoor spaces for sensible heating, sensible cooling, or both. The objective is to rate ceiling panels under repeatable conditions.

2. SCOPE

2.1 This standard specifies procedures, apparatus, and instrumentation for rating thermal performance of ceiling panels in a specific indoor configuration and thermal conditions.

2.2 Thermal performance of a ceiling panel is measured in terms of heat delivered or heat removed by the ceiling panel as a function of the average fluid temperature of the heat transfer medium in the ceiling panel and the temperatures characterizing the surrounding indoor space.

2.3 This standard covers testing of ceiling panels in the following effective panel surface high and low temperature range limits:

- **Sensible Heating Ceiling Panels:** from 24°C to 65°C (75°F to 149°F) for nonmetal heat transfer elements in the ceiling panel or from 24°C to 150°C (75°F to 302°F) for metal heat transfer elements in the ceiling panel.

- **Sensible Cooling Ceiling Panels:** from 14°C to 24°C (57°F to 75°F).

2.4 This standard does not cover the following ceiling panels:

- Hybrid (combined thermal radiation and forced-convection: load-sharing) ceiling panels.
- Ceiling panels that are embedded into the ceiling, wall, or floor structure.
- Test methods for design, production, or field-testing of ceiling panels.

3. UNITS OF MEASUREMENT

3.1 System of Units. In this standard, the International System of Units (SI) is used. Inch-pound (I-P) units are shown parenthetically. Values shall be based on the National Institute of Standards and Technology (NIST) values, which, in turn, are based on the fundamental values of the International Bureau of Weights and Measures.

3.2 Basic Units. The unit of length is meter, designated m (foot or inch, designated ft or in.). The unit of mass is the kilogram, designated kg (pound, designated lb), and the unit of time is second or hour, designated s or h. The unit of temperature is degree Celsius, designated °C (degree Fahrenheit, designated °F), or kelvin, designated K (degree rankine, designated °R). The unit of force is the newton, designated N (pound-force, designated lbf).

3.3 Derived Units

3.3.1 Velocity and Acceleration. The unit of velocity is m/s (ft/s). The unit of acceleration is m/s² (ft/s²).

3.3.2 Surface Area. The unit of surface area is m² (ft²).

3.3.3 Volume Flow Rate. The unit of volume flow rate is cubic meter (foot) per second, m³/s (ft³/s).

3.3.4 Pressure. The unit of pressure is pascal, designated Pa, or kilopascal, kPa (pound-force per square foot, designated lbf/ft²).

3.3.5 Energy, Work, and Power. The unit of energy and work is joule, designated J (British thermal unit, designated Btu). The unit of power is watt, designated W (British thermal unit per hour, designated Btu/h).

3.3.6 Heat Flux. The unit of heat flux is W/m² (Btu/[h·ft²]).

3.3.7 Thermal Resistance. The unit of thermal resistance is m²·K/W (h·ft²·°F/Btu).

3.3.8 Mass Density. The unit of mass density is kilogram per cubic meter, kg/m³ (pound per cubic foot, lb/ft³).

3.3.9 Dynamic Viscosity and Kinematic Viscosity. The unit of dynamic viscosity is Pa·s (lbf/[ft·s]). The unit of kinematic viscosity is m²/s (ft²/s).

3.3.10 Specific Heat. The unit of specific heat is J/(kg·K) (Btu/[lb·°F]).