


**ANSI/ASHRAE Standard 146-2006**  
**(Supersedes ANSI/ASHRAE Standard 146-1998)**



# ASHRAE STANDARD

## Methods of Testing and Rating Pool Heaters

Approved by the ASHRAE Standards Committee on June 24, 2006; by the ASHRAE Board of Directors on June 29, 2006; and by the American National Standards Institute on June 30, 2006.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2006 ASHRAE, Inc.

ISSN 1041-2336



[www.ansi.org](http://www.ansi.org)

**American Society of Heating, Refrigerating  
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

[www.ashrae.org](http://www.ashrae.org)

**ASHRAE Standard Project Committee 146**  
**Cognizant TC: TC 6.6, Service Water Heating**  
**SPLS Liaison: James E. Woods**

R. Michael Martin, *Chair\**  
Albert R. Barfield\*  
Titu R. Doctor\*  
Robert E. Hamos\*  
Henry Hwong\*

Shamel A. Kassab\*  
Alexander B. Lekov\*  
Frank Myers\*  
Mark W. Paquette\*  
Bodh R. Subherwal\*  
Dave Sutula\*

*\*Denotes members of voting status when the document was approved for publication*

---

**ASHRAE STANDARDS COMMITTEE 2005–2006**

Richard D. Hermans, *Chair*  
David E. Knebel, *Vice-Chair*  
Donald L. Brandt  
Steven T. Bushby  
Paul W. Cabot  
Hugh F. Crowther  
Samuel D. Cummings, Jr.  
Robert G. Doerr  
Hakim Elmahdy  
Roger L. Hedrick  
John F. Hogan  
Frank E. Jakob  
Stephen D. Kennedy

Jay A. Kohler  
James D. Lutz  
Merle F. McBride  
Mark P. Modera  
Cyrus H. Nasser  
Stephen V. Santoro  
Stephen V. Skalko  
David R. Tree  
Jerry W. White, Jr.  
James E. Woods  
William E. Murphy, *BOD ExO*  
Ronald E. Jarnagin, *CO*

Claire B. Ramspeck, *Assistant Director of Technology for Standards and Special Projects*

---

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

## CONTENTS

### ANSI/ASHRAE Standard 146-2006 Methods of Testing and Rating Pool Heaters

SECTION	PAGE
Foreword.....	2
1 Purpose .....	2
2 Scope .....	2
3 Definitions.....	2
4 Classifications.....	2
5 Requirements .....	2
6 Instruments.....	2
7 Apparatus .....	3
8 Methods of Testing .....	6
9 Test Procedures .....	8
10 Data to Be Recorded .....	9
11 Calculation of Results.....	9
12 Reference Properties.....	11
13 References .....	11
Appendix A: Correction Factor for Heating Value of Fuel Gas .....	11
Appendix B: Concurrent Water Meter Calibration.....	12
Appendix C: Optional Verification Test .....	12
Appendix D: Bibliography .....	15

#### NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at <http://www.ashrae.org>.

© Copyright 2006 American Society of Heating,  
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE  
Atlanta, GA 30329  
[www.ashrae.org](http://www.ashrae.org)

All rights reserved.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

## FOREWORD

Originally published in 1998, Standard 146 prescribes uniform methods of testing and rating pool heaters and comes under the classification of an ASHRAE Standard Method of Measurement or Test. It applies to all pool heaters operated by gas, oil, or electricity, including heat pumps using ambient air as a heat source.

This revision of the standard makes a number of major changes to the way heat pump pool heaters are tested.

### 1. PURPOSE

The purpose of this standard is to provide methods of testing and rating pool heaters.

### 2. SCOPE

**2.1** This standard provides methods of testing for heating capacity and energy efficiency.

**2.2** This standard applies to heaters operated by gas, oil, or electricity, including heat pumps using ambient air as a heat source.

### 3. DEFINITIONS

**apparatus:** as used in this standard, test room facilities and instrumentation.

**coefficient of performance (COP):** as applied to a heat pump, the ratio of heat output in kilowatts (Btu/h) to the total power input in kilowatts (Btu/h).

**coil, outdoor:** the heat exchanger that absorbs heat from the outdoor air.

**equipment:** as used in this standard, the equipment to be tested.

**heat output:** the rate at which heat is passed to the water in kilowatts (Btu/h) under specified conditions of operation.

**heating capacity:** the rate at which heat is passed to the water in kilowatts (Btu/h) when the pool heater is operating at rated input and achieving the rated thermal efficiency or COP.

**pool heater:** equipment designed for heating nonpotable water contained at atmospheric pressure in swimming pools, spas, hot tubs, and similar applications.

**rated input:** the energy-using capacity of a pool heater, as specified by the manufacturer and as specified in Section 8 of this standard.

**standard conditions:** the conditions of temperature and pressure at which the higher heating value of gas is reported,

namely, 15.556°C (60°F) and 101.325 kPa (29.921 in. of mercury).

**standard COP:** the ratio of heat output in kilowatts (Btu/h) to total power input in kilowatts (Btu/h) as defined when a heat pump pool heater is operating at standard rating conditions.

**standard rating conditions:** the temperature, pressure, and water-flow-rate conditions (specified in Section 8) at which the pool heater input and efficiency are reported.

**thermal efficiency:** the ratio of heat output in kilowatts (Btu/h) to total power input in kilowatts (Btu/h) when a gas-fired, oil-fired, or electrical-resistance pool heater is operated at specific conditions.

**total power input:** for electrical pool heaters, the total electrical input to the equipment in kilowatts.

## 4. CLASSIFICATION

Pool heaters are classified by energy source and include

- a. gas-fired pool heaters;
- b. oil-fired pool heaters;
- c. air-to-water heat pump pool heaters employing a compressor, water-cooled condenser, and outdoor air coil in a single-package assembly; and
- d. electric resistance pool heaters.

## 5. REQUIREMENTS

The pool heaters for which compliance with this standard is claimed shall be tested and calculations made to verify capacity and efficiency using the following procedures as appropriate:

- a. a steady-state heating capacity test for a pool heater at standard rating conditions;
- b. a steady-state efficiency test for a gas, oil, and electric resistance pool heater or coefficient of performance (COP) for a heat pump pool heater;
- c. a standby energy consumption test for all pool heaters except heat pump pool heaters.

## 6. INSTRUMENTS

**6.1 General.** Instruments are required for the following measurements with the minimum precision noted. Instruments shall be calibrated at a minimum of once a year. A record shall be kept containing, as a minimum, the date of calibration, the method of calibration, and the reference standard used.

**6.2 Temperature.** Temperature-measuring devices and any associated instrumentation systems shall be in accordance with *ASHRAE Standard 41.1-1986 (RA 2006), Standard Method for Temperature Measurement*.<sup>1</sup> Measurement of water temperature shall be to an accuracy corresponding to 1.0% or less of the temperature rise with the exception of heat pump pool heaters, for which the accuracy shall correspond to 0.03°C (0.05°F) or less of the temperature rise.