


ANSI/ASHRAE Standard 158.2-2006



ASHRAE STANDARD

Methods of Testing Capacity of Refrigerant Pressure Regulators

Approved by the ASHRAE Standards Committee on June 24, 2006; by the ASHRAE Board of Directors on June 29, 2006; and by the American National Standards Institute on June 30, 2006.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2006 ASHRAE, Inc.

ISSN 1041-2336



www.ansi.org

**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE Standard Project Committee 158.2
Cognizant TC: TC 8.8, Refrigerant System Controls and Accessories
SPLS Liaison: Robert G. Doerr

Dennis A. Littwin, *Chair**
Charles N. Bald
Richard J. Buck*
Frederic D. Colsoul*
David C. Dorste
Virgil T. Gulley*
Robert A. Jones*

Frank Latuda
Peter G. Malone*
Michael J. Noble*
Ernest W. Schumacher*
John J. Sluga
Jim Zheng*
Nicholas G. Zupp

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2005–2006

Richard D. Hermans, *Chair*
David E. Knebel, *Vice-Chair*
Donald L. Brandt
Steven T. Bushby
Paul W. Cabot
Hugh F. Crowther
Samuel D. Cummings, Jr.
Robert G. Doerr
Hakim Elmahdy
Roger L. Hedrick
John F. Hogan
Frank E. Jakob
Stephen D. Kennedy

Jay A. Kohler
James D. Lutz
Merle F. McBride
Mark P. Modera
Cyrus H. Nasser
Stephen V. Santoro
Stephen V. Skalko
David R. Tree
Jerry W. White, Jr.
James E. Woods
William E. Murphy, *BOD ExO*
Ronald E. Jarnagin, *CO*

Claire B. Ramspeck, *Assistant Director of Technology for Standards and Special Projects*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 158.2-2006 Methods of Testing Capacity of Refrigerant Pressure Regulators

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions and Symbols.....	2
4 Instrumentation.....	3
5 General Piping Specifications.....	3
6 Data to be Reported	4
7 Test Conditions.....	4
8 Test Procedure	4
9 Incompressible Flow Regime Capacity Calculations.....	6
10 Compressible Flow Regime Capacity Calculations.....	6
11 Choked Flow Regime Capacity Calculations.....	6
12 References	7
Appendix A: Example Tables, Data Sheets, and Graphs.....	7
Appendix B: Example of Computation to Express Regulator Capacity in Terms of Refrigerating Effect.....	12

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at <http://www.ashrae.org>.

© Copyright 2006 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org

All rights reserved.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This standard was written at the request of the Air Conditioning & Refrigeration Institute (ARI) to provide a standard method of test for the capacity of refrigerant pressure regulators. It is anticipated that ARI will revise their Standard 770, Refrigerant Pressure Regulating Valves, to require this standard be used as a method of test for capacity. It is further anticipated that ARI will continue to maintain Standard 770 as it relates to standard methods of rating refrigerant service pressure regulators. ARI 770 may also include information concerning other refrigerant pressure regulator performance characteristics.

The basis for the method of testing and calculation of capacity for flow through regulators is a research project (PRF 5233) performed at the Ray W. Herrick Laboratories, Purdue University, Lafayette, Indiana, and sponsored by ARI. This research followed a study performed at Herrick Laboratories, under ARI auspices, by R.T. McKenzie, J.B. Chaddock, and W.E. Fontaine between September 1963 and September 1966.

This standard provides a means of accurately measuring the refrigerant mass flow capacity of regulators. The flow capacity may be expressed in terms of refrigerating effect with various refrigerants by performing simple thermodynamic computations. Examples of the computations necessary to express regulator capacity in kW (tons) or other appropriate dimensions are included in Appendix B to this standard for the user's convenience.

1. PURPOSE

This standard provides methods of determining the mass flow capacity of refrigerant pressure regulators with sufficient accuracy to facilitate proper engineering application of the device in systems operating at various conditions with various refrigerants by

- a. prescribing a method of measuring key flow and gradient characteristics of refrigerant pressure regulators using air or water as the working fluid and
- b. prescribing computational means to enable reliable prediction of refrigerant vapor and liquid mass flow capacity based on the measured flow and gradient characteristics.

2. SCOPE

2.1 This standard applies to refrigerant pressure regulators that meet the definition found in Section 3, "Definitions," and

that are intended for refrigerant service in applications where only single-phase flow occurs within the regulator.

2.2 This standard is applicable to refrigerant pressure regulators in the following circumstances:

- a. for use in either liquid or vapor refrigerant applications and
- b. for use with refrigerants deemed suitable according to *ANSI/ASHRAE Standard 15-2004, Safety Standard for Refrigeration Systems*¹ and *ANSI/ASHRAE Standard 34-2004, Designation and Safety Classification of Refrigerants*.²

2.3 This standard specifies procedures, apparatus, and instrumentation that will produce capacity and gradient information sufficiently accurate to apply the device tested.

2.4 This standard does not do the following:

- a. specify rating conditions or electrical or mechanical design requirements (rating conditions may be found in *ARI Standard 770, Refrigerant Pressure Regulating Valves*³),
- b. make recommendations for safety, or
- c. specify tests for production, specification compliance, or field testing of regulators.

3. DEFINITIONS AND SYMBOLS

3.1 Definitions

capacity: the mass flow rate of a selected refrigerant that will pass through the regulator at specified conditions.

certified standard instrument: an instrument calibrated by the manufacturer or other reliable agency and certified traceable to the National Institute for Standards and Technology (NIST).

controlled parameter: as used in this standard, this term refers to the system pressure that is regulated by the regulator under test.

controlled parameter change (CPC): the difference between the setpoint and regulated pressure when the regulator is operating at a specified capacity.⁴ (See Figure A-1 in Appendix A.)

direct-operated pressure regulator: a throttling valve of any size that responds directly to changes in its regulated pressure. A change in regulated pressure (CPC) provides all the work necessary to position the closure member of the valve.

flowmeter: a device for determining the mass flow rate through the regulator under test.

gradient: the change in regulated pressure (controlled parameter) required to cause the closure member of a refrigerant pressure regulator to move from its opening point (setpoint) to a specified flow capacity.⁴

pilot-operated pressure regulator: a relatively large throttling valve in which a smaller direct-operated pressure regulator