



STANDARD

ANSI/ASHRAE Standard 169-2020

(Supersedes ANSI/ASHRAE Standard 169-2013)

Includes ANSI/ASHRAE addenda listed in Appendix C

Climatic Data for Building Design Standards

See Appendix C for approval dates.

This Standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the Standard. Instructions for how to submit a change can be found on the ASHRAE[®] website (<https://www.ashrae.org/continuous-maintenance>).

The latest edition of an ASHRAE Standard may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway NW, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2020 ASHRAE

ISSN 1041-2336



Includes Web-based access to climatic data, design conditions, figures, and tables.
(Requires Adobe Acrobat[®] and Microsoft Excel[®])

Cognizant TC: 4.2, Climate Information
SPLS Liaison: Walter Grondzik

Drury B. Crawley*, *Chair*
Joshua New*, *Vice-Chair*
Parag Rastogi*, *Secretary*
Riad G. Assaf*

Evyatar Erell
Jack N. Lott
Robert J. Morris
Michael Roth*

Didier J. Thevenard*
Russell Vose*
Justin Wong

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2020–2021

Drury B. Crawley, *Chair*
Rick M. Heiden, *Vice Chair*
Els Baert
Charles S. Barnaby
Robert B. Burkhead
Thomas E. Cappellin
Douglas D. Fick
Walter T. Grondzik
Susanna S. Hanson
Jonathan Humble

Srinivas Katipamula
Gerald J. Kettler
Essam E. Khalil
Malcolm D. Knight
Jay A. Kohler
Larry Kouma
Cesar L. Lim
James D. Lutz
Karl L. Peterman
Erick A. Phelps

David Robin
Lawrence J. Schoen
Steven C. Sill
Richard T. Swierczyna
Christian R. Taber
Russell C. Tharp
Theresa A. Weston
Craig P. Wray
Jaap Hogeling, *BOD ExO*
William F. McQuade, *CO*

Connor Barbaree, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS
ANSI/ASHRAE Standard 169-2020
Climatic Data for Building Design Standards

SECTION	PAGE
Foreword	2
1 Purpose.....	2
2 Scope.....	2
3 Definitions, Abbreviations, and Acronyms.....	2
4 Climatic Design Data and Climate Zones	3
5 Climate Zone Maps.....	4
Normative Appendix A: Climatic Design Data and Climate Zones.....	5
Informative Appendix B: Climate Zone Maps.....	243
Informative Appendix C: Addenda Description.....	258
Online Supporting Files: www.ashrae.org/169-2020	

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2020 ASHRAE

180 Technology Parkway NW · Peachtree Corners, GA 30092 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Standard 169 provides a comprehensive source of climate data for those involved in building design. It has been established to provide a variety of climatic information used primarily for the design, planning, and sizing of buildings' energy systems and equipment. This standard is referenced in other ASHRAE standards, such as Standards 90.1, 90.2, and 189.1.

The data presented in this standard are compiled from the 2017 ASHRAE Handbook—Fundamentals, Chapter 14, "Climatic Design Information," and other data developed specifically for this standard through ASHRAE RP-1699, "Updating the ASHRAE Climatic Data for Design and Standards."

The data and tables have been completely revised and updated from the 2013 edition. The standard now also includes the weather and shielding factor (WSF) required in Standard 62.2-2016, as well as data for 8118 locations throughout the world, an increase of 2554.

1. PURPOSE

This standard provides recognized climatic data for use in building design and related equipment standards.

2. SCOPE

2.1 This standard covers climatic data used in ASHRAE standards, including dry-bulb, dew-point, and wet-bulb temperatures, enthalpy, humidity ratio, wind conditions, solar irradiation, latitude, longitude, and elevation for locations worldwide.

2.2 This standard also includes statistical data, such as mean temperatures, average temperatures, mean/median annual extremes, daily ranges, heating and cooling degree-days and degree hours, hours and seasonal percentages within ranges of temperatures, as well as bins.

3. DEFINITIONS, ABBREVIATIONS, AND ACRONYMS

3.1 Definitions

degree-day: the difference in temperature between the outdoor mean temperature over a 24-hour period and a given base temperature. The classifications are defined as follows:

cooling degree-day base 50°F, CDD50 (10°C, CDD10): for any one day, when the mean temperature is more than 50°F (10°C), there are as many degree-days as degrees Fahrenheit or Celsius temperature difference between the mean temperature for the day and 50°F (10°C) (mean temperature minus 50°F [10°C]). Annual cooling degree-days (CDDs) are the sum of the degree-days over a calendar year.

heating degree-day base 65°F, HDD65 (18.3°C, HDD18): for any one day, when the mean temperature is less than 65°F (18.3°C), there are as many degree-days as degrees Fahrenheit or Celsius temperature difference between and 65°F (18.3°C) and the mean temperature for the day (65°F [18.3°C] minus the mean temperature). Annual heating degree-days (HDDs) are the sum of the degree-days over a calendar year.

3.2 Abbreviations and Acronyms

CDD_n	=	cooling degree-days base $n^\circ\text{F}$, $^\circ\text{F}\cdot\text{day}$ ($n^\circ\text{C}$, $^\circ\text{C}\cdot\text{day}$)
CDH_n	=	cooling degree-hours base $n^\circ\text{F}$, $^\circ\text{F}\cdot\text{h}$ ($n^\circ\text{C}$, $^\circ\text{C}\cdot\text{h}$)
CZ	=	climate zone
DB	=	dry-bulb temperature, $^\circ\text{F}$ ($^\circ\text{C}$)
DBAvg	=	average daily dry-bulb temperature, $^\circ\text{F}$ ($^\circ\text{C}$)
DBSD	=	standard deviation of average daily dry-bulb temperature, $^\circ\text{F}$ ($^\circ\text{C}$)
DP	=	dew-point temperature, $^\circ\text{F}$ ($^\circ\text{C}$)
$E_{bn,noon}$	=	clear-sky beam normal irradiance at solar noon, Btu/h/ft^2 (W/m^2)