

ANSI/ASHRAE Standard 17-2008 (Supersedes ANSI/ASHRAE Standard 17-1998 [RA 2003])



# Method of Testing Capacity of Thermostatic Refrigerant Expansion Valves

Approved by the ASHRAE Standards Committee on January 19, 2008; by the ASHRAE Board of Directors on January 23, 2008; and by the American National Standards Institute on January 24, 2008.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2008 ASHRAE

ISSN 1041-2336



American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE, Atlanta, GA 30329 www.ashrae.org

## ASHRAE Standard Project Committee 17-1998 Cognizant TC: 8.8, Refrigerant System Controls and Accessories Standards Project Committee Liaison: Thomas E. Watson

Richard J. Buck,\* *Chair* Dawood A. Ali,\* *Vice Chair* Peter G. Malone,\* *Secretary* Larry D. Cummings Eugene A. Dianetti\* Albert A. Domingorena\* David C. Dorste Sung L. Kwon\* Frank Latuda Dennis A. Littwin\* Lawrence J. Loman\* Ernest W. Schumacher\* Elmer J. Subera\* Nicholas G. Zupp\*

\* Denotes members of voting status when the document was previously approved for publication

## STANDARDS REAFFIRMATION SUBCOMMITTEE 2007–2008\*

James Lutz, *Chair* Michael Beda Steven Bushby R. Michael Martin Bodh Subherwal James Woods

\* For the 2008 revision in which minor changes were performed (i.e., updating references), SRS acted as the consensus project committee.

#### ASHRAE STANDARDS COMMITTEE 2007–2008

Stephen D. Kennedy, *Chair* Hugh F. Crowther, *Vice-Chair* Robert G. Baker Michael F. Beda Donald L. Brandt Steven T. Bushby Paul W. Cabot Kenneth W. Cooper Samuel D. Cummings, Jr. K. William Dean Robert G. Doerr Roger L. Hedrick Eli P. Howard, III Frank E. Jakob Nadar R. Jayaraman Byron W. Jones Jay A. Kohler James D. Lutz Carol E. Marriott R. Michael Martin Merle F. McBride Frank Meyers H. Michael Newman Lawrence J. Schoen Bodh R. Subherwal Jerry W. White, Jr. Bjarne W. Olesen, *BOD ExO* Lynn G. Bellenger, *CO* 

Claire B. Ramspeck, Assistant Director of Technology for Standards and Special Projects

## SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

#### DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

#### ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

This is a preview of "ANSI/ASHRAE 17-2008". Click here to purchase the full version from the ANSI store.

## CONTENTS

# ANSI/ASHRAE Standard 17-2008, Method of Testing Capacity of Thermostatic Refrigerant Expansion Valves

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions	2
4 Conditions for Testing Capacity	
5 Data Required for Reporting Capacity	
6 Test Instruments	
7 Test Apparatus	4
8 Test Procedure	4
9 Capacity Calculation	5
10 References	5
Informative Appendix A	6

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at http://www.ashrae.org.

© Copyright 2008 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. 1791 Tullie Circle NE Atlanta, GA 30329 www.ashrae.org All rights reserved. (This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

## FOREWORD

This is a revision of ANSI/ASHRAE Standard 17-1998 (RA 2003).

This standard was prepared under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). It may be used in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform standards throughout the industry.

This standard prescribes a method of testing capacity of thermostatic expansion valves for use in air-conditioning and refrigeration systems. This standard does not specify the test conditions to be used for obtaining the standard rating. That is done in a rating standard developed by the Air-Conditioning and Refrigeration Institute (ARI). The latest edition of ARI Standard 750 is referenced for the test conditions to be used in obtaining standard ratings for thermostatic refrigerant expanding valves.

The changes made for the 2008 revision are as follows:

- references were numbered
- references were updated

## 1. PURPOSE

This standard prescribes a method of testing the capacity of thermostatic refrigerant expansion valves for use in vaporcompression refrigeration systems.

## 2. SCOPE

- 2.1 This standard is applicable to
- a. thermostatic expansion valves (also referred to in this standard as expansion valves) as defined in Section 3, "Definitions,"
- b. expansion valves of the direct-acting type but not the pilot-operated type, and
- c. many currently used refrigerants deemed available and suitable according to *ANSI/ASHRAE Standard 15*<sup>1</sup> and *ANSI/ASHRAE Standard 34*.<sup>2</sup>

**2.2** This standard specifies procedures, apparatus, and instrumentation that will produce accurate capacity data.

- 2.3 This standard does not
- a. specify tests for production, specification compliance, or field testing of expansion valves, nor
- b. specify capacity rating conditions for testing expansion valves. These may be found in *ARI Standard* 750.<sup>3</sup>

# 3. DEFINITIONS

The following definitions apply only to parts and terms used in this standard.

*capacity of an expansion valve:* the refrigerating effect in kW (Btu/h or tons) of refrigeration, produced by the mass flow of refrigerant that will pass through the valve under the conditions that are cited in Section 5.

*certified standard instrument:* an instrument calibrated by the manufacturer or other reliable agency and certified as traceable to the National Institute of Standards and Technology (NIST).

*direct-acting valve:* an expansion valve designed so that the valve plug opens the valve port in inverse response to sensed equalizer pressure and in direct response to temperature-sensing element temperature. The valve plug is positioned through direct mechanical linkage to the actuating element (e.g., diaphragm or bellows).

evaporator: an evaporatively cooled heat exchanger.

*external equalizer:* in a thermostatic expansion valve, a connection from a selected point in the low-pressure part of the circuit to the system pressure-sensing side of the actuating element such that the selected point pressure is transmitted to the actuating element (e.g., diaphragm or bellows).

*initial valve opening:* a minimal valve opening position not to exceed 0.05 mm (0.002 in.).

*internal equalizer:* in a thermostatic expansion valve, an integral internal port or passage whereby the system pressuresensing side of the actuating element (e.g., diaphragm or bellows) is exposed to valve outlet pressure.

*liquid refrigerant flowmeter:* a device for determining the refrigerant mass flow rate.

*nominal capacity:* the capacity reported by the manufacturer for an expansion valve, citing ANSI/ARI Standard  $750^3$  for the test conditions.

*operating superheat:* the difference between the temperature at the temperature-sensing element and the system refrigerant vapor saturation temperature corresponding to the valve equalizer pressure.

*permanent bleed rate:* the capacity of the permanent bleed provision under the conditions cited in Section 5, expressed either as a percentage of the nominal capacity or in kW (Btu/h or tons) of refrigerating effect produced by the evaporation of that amount of refrigerant flow.

*permanent bleed-type valve:* a valve that has a fixed flow passage incapable of being closed by action of the valve. Such a fixed orifice permits a flow through or in parallel with the main valve port.

*pilot-operated valve:* expansion valve of a type used on large capacity systems (e.g., direct-expansion chillers) where the required capacity per valve is beyond the range of direct-acting valves; this type of valve is under the control of a direct-acting valve.