



ANSI/ASHRAE Standard 22-2003

ASHRAE[®] STANDARD

Methods of Testing for Rating Water- Cooled Refrigerant Condensers

Approved by the ASHRAE Standards Committee January 29, 2003; by the ASHRAE Board of Directors January 30, 2003; and by the American National Standards Institute April 22, 2003.

ASHRAE Standards are updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in U.S. and Canada).

©Copyright 2003 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336

When addenda or interpretations to this standard have been approved, they can be downloaded free of charge from the ASHRAE web site at <http://xp20.ashrae.org/standards/addenda.htm> or <http://xp20.ashrae.org/standards/intpstd.htm>.



**AMERICAN SOCIETY OF HEATING,
REFRIGERATING AND
AIR-CONDITIONING ENGINEERS, INC.**

1791 Tullie Circle, NE • Atlanta, GA 30329

ASHRAE Standard Project Committee 22
Cognizant TC: TC 8.5, Liquid-to-Refrigerant Heat Exchangers

Fred C. Sheidman, *Chair**

Robert R. Miller*

Arthur G. Fovargue*

Joesph T. Pearson*

Harold B. Ginder*

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2002-2003

Thomas E. Watson, *Chair*
Van D. Baxter, *Vice-Chair*
Charles G. Arnold
Dean S. Borges
Paul W. Cabot
Charles W. Coward, Jr.
Brian P. Dougherty
Hakim Elmahdy
Arthur D. Hallstrom
Matt R. Hargan
Richard D. Hermans
Stephen D. Kennedy

David E. Knebel
Frederick H. Kohloss
William J. Landman
Merle F. McBride
Ross D. Montgomery
Cyrus H. Nasser
Davor Novosel
Dennis A. Stanke
Michael H. Tavares
Steven T. Taylor
David R. Tree
Terry E. Townsend, *CO*
Maureen Grasso, *ExO*

Claire B. Ramspeck, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 22-2003, Methods of Testing for Rating Water-Cooled Refrigerant Condensers

| SECTION | PAGE |
|--|------|
| Foreword..... | 2 |
| 1 Purpose | 2 |
| 2 Scope | 2 |
| 3 Definition of Terms..... | 2 |
| 4 Expression of Test Results..... | 2 |
| 5 Test Methods..... | 2 |
| 6 Instruments and Test Apparatus | 4 |
| 7 Test Procedure | 5 |
| 8 References | 6 |

© Copyright 2003 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org

All rights reserved.

(This foreword is not part of this standard but is included for information purposes only.)

FOREWORD

This standard prescribes methods for testing water-cooled refrigerant condensers. To attain this objective, the standard lists and defines the terms suggested for rating water-cooled refrigerant condensers and establishes testing methods that may be used as a basis for obtaining ratings of water-cooled refrigerant condensers.

This standard is a reaffirmation of Standard 22-1992, but because the ANSI approval for the 1992 revision expired, the current reaffirmed version of the standard has been approved by ANSI as a "new" standard. In the near future there will be a call to form a new project committee, and Standard 22 will be revised at that time to include any substantive changes that are needed.

1. PURPOSE

This standard prescribes methods of testing the thermal performance of water-cooled refrigerant condensers.

2. SCOPE

To attain this objective, this standard

- (a) lists and defines the terms suggested for the rating of water-cooled refrigerant condensers and
- (b) establishes methods of test that can be used as a basis for obtaining ratings of water-cooled refrigerant condensers.

3. DEFINITION OF TERMS

condensing heat rejection (q_c): the portion of the total heat rejection of a condenser that is used for desuperheating and condensing the entering refrigerant vapor to a saturated liquid. This is the product of the mass rate of refrigerant flow (w_r) and the difference between the enthalpy of the entering refrigerant vapor and that of the saturated refrigerant liquid at the leaving pressure.

subcooling heat rejection (q_s): the total heat rejection minus the condensing heat rejection. This is the product of the mass rate of refrigerant flow (w_r) and the difference between the enthalpy of a saturated refrigerant liquid at the pressure of the leaving refrigerant and that of the refrigerant liquid at the actual leaving temperature.

total heat rejection (q_t): the total useful capacity of a water-cooled refrigerant condenser for removing heat from the refrigerant circulated through it. This is the product of the mass rate of refrigerant flow (w_r) and the difference of enthalpy of the entering and leaving refrigerant fluid.

water-cooled refrigerant condenser: a factory-made assembly of elements by which the flows of refrigerant vapor and water are maintained in such a heat transfer relationship that the refrigerant vapor is condensed into a liquid.

4. EXPRESSION OF TEST RESULTS

4.1 Terms Recommended for Expressing Test Results

4.1.1 In expressing test results, the following factors should be stated:

- (a) condensing heat rejection (q_c), Btu/h (kW),
- (b) subcooling heat rejection (q_s), Btu/h (kW),
- (c) saturated temperature of entering refrigerant vapor, °F (°C),
- (d) temperature of entering water, °F (°C),
- (e) water mass flow rate (w_w), lbm/h (kg/s), and
- (f) water pressure drop through condenser, psi (kPa).

5. TEST METHODS

5.1 Standard Test Methods

5.1.1 Tests shall consist of a primary test and a simultaneous confirming test at the conditions specified.

5.1.2 Specified conditions will include

- (a) either the total heat rejection, Btu/h (kW), or the saturated temperature of entering refrigerant vapor, °F (°C),
- (b) temperature of entering water, °F (°C),
- (c) water mass flow rate, lbm/h (kg/s),
- (d) minimum superheat of entering vapor, °R (K),
- (e) minimum ambient temperature, °F (°C),
- (f) subcooling, °F (°C), and
- (g) refrigerant used.

5.1.3 The results of the confirming test shall be within 3% of the primary test, but the primary test shall govern for rating purposes.

5.1.4 Refrigerant flow through the condenser shall be produced by one of the following means (see Figures 1a and 1b):

- (a) refrigerating compressor and low-side evaporator or calorimeter (preferred method) or
- (b) refrigerant boiler.

5.2 Primary Test Methods

5.2.1 The primary test for closed condensers (see Figure 2) shall consist of determination of the heat rejected from the refrigerant by

- (a) measurement of heat rejected to the water and
- (b) calculation of heat rejected through the external surfaces of the condenser to the ambient air.

5.2.2 The heat rejected from the refrigerant to the water is the product of the water flow rate and the enthalpy difference of the leaving and entering water.

5.2.3 The water flow rate shall be determined by use of a water quantity meter, water flow meter, or weigh tank.

5.2.4 The enthalpy difference between the leaving and entering water shall be determined from temperature measurements.

5.2.5 The heat rejected through the external surfaces to the ambient air shall be determined by

$$q_L = U_s A_s (t_c - t_a) \quad (1)$$