

STANDARD



ANSI/ASHRAE Standard 29-2015 (RA 2018)
(Supersedes ANSI/ASHRAE Standard 29-2009)

Method of Testing Automatic Ice Makers

Approved by ASHRAE and by the American National Standards Institute on October 29, 2018.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2018 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 29
Cognizant TC: 10.7, Commercial Food and Beverage Refrigeration Equipment
SPLS Liaison: Wayne H. Stoppelmoor, Jr.

Daryl G. Erbs*, Chair
David B. Cowen*
James R. Frantz*
Brian A. Fricke*

Randall J. Haseman*
Thomas M. Lasecki*
Denis Livchak*
Howard A. Ricketts*

Stephen Schaefer*
Bodh R. Subherwal*
Sarah Widder*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2018–2019

Donald M. Brundage, Chair
Wayne H. Stoppelmoor, Jr., Vice-Chair
Els Baert
Charles S. Barnaby
Niels Bidstrup
Robert B. Burkhead
Michael D. Corbat
Drury B. Crawley
Julie M. Ferguson
Michael W. Gallagher

Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson
Roger L. Hedrick
Rick M. Heiden
Jonathan Humble
Kwang Woo Kim
Larry Kouma
R. Lee Millies, Jr.
Karl L. Peterman

Erick A. Phelps
David Robin
Lawrence J. Schoen
Dennis A. Stanke
Richard T. Swierczyna
Russell C. Tharp
Adrienne G. Thomle
Craig P. Wray
Lawrence C. Markel, BOD ExO
Michael CA Schwedler, CO

Steven C. Ferguson, Senior Manager of Standards

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 29-2015 (RA 2018) Method of Testing Automatic Ice Makers

SECTION	PAGE
Foreword	2
1 Purpose.....	2
2 Scope.....	2
3 Definitions	2
4 Classification.....	2
5 Instruments and Apparatus	2
6 Test Methods	3
7 Test Procedures.....	3
8 Data to Be Reported	4
9 Calculation of Results	4
Normative Annex A: Method of Calorimetry	6
Informative Annex B: Bibliography	9

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2018 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE Standard 29 was first published in 1988 and was reaffirmed in 1999 and 2005 and revised in 2009 and 2015.

The 2015 revision incorporated a clarification in Section 5 to instrumentation, test equipment, and data acquisition. Detail was added to Section 6 for water and air-temperature requirements during test. More specific instruction was provided in Section 7 for ice capacity determination sampling. Finally, revisions were added to Normative Annex A for determination of calorimeter constant and heat of fusion for ice product for continuous-type ice makers.

This is a reaffirmation of Standard 29-2015. This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. This reaffirmation updates references in Informative Annex B.

1. PURPOSE

This standard prescribes a method of testing automatic ice makers by

- a. specifying procedures to be used when testing automatic ice makers,
- b. establishing the types of equipment to which the provisions of the standard apply,
- c. defining terms describing the equipment covered and terms related to testing,
- d. specifying the type of instrumentation and test apparatus required in testing,
- e. specifying a uniform method for calculation of results, and
- f. specifying data and results to be recorded.

2. SCOPE

This standard does not include automatic ice makers installed in household refrigerators, combination refrigerator-freezers, and household freezers.

3. DEFINITIONS

automatic ice maker: a factory-made assembly consisting of a condensing unit and ice-making section operating as an integrated unit, with means for making and harvesting ice. It may also include means for storing or dispensing ice, or both. The automatic ice maker may be composed of one or more sections for shipping purposes.

batch-type ice maker: an ice maker having alternate freezing and harvesting periods. Also referred to as a *cube-type ice maker*.

continuous-type ice maker: an ice maker that continually freezes and harvests ice at the same time.

dump water: water drainage from an ice maker to control the clarity of ice or to prevent scaling.

pure ice: ice made by using water with less than 5 ppm of solids concentration.

4. CLASSIFICATION

4.1 Method of Rejecting Heat

- 4.1.1 Water-cooled condenser.
- 4.1.2 Air-cooled condenser.

4.2 Type of Ice Harvested

4.2.1 Ice in irregular shapes of chips, flakes, ribbons, or wafers.

4.2.2 Uniformly shaped ice of not over 56 g (2 oz).

5. INSTRUMENTS AND APPARATUS

5.1 Test Room

5.1.1 Ambient Temperature. With the ice maker at rest, the vertical ambient temperature gradient in any metre (foot) of vertical distance from 51 mm (2 in.) above the floor or supporting platform to a height of 2.1 m (7 ft), or to a height of 0.3 m (1 ft) above the top of the cabinet within the clearances specified in Section 6.5, whichever is greater, shall not exceed 0.91°C/m (0.5°F/ft).

5.1.2 Air Circulation. With the ice maker at rest, ambient air movement created by any source external to the unit shall not impinge upon the air inlet openings with a velocity greater than 0.25 m/s (50 fpm).

5.1.3 Test Room Operation. No changes to the test room shall be made during operation of the ice maker under test that would impact the vertical ambient temperature gradient or the ambient air movement specified in Sections 5.1.1 and 5.1.2.

5.2 Temperature-Measuring Instruments

5.2.1 Types. Temperature shall be measured with instruments of a type having the specified accuracies at the temperatures of use.

5.2.2 Accuracy and readability each shall be within $\pm 0.56^{\circ}\text{C}$ (1.0°F).

5.2.3 Where accuracy greater than $\pm 0.56^{\circ}\text{C}$ (1.0°F) is specified, the instrument shall be calibrated by comparison with a certified standard in the range of use or shall itself be certified as to accuracy, and the resolution shall be at least equal to the accuracy requirement unless otherwise specified.

5.3 Electrical Instruments

5.3.1 Accuracy and readability shall each be within $\pm 2.0\%$ of the quantity measured.

5.3.2 Input power shall be measured with an integrating watt-hour meter graduated to 0.01 kWh.