



**STANDARD**

**ANSI/ASHRAE Standard 37-2009 (RA 2019)**  
(Reaffirmation of ANSI/ASHRAE Standard 37-2009)

# **Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat-Pump Equipment**

Approved by ASHRAE and the American National Standards Institute on June 21, 2019.

ASHRAE® Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2019 ASHRAE

ISSN 1041-2336



**ASHRAE Standard Project Committee 37**  
**Cognizant TC: 8.11, Unitary and Room Air Conditioners and Heat Pumps**  
**SPLS Liaison: Matt R. Hargan**

Alberto A. da Rosa\*, *Chair*  
Greg S. Bennett  
Darryl Denton\*

Piotr A. Domanski  
Brian P. Dougherty\*  
Byron F. Horak\*

H. Michael Hughes\*  
Birol I. Kilkis\*  
Arvo Lannus

\* Denotes members of voting status when the document was approved for publication

---

**ASHRAE STANDARDS COMMITTEE 2018–2019**

Donald M. Brundage, *Chair*  
Wayne H. Stoppelmoor, Jr., *Vice-Chair*  
Els Baert  
Charles S. Barnaby  
Niels Bidstrup  
Robert B. Burkhead  
Michael D. Corbat  
Drury B. Crawley  
Julie M. Ferguson  
Michael W. Gallagher

Walter T. Grondzik  
Vinod P. Gupta  
Susanna S. Hanson  
Roger L. Hedrick  
Rick M. Heiden  
Jonathan Humble  
Kwang Woo Kim  
Larry Kouma  
R. Lee Millies, Jr.  
Karl L. Peterman

Erick A. Phelps  
David Robin  
Lawrence J. Schoen  
Dennis A. Stanke  
Richard T. Swierczyna  
Rusty Tharp  
Adrienne G. Thomle  
Craig P. Wray  
Lawrence C. Markel, *BOD ExO*  
Michael CA Schwedler, *CO*

Steven C. Ferguson, *Senior Manager of Standards*

---

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

---

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

---

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

## CONTENTS

### ANSI/ASHRAE Standard 37-2009 (RA 2019) Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat-Pump Equipment

SECTION	PAGE
Foreword .....	2
1 Purpose .....	2
2 Scope .....	2
3 Definitions .....	2
4 Classifications .....	2
5 Instruments .....	2
6 Airflow and Air Differential Pressure Measurement Apparatus .....	3
7 Methods of Testing and Calculation .....	8
8 Test Procedures .....	17
9 Data to be Recorded .....	22
10 Test Results .....	22
11 Symbols used in Equations .....	24
12 Reference Properties and Data .....	25
13 References .....	25
Informative Appendix A: Classifications of Unitary Air Conditioners and Heat Pumps .....	27

#### NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at [www.ashrae.org/technology](http://www.ashrae.org/technology).

© 2019 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · [www.ashrae.org](http://www.ashrae.org) · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.  
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

## FOREWORD

*This is a reaffirmation of Standard 37-2009. This standard was prepared under the auspices of the ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. This 2019 reaffirmation includes no substantive changes to the standard.*

## 1. PURPOSE

**1.1** The purpose of this standard is to provide test methods for determining the cooling capacity of unitary air conditioning equipment and the cooling or heating capacities, or both, of unitary heat-pump equipment.

**1.2** These test methods do not specify methods of establishing ratings that involve factors such as manufacturing tolerances and quality control procedures.

## 2. SCOPE

**2.1** This standard applies to electrically driven mechanical-compression unitary air conditioners and heat pumps consisting of one or more assemblies that include an indoor air coil(s), a compressor(s), and an outdoor coil(s). Where such equipment is provided in more than one assembly, the separated assemblies are designed to be used together.

**2.2** This standard does not include methods of testing the following:

- a. Cooling coils for separate use
- b. Condensing units for separate use
- c. Room air conditioners
- d. Heat-operated unitary equipment
- e. Liquid chilling packages
- f. Multiple indoor air coils operating simultaneously in heating and cooling modes

## 3. DEFINITIONS

**air, standard:** dry air having a mass density of 1.204 kg/m<sup>3</sup> (0.075 lb/ft<sup>3</sup>).

**apparatus:** as used in this standard, this term refers exclusively to test room facilities and instrumentation.

**capacity, heating:** the rate, expressed in watts (Btu/h), at which the equipment adds heat to the air passing through it under specified conditions of operation.

**capacity, latent cooling:** the rate, expressed in watts (Btu/h), at which the equipment removes latent heat from the air passing through it under specified conditions of operation.

**capacity, sensible cooling:** the rate, expressed in watts (Btu/h), at which the equipment removes sensible heat from the air passing through it under specified conditions of operation.

**capacity, total cooling:** the rate, expressed in watts (Btu/h), at which the equipment removes heat from the air passing through it under specified conditions of operation.

**coil, indoor:** the heat exchanger that removes heat from or adds heat to the conditioned space.

**coil, outdoor:** the heat exchanger that rejects heat to or absorbs heat from a source external to the conditioned space.

**equipment:** as used in this standard, this term refers exclusively to the unitary equipment to be tested.

**equipment, unitary:** this term shall be defined as provided in Section 2 and Section 4.

**indoor side:** that part of the system that removes heat from or adds heat to the indoor airstream.

**outdoor side:** that part of the system that rejects heat to or absorbs heat from a source external to the indoor airstream.

**pressure, standard barometric:** 101.325 kPa (14.696 psi).

**refrigerant, volatile:** a refrigerant that changes from the liquid to the vapor state in the process of absorbing heat.

**shall:** where “shall” or “shall not” is used for a provision, that provision is mandatory if compliance with the standard is claimed.

**should, recommended, or it is recommended:** “should,” “recommended,” or “it is recommended” are used to indicate provisions that are not mandatory but that are desirable as a good practice.

## 4. CLASSIFICATIONS

Unitary equipment within the scope of this standard may be classified as follows:

### 4.1 Component Arrangement

- a. Units employing compressor(s), indoor air coil(s), and outdoor coil(s) in a single package assembly
- b. Units employing compressor(s) and indoor coil(s) in one or more assemblies with remote outdoor coil(s)
- c. Units employing indoor coil assemblies, with outdoor coil(s) and compressor(s) in one or more assemblies

### 4.2 Method of Outdoor Coil Heat Exchange

- a. Air
- b. Liquid
- c. Evaporative cooled condensing

**Note:** Related Air-Conditioning and Refrigeration Institute (ARI) classifications for unitary air conditioners and heat pumps are given in Tables A-1 and A-2, respectively, in Appendix A, and are illustrative but not restrictive.

## 5. INSTRUMENTS

### 5.1 Temperature Measuring Instruments

**5.1.1** All temperature measurements (with the exception of dew point temperature) shall be made in accordance with ANSI/ASHRAE Standard 41.1.<sup>1</sup>