

Standard 58-1986 (RA 99)
Method of Testing for Rating Room Air Conditioner and
Packaged Terminal Air Conditioner Heating Capacity

ASHRAE Standards Project Committee 58-1986

Ronald R. Huffman, *Chair*

David M. Lapychak

W. Robert Nussdorfer

George J. Premaza

James P. Schafer

Richard F. Sharp

Mark W. Paquette

David A. Didion

Kenneth C. Schaible

L. Andrew Maciula

ASHRAE STANDARDS COMMITTEE 1998-99

Michael R. Bilderbeck, *Chair*

Arthur E. McIvor, *Vice-Chair*

George F. Carscallen

Waller S. Clements

Piotr A. Domanski

Richard A. Evans

Mark C. Hegberg

Martha J. Hewett

Douglas C. Hittle

Frederick H. Kohloss

William J. Landman

Rodney H. Lewis

Nance C. Lovvorn

Amanda K. Meitz

Davor Novosel

Joseph A. Pietsch

James A. Ranfone

Gaylon Richardson

Ganesan Sundaresan

Thomas E. Watson

Bruce A. Wilcox

J. Richard Wright

James E. Woods, *BOD ExO*

Ronald P. Vallort, *CO*

Claire Ramspeck, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE 58-1986 (RA 99) Method of Testing for Rating Room Air Conditioner and Packaged Terminal Air Conditioner Heating Capacity

SECTION	PAGE
Foreword	
1 Purpose	2
2 Scope.....	2
3 Definitions.....	2
4 Classifications.....	2
5 Instruments.....	2
5.1 Temperature-Measuring Instruments.....	2
5.2 Pressure-Making Instruments.....	3
5.3 Airflow and External Resistance Measuring Instruments.....	3
5.4 Electricity-Measuring Instruments.....	3
5.5 Water Flow-Measuring Instruments.....	3
5.6 Other Instruments.....	3
6 Apparatus	3
6.1 Test Room Requirements.....	3
6.2 Air Conditioner Installation.....	3
6.3 Air Tunnel.....	4
6.4 Pressure-Equalizing Apparatus.....	4
6.5 Airflow-Measuring Apparatus.....	4
6.6 Nozzles.....	6
6.7 Air-Sampling Apparatus.....	7
7 Test Procedures	7
7.1 Airflow Measurements.....	7
7.2 Temperature and Steam Pressure Measurements.....	7
7.3 Heating Capacity Test.....	8
8 Data to be Recorded.....	8
9 Calculation of Test Results	8
10 Test Report.....	10
11 References	10
Appendix A, Bibliography.....	10

(This foreword is not a part of this standard but is included for information only.)

FOREWORD

The need for metrication and advances in instrumentation have created a need for updating this standard. In addition, the class of products known as "packaged terminal air conditioners" has been included. This standard comes under the classification of ASHRAE Standard Method of Measurement or Test. It is a revision of a standard originally issued in 1965 and last revised in 1974.

1. PURPOSE

The purpose of this standard is to prescribe test methods for determining the heating capacities and airflow quantities for room air conditioners and packaged terminal air conditioners equipped with means for room heating.

2. SCOPE

2.1 This standard

- (a) establishes a uniform method of testing for obtaining rating data,
- (b) specifies test equipment for performing such tests,
- (c) specifies data required and calculations to be used, and
- (d) lists and defines the terms used in testing.

2.2 For purposes of this standard, room air conditioners and packaged terminal air conditioners are defined in Section 3, "Definitions."

2.3 This standard does not prescribe methods of testing to obtain cooling capacities of room air conditioners or packaged terminal air conditioners.

3. DEFINITIONS

accuracy of readings: where percentage limits of readings are herein given, the reference basis is the magnitude of the greater quantity measured and not the scale of the instrument.

heat pump room air conditioner/heat pump packaged terminal air conditioner: a room air conditioner or packaged terminal air conditioner that employs a means for reversing the function of the indoor and outdoor coils such that the indoor coil becomes the refrigerating system condenser, allowing for heating of the air in the conditioned space; similarly, the outdoor coil becomes the evaporator, utilizing outdoor air as a source of heat.

heating capacity: the rate, expressed in Btu/h (W), at which the equipment adds heat to the air passing through it under specified conditions of operation.

indoor air-enthalpy test method: a procedure for determining heating capacity in Btu/h (W) that involves measurement of the quality of air entering and leaving and the airflow rate and the air-enthalpy change.

indoor coil: the heat exchanger that removes heat from or adds heat to the conditioned space.

outdoor coil: the heat exchanger that rejects heat to or absorbs heat from a source external to the conditioned space.

packaged terminal air conditioner: a factory-selected combination of heating and cooling components, assemblies, or

sections, including a primary source of refrigeration and dehumidification, intended to serve an individual room or zone.

qualification test: a procedure employed for verifying the accuracy of the measuring techniques (temperature, airflow rates, duct heat calibration) employed in determination of room heating effect. This qualification procedure is periodically employed in determining room heating effect.

room air conditioner: an encased assembly designed as a unit primarily for mounting in a window, through a wall, or as a console. It is designed primarily to provide free delivery of conditioned air to an enclosed space, room, or zone. It includes a primary source of refrigeration and dehumidification, means for air circulation, air cleaning, and heating, and may include means for ventilation and humidification.

standard air: air having a density of 0.075 lb/ft³ (1.202 kg/m³) and equivalent to dry air at a temperature of 70°F (21.1°C) and a barometric pressure of 29.92 in. Hg (101 kPa).

standard barometric pressure: 29.92 in. Hg (101 kPa).

4. CLASSIFICATIONS

4.1 Two basic types of product are considered in this standard, as seen in the title, scope, and definitions: room air conditioners and packaged terminal air conditioners. For the purpose of conciseness throughout the body of the text, the general term "air conditioner" will be used.

4.2 Two types of heating means commonly are employed in these products: electrical resistance and heat pump (reverse cycle). Additional means include steam and hot water.

4.3 There are two basic methods of testing heat pump units: steady-state (no defrosting) and transient (with defrost cycles required).

4.4 There are two basic heating capacity calculations: the specific heat method for no moisture change and the enthalpy method when moisture is added.

5. INSTRUMENTS

5.1 Temperature-Measuring Instruments

5.1.1 Temperature measurement and temperature-measuring instruments shall be in accordance with the latest issue of ASHRAE Standard 41.1, the standard measurements guide.¹

5.1.2 Instrument accuracy shall be within the following limits:

- (1) wet- and dry-bulb temperatures, $\pm 1^\circ\text{F} (\pm 0.05^\circ\text{C})$, except for those instruments employed specifically for the defrost period, $\pm 0.5^\circ\text{F} (\pm 0.28^\circ\text{C})$;
- (2) water temperatures, $\pm 0.1^\circ\text{F} (\pm 0.05^\circ\text{C})$; and
- (3) all other temperatures, $\pm 0.5^\circ\text{F} (\pm 0.28^\circ\text{C})$.

5.1.3 In no case shall the smallest scale division of the temperature-measuring instrument exceed twice the specified accuracy. For example, for the specified accuracy of $\pm 0.1^\circ\text{F} (\pm 0.05^\circ\text{C})$, the smallest scale division shall not exceed $0.2^\circ\text{F} (0.11^\circ\text{C})$.

5.1.4 When instrument accuracy closer than $\pm 0.5^\circ\text{F} (\pm 0.28^\circ\text{C})$ is specified, the instrument shall be calibrated by