

STANDARD

ANSI/ASHRAE/ACCA Standard 183-2007 (RA 2017)

(Reaffirmation of ANSI/ASHRAE/ACCA Standard 183-2007)

Peak Cooling and Heating Load Calculations in Buildings Except Low-Rise Residential Buildings

Approved by ASHRAE on October 31, 2017; by the Air Conditioning Contractors of America on October 11, 2017; and by the American National Standards Institute on November 1, 2017.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2017 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 183
Cognizant TC: 4.1, Load Calculation Data and Procedures
SPLS Liaison: Ross D. Montgomery

Christopher K. Wilkins*, *Chair*
Phil D. Forner*, *Vice-Chair*
Constantinos A. Balaras*
Steven F. Bruning*
Terry L. Cornell*

Robert C. Doeffinger, Jr.*
Glenn Friedman*
Patricia E. Jones*
Curtis O. Pedersen
James F. Pegues*

Henry T. Rutkowski*
John Sedine*
Jonathan C. Spreeman*
Arunkumar T. Vedhathiri*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2017–2018

Steven J. Emmerich, *Chair*
Donald M. Brundage, *Vice-Chair*
Niels Bidstrup
Michael D. Corbat
Drury B. Crawley
Julie M. Ferguson
Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson

Roger L. Hedrick
Rick M. Heiden
Jonathan Humble
Srinivas Katipamula
Kwang Woo Kim
Larry Kouma
Arsen K. Melikov
R. Lee Millies, Jr.
Karl L. Peterman
Erick A. Phelps

David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Richard T. Swierczyna
Jack H. Zarour
Lawrence C. Markel, *BOD ExO*
M. Ginger Scoggins, *CO*

Stephen C. Ferguson, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE/ACCA Standard 183-2007 (RA 2017), Peak Cooling and Heating Load Calculations in Buildings Except Low-Rise Residential Buildings

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions, Abbreviations, and Acronyms	2
4 Compliance.....	3
5 Weather Data and Indoor Design Conditions	3
6 Cooling Load Method	4
7 External Heat Gains	4
8 Internal Heat Gains.....	4
9 Heating Load	4
10 System Cooling and Heating Loads	4
Informative Appendix A: Choice of Methods.....	5
Informative Appendix B: Recommended ASHRAE/ACCA Compliance Form for Standard 183-2007	6

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2017 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not a part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Standard 183 was created in a collaborative effort between ASHRAE and ACCA, the Air Conditioning Contractors of America. It establishes minimum requirements for performing peak cooling and heating load calculations for buildings except low-rise residential buildings. Although there are many methods available to perform peak cooling and heating load calculations, the intent of this standard is to establish a minimum level of requirements that is as inclusive of as many methods as possible while still being restrictive enough to mandate an appropriate level of care and accuracy. An accurate estimate of peak cooling or heating load requires not only that a sound method be used but also that inputs to the method are reasonable and realistic (the execution of the method).

The heat transfer interactions that occur outside and inside a conditioned building are complex and involve many interrelated variables. All load calculation methods therefore involve some level of simplification of the actual interactions among these variables to allow practical solutions to these very complex problems. The requirements in this standard that relate to the load calculation method are technical to the extent that they address these simplifications of the fundamental heat transfer interactions. If a method oversimplifies the problem, then an inaccurate load estimate can result. Complying with this standard requires knowledge of the underlying principles of the methods used and the techniques that these methods use to address the fundamental heat transfer interactions.

There is a distinction in this standard between zone load and system load. This standard is intended to address the calculation of zone load, but it is impossible to completely decouple the system load or capacity calculation from the zone load calculation. Systems and the processes to calculate their loads or capacities vary dramatically. Some aspects of the overall approach to systems are included in this standard, but the standard is not intended to be a comprehensive or detailed discussion of how to calculate system loads. Users of this standard are cautioned not to confuse zone heat gain with system sizing.

This is a reaffirmation of Standard 183-2007. This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. This version of the reaffirmation includes an updated reference to Informative Appendix A.

1. PURPOSE

This standard establishes requirements for performing peak cooling and heating load calculations for buildings except low-rise residential buildings.

2. SCOPE

This standard sets minimum requirements for methods and procedures used to perform peak cooling and heating load calculations for buildings except low-rise residential buildings.

3. DEFINITIONS, ABBREVIATIONS, AND ACRONYMS

3.1 Terms Defined in this Standard

beam solar: the component of solar radiation received from the sun without being scattered by the atmosphere or reflected by other surfaces.

building location: for purposes of load calculation, the building's latitude and longitude or the country, state, and city.

convective heat gain: the portion of a heat gain that is transferred by convection to air inside a building.

cooling load: a general term used to refer to the sensible and latent cooling load of a zone or an HVAC system.

diffuse solar: the component of solar radiation composed of the sky diffuse and ground diffuse solar flux.

design conditions: for outdoor conditions, the air temperature, humidity, and solar flux values used to calculate cooling and heating loads. For indoor conditions, the air temperature and/or humidity requirements for a zone or a building.

diversity: adjustments to internal heat gains made to account for the fact that the instantaneous heat output of all load-producing items (i.e., occupants, lighting, appliances, devices, equipment) is normally less than the maximum output for the same set of items. The instantaneous load is discounted for factors such as on-off cycles, occupancy schedules, duty cycles, and reduced power input.

fenestration: windows, skylights, and doors. Fenestration is typically composed of multiple components or assemblies, such as framing, glazing, dividers, and mullions.

flux: energy flow rate per unit surface area.

ground diffuse solar: the component of solar radiation received after being reflected by ground surfaces surrounding a building.

heat gain: the rate at which heat enters a surface, an airstream, or a zone. Heat gain is classified by its mode (convective or radiant) and by whether it is a sensible or latent gain. The radiant portion of heat gain becomes cooling load by a conversion process over time that causes a delay between the time the heat gain occurs and the time the heat is converted to cooling load.

heating load: for zones, the rate at which heat must be added to maintain indoor design conditions. For systems, the rate at