

STANDARD

ANSI/ASHRAE/ASHE Standard 170-2013
(Supersedes ANSI/ASHRAE/ASHE Standard 170-2008)
Includes ANSI/ASHRAE/ASHE addenda listed in Appendix C

Ventilation of Health Care Facilities

See Appendix C for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, the ASHE Board of Directors, and the American National Standards Institute.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site (www.ashrae.org) or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE Web site (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2013 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 170
Cognizant TC: TC 9.6, Healthcare Facilities
SPLS Liaison 2011-2013: Douglass S. Abramson
SPLS Liaison 2009-2011: Byron W. Jones
SPLS Liaison 2008-2009: William F. Walter

Paul T. Ninomura, *Chair*
Chris P. Rousseau, *Co-Vice Chair and Secretary*
Michael P. Sheerin, *Co-Vice Chair*
Judene M. Bartley*
Theodore Cohen
John M. Dombrowski
Douglas S. Erickson
James (Skip) Gregory

Hamid Habibi
Jeffery M. Hardin
Richard D. Hermans
Michael R. Keen
Marvin L. Kloostra
Peter H. Langowski
Michael F. Mamayek
Farhad Memarzadeh

Richard D. Moeller
Tyler Ninomura
Russell N. Olmsted
Heather L. Platt
Anand K. Seth
Rajendra N. Shah
Gordon P. Sharp
Andrew J. Streifel
Michael E. Woolsey

**This edition is dedicated to our friend and colleague, Judene Bartley. This Standard benefited tremendously from her insight and tireless contributions regarding healthcare infection prevention.*

ASHRAE STANDARDS COMMITTEE 2013–2014

William F. Walter, *Chair*
Richard L. Hall, *Vice-Chair*
Karim Amrane
Joseph R. Anderson
James Dale Aswegan
Charles S. Barnaby
Steven F. Bruning
John A. Clark
Waller S. Clements
David R. Conover

John F. Dunlap
James W. Earley, Jr.
Steven J. Emmerich
Julie M. Ferguson
Krishnan Gowri
Cecily M. Grzywacz
Rita M. Harrold
Adam W. Hinge
Debra H. Kennoy
Malcolm D. Knight

Rick A. Larson
Mark P. Modera
Cyrus H. Nasser
Janice C. Peterson
Heather L. Platt
Douglas T. Reindl
Julia A. Keen, *BOD ExO*
Thomas E. Werkema, Jr., *CO*

Stephanie C. Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS
ANSI/ASHRAE/ASHE Standard 170-2013,
Ventilation of Health Care Facilities

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions	2
4 Compliance	3
5 Planning	4
6 Systems and Equipment	4
7 Space Ventilation	7
8 Planning, Construction, and System Startup	13
9 Normative References	14
Informative Appendix A—Operations and Maintenance Procedures	15
Informative Appendix B—Informative References and Bibliography	16
Informative Appendix C—Addenda Description Information	17

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2013 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ANSI/ASHRAE/ASHE Standard 170, Ventilation of Health Care Facilities, is one of a family of documents that offers guidance, regulation, and mandates to designers of health care facilities. It is first and foremost a mandatory minimum requirement and, as such, may not always offer the state-of-the-art best practice for health care ventilation design. Other publications, such as the ASHRAE HVAC Design Manual for Hospitals and Clinics, 2nd Edition, complement the standard, providing additional depth and detail for the designer. In addition, the health care designer must refer to any design requirements from the appropriate jurisdiction that has authority. Many jurisdictions use or refer to Guidelines for Design and Construction of Health Care Facilities, published by the Facility Guidelines Institute (FGI). Where practical, the committee was cognizant of these other documents in the development of this standard.

Ventilation design for health care spaces is a combination of tasks that leads to a set of documents used in construction. One such task requires medical planners to develop departmental programs of spaces. These programs include space names that suggest the use for which the space is intended, and health care ventilation designers depend upon these names to determine the ventilation parameters for their designs. This standard provides these ventilation parameters.

Ventilation systems and designs for health care facilities are intended to provide a comfortable environment for patients, health care workers, and visitors while diluting, capturing and exhausting airborne contaminants including potentially infectious airborne agents such as M. tuberculosis. Without high-quality ventilation in health care facilities, patients, health care workers, and visitors can become exposed to contaminants through normal respiration of particles in the air. Poorly ventilated health care facilities may increase the concentration of airborne contaminants including fungi or mold, which may cause allergic responses in even healthy workers and occupants. Some patients are profoundly immunosuppressed for prolonged periods and, if exposed, are highly susceptible to infection from fungi. For such patients, fungal spores become invasive pathogens and lead to high rates of severe morbidity and mortality. For all these reasons, and considering the various occupancies and patient populations, great care must be taken in the design of health care ventilation systems.

1. PURPOSE

The purpose of this standard is to define ventilation system design requirements that provide environmental control for comfort, asepsis, and odor in health care facilities.

2. SCOPE

2.1 The requirements in this standard apply to patient-care areas and related support areas within health care facilities, including hospitals, nursing facilities, and outpatient facilities.

2.2 This standard applies to new buildings, additions to existing buildings, and those alterations to existing buildings that are identified within this standard.

2.3 This standard considers chemical, physical, and biological contaminants that can affect the delivery of medical care to patients; the convalescence of patients; and the safety of patients, health care workers, and visitors.

3. DEFINITIONS

absorption distance: the distance downstream of a humidifier required for all moisture to be absorbed into the airstream.

addition: an extension or increase in floor area or height of a building, building system, or equipment.

airborne infection isolation (AII): the isolation of patients infected with organisms spread by airborne droplet nuclei less than 5 μm in diameter (see FGI [2010] in Informative Appendix B). For the purposes of this standard, the abbreviation "AII" refers to the room that provides isolation.

airborne infection isolation room: a room that is designed according to the requirements of this standard and that is intended to provide airborne infection isolation.

alteration: a significant change in the function or size of a space, in the use of its systems, or in the use of its equipment, either through rearrangement, replacement, or addition. Routine maintenance and service shall not constitute an alteration.

authority having jurisdiction: the agent or agency responsible for enforcing this standard.

average velocity: the volumetric flow rate obtained by dividing the air quantity issuing from an air distribution device by the nominal face area of the device.

building: a structure that is wholly or partially enclosed within exterior walls and a roof, or within exterior and party walls and a roof, and that affords shelter to persons, animals, or property. In this standard, a building is a structure intended for use as a hospital or health care facility.

classification of surgeries:

procedure room (Class A surgery): provides minor surgical procedures performed under topical, local, or regional anesthesia without preoperative sedation. Excluded are intravenous, spinal, and epidural procedures, which are Class B or C surgeries.

operating room (Class B surgery): provides minor or major surgical procedures performed in conjunction with oral, parenteral, or intravenous sedation or performed with the patient under analgesic or dissociative drugs.

operating room (Class C surgery): provides major surgical procedures that require general or regional block anesthesia and/or support of vital bodily functions.

(For more information on this method of classifying surgeries, see ACS (2000) in Informative Appendix B.)