



ANSI/ASHRAE/IESNA Standard 90.1-1999
(with minor editorial changes)

ASHRAE[®] STANDARD

Energy Standard for Buildings Except Low-Rise Residential Buildings

I-P Edition

Approved by the ASHRAE Standards Committee June 19, 1999;
by the ASHRAE Board of Directors June 24, 1999; and by the
American National Standards Institute April 4, 2000.

This standard has been superseded by ANSI/ASHRAE/IESNA Standard 90.1-2001, which is under continuous maintenance and for which the Standards Committee has established a documented program for action on requests for change. Information on that standard, as well as forms for proposing changes, may be obtained from ASHRAE's Internet Home Page, <http://www.ashrae.org>. The latest edition of an ASHRAE standard and printed copies of a public review draft may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in U.S. and Canada).

©Copyright 1999 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



Jointly sponsored by



The
LIGHTING
AUTHORITY

**Illuminating
Engineering Society
of North America**

120 Wall Street, 17th Floor, New York, NY 10005-4001

**AMERICAN SOCIETY OF HEATING,
REFRIGERATING AND
AIR-CONDITIONING ENGINEERS, INC.**

1791 Tullie Circle, NE · Atlanta, GA 30329

ASHRAE/IESNA Standard Project Committee 90.1–1999
Cognizant TC: TC 9.6, Systems Energy Utilization
Standards Project Committee Liaison: Mark C. Hegberg

Ronald E. Jarnagin, <i>Chair*</i>	Adam Hinge*	David Ranieri
Lawrence G. Spielvogel, <i>Vice-Chair*</i>	John F. Hogan*	Jose A. Reig
Safiruddin M. Adeni*	John K. Holton	Robert D. Ross*
Lindsay Audin	William G. Holy*	Robert A. Rundquist
Donald L. Beaty*	Joseph G. Howley, Jr.*	Daniel M. Sander
Richard L. Beck, Jr.	Graham C. Hunter, II*	Dale Sartor
James R. Benya	Mark C. Hydeman*	Michael C.A. Schwedler*
Dwight A. Beranek	R. Gerald Irvine*	Stephen V. Skalko*
Stephen G. Braun	J. Delaine Jones*	T. Kenneth Spain*
Harvey J. Bryan	Hyman M. Kaplan*	Frank A. Stanonik*
Mark L. Bulger	Stephen D. Kennedy*	Donald F. Steiner*
Joseph Canal*	David E. Knebel	Bodh R. Subherwal*
R.L. Douglas Cane	David L. Ledvinka	Marc C. Sullivan*
Carol Chaffee	Jo Anne Lindsey	L. Scott Taylor
Charles N. Claar*	Harry R. Lobdell	Steven T. Taylor
Roy Crane	Kenneth R. Luther*	Jason R. Theios
Drury B. Crawley	Douglas E. Mahone*	Joseph E. Thompson, III*
Harold L. Crowder, Jr.*	R. Michael Martin*	Cedric S. Trueman*
Joseph J. Deringer	R. Christopher Mathis*	Martha G. Van Geem
Barry G. Donaldson	Scott L. Matthews	R. Neil Walker
Paul J. DuPont	Merle F. McBride	McHenry Wallace, Jr.*
Charles Eley*	Tim Michels	Richard D. Watson*
Keith I. Emerson	Frank Myers*	John L. Weidt
Richard E. Ertinger	Steven M. Nadel*	Michael J. Weix
Charles F. Foster, III*	Ronald G. Nickson*	Lawrence R. Wethje*
James A. Garrigus*	Tony Novo	Jerry W. White, Jr.*
Magdalena Gociman*	John G. Perry	Bruce A. Wilcox*
David B. Goldstein	David C.J. Peters	Robin Wilson*
James W. Griffith	James S. Peters	Michael W. Woodford
Gerald C. Groff	William R. Prindle*	Thomas P. Wutka
Ashok Gupta*	James A. Ranfone*	James M. Yorgey

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 1998-99

Michael R. Bilderbeck, *Chair*

Arthur E. McIvor, *Vice-Chair*

George F. Carscallen

Waller S. Clements

Piotr A. Domanski

Richard A. Evans

Mark C. Hegberg

Martha J. Hewett

John F. Hogan

Frederick H. Kohloss

William J. Landman

Rodney H. Lewis

Nance C. Lovvorn

Amanda Meitz

Davor Novosel

Joseph A. Pietsch

James A. Ranfone

Gaylon Richardson

Ganesan Sundaresan

Thomas E. Watson

Bruce A. Wilcox

J. Richard Wright

James E. Woods, *BOD ExO*

Ronald P. Vallort, *CO*

Claire Ramspeck, *Manager of Standards*

NOTE

This standard is under continuous maintenance. Future changes to the standard will be posted on the ASHRAE Home Page at www.ashrae.org/STANDARDS/standa.htm.

SPECIAL NOTE

This standard was developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

When addenda or interpretations to this standard have been approved, they can be downloaded free of charge from the ASHRAE Home Page at www.ashrae.org/STANDARDS/addenda.htm or www.ashrae.org/STANDARDS/intpstd.htm.

© Copyright 2000 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.
1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org

All rights reserved.

CONTENTS

ASHRAE/IESNA 90.1-1999 Energy Standard for Buildings Except Low-Rise Residential Buildings

SECTION	PAGE
Forward.....	2
1 Purpose	3
2 Scope.....	3
3 Definitions, Abbreviations, and Acronyms	3
4 Administration and Enforcement.....	15
5 Building Envelope	17
6 Heating, Ventilating, and Air-Conditioning	25
7 Service Water Heating.....	46
8 Power.....	48
9 Lighting	48
10 Other Equipment.....	55
11 Energy Cost Budget Method.....	55
12 Normative References	62
<i>Normative Appendices (these sections are normative and part of this standard)</i>	
Appendix A: Assembly U-Factor, C-Factor, and F-Factor Determinations.....	63
Appendix B: Building Envelope Criteria.....	90
Appendix C: Method for Building Envelope Trade-Off Option in Subsection 5.4	117
Appendix D: Climate Data	126
<i>Informative Appendix (this appendix is informative and not part of this standard)</i>	
Appendix E: Informative References	160

(This forward is not part of this standard but is included for information purposes only.)

FORWARD

Initial development of *ASHRAE/IESNA Standard 90.1-1999* began in early 1990 following the publication of *ASHRAE/IESNA Standard 90.1-1989*. A group consisting of the existing project committee members and other interested persons sat down to begin mapping out a strategy for the development of the successor to the 1989 standard. Drawing upon the lessons learned from the recently completed 1989 standard, this group identified the need for a consistent approach to be used in evaluating criteria for the next version of the standard. Two key decisions were reached by this group: (1) economics should be used as the basis for informing the professional judgment of the project committee in setting the criteria, and (2) all sections of the new standard should apply the economic approach as consistently as possible to ensure that the standard was balanced among the respective sections (e.g., envelope, lighting, mechanical).

A Criteria Development Panel was formed from members of the project committee to formulate the details of the standards development approach. The Criteria Development Panel produced a simplified National Energy Model (NEM) that was used to estimate the potential energy-saving impacts of a new standard as a function of the economic parameters chosen by the project committee. Based on the work of the Criteria Development Panel, the committee reached a consensus decision on the target level of economics for the new standard, as well as an optional higher alternate level of efficiency. Each of these target efficiency levels included a corresponding savings goal based on runs from the NEM.

Subsequently, the project committee began development of a new standard using the consensus economics as a guiding principle. Each major section of the standard was developed by individual subcommittees, which were free to apply the economic approach in a fashion deemed most appropriate to the building components and systems within their purview.

This effort resulted in the project committee's approval of the first public review draft of the revised standard in December 1995. The public review period for the first public review draft closed in June 1996. The first public review draft received a substantial number of public comments, primarily from certain manufacturing and utility interests.

The project committee decided to completely revise the proposed standard and approved a second public review draft in March 1997. The public review period for the second public review draft closed in March 1998, and this draft also received a large number of comments, primarily from two major groups (utility and environmental interests). A final round of Independent Substantive Change proposals were issued to attempt to resolve the remaining comments, and the project committee voted for final approval of the standard at the ASHRAE Annual Meeting in June 1999 at Seattle. At that time the project committee also recommended changing the method of maintenance of Standard 90.1 from periodic maintenance to continuous maintenance.

ASHRAE/IESNA Standard 90.1-1999 contains numerous improvements over the 1989 version, including enhancements in energy efficiency levels; an expanded scope to include existing buildings; an entire document written in mandatory, enforceable language suitable for code adoption; availability in both IP and SI units to meet national and international needs; expanded climatic data and range of requirements to address international needs; simplification of efficiency requirements; true prescriptive options for all components in addition to performance-based approaches; and many other changes. The popular ENVSTD Envelope Tradeoff Software first introduced with the 1989 edition of Standard 90.1 has been updated to a Windows version and will be included with a revised Users Manual to support implementation and use of *ASHRAE/IESNA Standard 90.1-1999*.

This new energy standard represents ASHRAE's entry into the next millennium by providing a document that is both maintainable and ready for use by the many end users in the code community.

1. PURPOSE

The purpose of this standard is to provide minimum requirements for the energy-efficient design of buildings except low-rise residential buildings.

2. SCOPE

2.1 This standard provides

- (a) minimum energy-efficient requirements for the design and construction of
 - 1. new buildings and their systems,
 - 2. new portions of buildings and their systems, and
 - 3. new systems and equipment in existing buildings and
- (b) criteria for determining compliance with these requirements.

2.2 The provisions of this standard apply to

- (a) the envelope of buildings, provided that the enclosed spaces are
 - 1. heated by a heating system whose output capacity is greater than or equal to 3.4 Btu/h-ft² or
 - 2. cooled by a cooling system whose sensible output capacity is greater than or equal to 5 Btu/h-ft², and
- (b) the following systems and equipment used in conjunction with buildings:
 - 1. heating, ventilating, and air conditioning,
 - 2. service water heating,
 - 3. electric power distribution and metering provisions,
 - 4. electric motors and belt drives, and
 - 5. lighting.

2.3 The provisions of this standard do not apply to

- (a) single-family houses, multi-family structures of three stories or fewer above grade, manufactured houses (mobile homes), and manufactured houses (modular),
- (b) buildings that do not use either electricity or fossil fuel, or
- (c) equipment and portions of building systems that use energy primarily to provide for industrial, manufacturing, or commercial processes.

2.4 Where specifically noted in this standard, certain other buildings or elements of buildings shall be exempt.

2.5 This standard shall not be used to circumvent any safety, health, or environmental requirements.

3. DEFINITIONS, ABBREVIATIONS, AND ACRONYMS

3.1 General

Certain terms, abbreviations, and acronyms are defined in this section for the purposes of this standard. These definitions are applicable to all sections of this standard. Terms that are not defined shall have their ordinarily accepted meanings within the context in which they are used. Ordinarily accepted meanings shall be based upon American standard English

language usage as documented in an unabridged dictionary accepted by the adopting authority.

3.2 Definitions

above-grade wall: see *wall*.

access hatch: see *door*.

addition: an extension or increase in floor area or height of a building outside of the existing building envelope.

adopting authority: the agency or agent that adopts this standard.

alteration: a replacement or addition to a building or its systems and equipment; routine maintenance, repair, and service or a change in the building's use classification or category shall not constitute an alteration.

annual fuel utilization efficiency (AFUE): an efficiency descriptor of the ratio of annual output energy to annual input energy as developed in accordance with the requirements of U.S. Department of Energy (DOE) 10CFR Part 430.

application part-load value (APLV): a single number part-load efficiency figure of merit calculated in accordance with the method described in ARI Standard 550 or 590 referenced to modified rating conditions described in those standards.

attic and all other roofs: see *roof*.

authority having jurisdiction: the agency or agent responsible for enforcing this standard.

automatic: self-acting, operating by its own mechanism when actuated by some nonmanual influence, such as a change in current strength, pressure, temperature, or mechanical configuration. (See *manual*.)

automatic control device: a device capable of automatically turning loads off and on without manual intervention.

ballast: a device used in conjunction with an electric-discharge lamp to cause the lamp to start and operate under the proper circuit conditions of voltage, current, wave form, electrode heat, etc.

(a) **electronic ballast:** a ballast constructed using electronic circuitry.

(b) **hybrid ballast:** a ballast constructed using a combination of magnetic core and insulated wire winding and electronic circuitry.

(c) **magnetic ballast:** a ballast constructed with magnetic core and a winding of insulated wire.

below-grade wall: see *wall*.

boiler: a self-contained low-pressure appliance for supplying steam or hot water.