



STANDARD

ANSI/ASHRAE Standard 111-2008 (RA 2017)
(Supersedes ANSI/ASHRAE Standard 111-2008)

Measurement, Testing, Adjusting, and Balancing of Building HVAC Systems

Approved by ASHRAE on October 31, 2017, and by the American National Standards Institute on November 1, 2017.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2017 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 170

Cognizant TC: 9.6, Healthcare Facilities

SPLS Liaison: H. Michael Newman

Richard D. Hermans*, *Chair*
Paul T. Ninomura*, *Vice-Chair*
Michael F. Mamayek*, *Secretary*
Theodore Cohen*
George A. Freeman
Gerald L. Hendrickson
Michael R. Keen*

William M. Kingrey
Marvin L. Kloostra*
Frederick H. Kohloss
Peter Hogan Langowski*
Michael Mayo
Anand K. Seth*
Rajendra N. Shah*

Dennis E. Shaughnessy
Michael Patrick Sheerin*
Robert J. Weber
Michael E. Woolsey*
Xudong Yang

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2017–2018

Steven J. Emmerich, *Chair*
Donald M. Brundage, *Vice-Chair*
Niels Bidstrup
Michael D. Corbat
Drury B. Crawley
Julie M. Ferguson
Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson

Roger L. Hedrick
Rick M. Heiden
Jonathan Humble
Srinivas Katipamula
Kwang Woo Kim
Larry Kouma
Arsen K. Melikov
R. Lee Millies, Jr.
Karl L. Peterman
Erick A. Phelps

David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Richard T. Swierczyna
Jack H. Zarour
Lawrence C. Markel, *BOD ExO*
M. Ginger Scoggins, *CO*

Stephen C. Ferguson, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 111-2008 (RA 2017) Measurement, Testing, Adjusting, and Balancing of Building HVAC Systems

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions and Symbols.....	2
4 Instrumentation.....	3
5 Flow-Measuring and Balancing Devices	15
6 System Effect	19
7 Air System Measurements	25
8 Hydronic Measurements.....	36
9 Air Testing, Adjusting, and Balancing.....	40
10 Hydronic Testing and Balancing.....	47
11 Equipment Field Testing.....	48
12 Reporting Procedures and Forms	51
13 Commissioning for Test and Balances	57
14 References	58
Informative Appendix A: Bibliography.....	58
Informative Appendix B: Sample Specifications	59
Informative Appendix C: System Effect	60
Informative Appendix D: Air Measurements	61
Informative Appendix E: Pumps	81

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2017 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ANSI/ASHRAE Standard 111 was first published in 1988 with the title Practices for Measurement, Testing, Adjusting, and Balancing of Building Heating, Ventilation, Air-Conditioning, and Refrigeration Systems. At the time of publication, the cognizant Technical Committee was TC 9.7, Testing and Balancing, which is now designated as Technical Committee 7.7. In 1992 the TC recommended that the standard be rewritten for testing and balancing in order to update procedures for the industry and to aid design engineers in writing a testing and balancing specification that would encompass the design ramifications of present-day HVAC systems.

Field test results are considered essential to designers, manufacturers, and installers to better enable them to evaluate the results of their design, equipment performance, and installation techniques under actual operating conditions. The 2008 edition of the standard updated the testing procedures for air, hydronics, and control verification; identified new instrumentation used in testing; and incorporated the findings of several research projects that had established new means for testing. The standard was also updated to suggest how the Test and Balance Agency could interface with the Commissioning team.

This current version is a reaffirmation of Standard 111-2008. This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. This version of the reaffirmation has no changes.

This standard covers causes affecting a system's performance. Its intent is to convey the message that field testing can be repeated but will not necessarily provide the accuracy of factory testing. However, when the proper conditions exist—good engineering practices, realistic ratings, and good craftsmanship installation—adequate results can be obtained to satisfy a given set of design conditions within a reasonable set of limitations. Testing and balancing provides the means to determine and monitor system performance and may be utilized repeatedly long after the project is completed.

Testing and balancing reports provide many benefits that can be used

- a. to assist personnel responsible for the efficient operation of HVAC systems;
- b. to provide a record of existing conditions;
- c. to compare periodic tests to original conditions as a way to determine possible system deterioration or reduced efficiency;

- d. to establish operating conditions whenever modifications or changes are made in the HVAC system;
- e. to determine existing conditions for base energy-level calculations used in energy conservation programs;
- f. to create procedures and reports that can be used to verify energy conservation results; and
- g. to provide a comparison of design versus actual field performance.

1. PURPOSE

To provide uniform procedures for measurement, testing, adjusting, balancing, evaluating, and reporting the performance of building heating, ventilating, and air-conditioning systems in the field.

2. SCOPE

2.1 This standard applies to building heating, ventilating, and air-conditioning (HVAC) systems of the air-moving and hydronic types and their associated heat transfer, distribution, refrigeration, electrical power, and control subsystems.

2.2 This standard includes

- a. methods for determining thermodynamic, hydraulic, hydronic, mechanical, and electrical conditions;
- b. methods for determining room air-change rates, room pressurization, and cross contamination of spaces;
- c. procedures for measuring and adjusting outdoor ventilation rates to meet specified requirements; and
- d. methods for validating collected data while considering system effects.

2.3 This standard establishes

- a. minimum system configuration requirements to ensure that the system can be field tested and balanced;
- b. minimum instrumentation required for field measurements;
- c. procedures for obtaining field measurements in HVAC testing and balancing and equipment testing; and
- d. formats for recording and reporting results.

2.4 The field data collected and reported under this standard are intended for use by building designers, operators, and users, and by manufacturers and installers of HVAC systems.

3. DEFINITIONS AND SYMBOLS

The following terms are used in this standard as they are defined below. For definitions of other technical terms, refer to the ASHRAE *Terminology of Heating, Ventilation, Air Conditioning, and Refrigeration*.

A_k factor: the effective area of an air terminal, which is equal to the measured airflow rate divided by the velocity reading of a particular instrument used in a prescribed manner.

fan velocity pressure: the velocity pressure corresponding to the average velocity through the fan outlet; the kinetic energy per unit volume of air exiting the fan.