


ANSI/ASHRAE Standard 113-2005
(Supersedes ANSI/ASHRAE Standard 113-1990)



ASHRAE STANDARD

Method of Testing for Room Air Diffusion

This standard was approved by the ASHRAE Standards Committee on June 25, 2005; by the ASHRAE Board of Directors on June 30, 2005; and by the American National Standards Institute on July 1, 2005.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2005 ASHRAE, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE Standard Project Committee 113
Cognizant TC: TC 5.3, Room Air Distribution
SPLS Liaison: Roger L. Hedrick

Mohammad H. Hosni, *Chair**
Takashi Akimoto*
Douglas P. Baker
Fred S. Bauman*
Robert T. Clark*
Daniel Int-Hout, III
Rodney H. Lewis
Frederick A. Lorch*
Kenneth J. Loudermilk*
Arsen Krikor Melikov*
Paul L. Miller, Jr.

Bjarne W. Olesen
Rajendra N. Shah*
Jerry M. Sipes*
Jack L. Stegall*
Harold E. Straub*
Richard T. Swierczyna*
Shin-Ichi Tanabe*
Paul R. Vandermeulen*
William J. Waeldner*
Jianshun S. Zhang*
Alexander M. Zhivov*

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2004-2005

Dean S. Borges, *Chair*
Richard D. Hermans, *Vice-Chair*
Donald B. Bivens
Paul W. Cabot
Hugh F. Crowther
Brian P. Dougherty
Hakim Elmahdy
Matt R. Hargan
Roger L. Hedrick
John F. Hogan
Frank E. Jakob
Stephen D. Kennedy

David E. Knebel
James D. Lutz
Merle F. McBride
Mark P. Modera
Cyrus H. Nasser
Davor Novosel
Stephen V. Santoro
Gideon Shavit
David R. Tree
Bede Wellford
James E. Woods
Michael F. Beda, *BOD ExO*
William A. Harrison, *CO*

Claire B. Ramspeck, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 113-2005 Method of Testing for Room Air Diffusion

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Classification of Parameters	3
5 Instruments and Apparatus	3
6 Test Conditions and Procedures.....	4
7 Measurements and Measurement Locations	5
8 Report.....	5
9 References	5
Appendix A: Data Collection and Recommended Calculations.....	6
Appendix B: Rating Methods	7
Appendix C: Example Calculations.....	9
Appendix D: Compliance	10
Appendix E: Bibliography	10

NOTE

When interpretations or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at <http://www.ashrae.org>.

© Copyright 2005 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.
1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org

All rights reserved.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This revision of Standard 113-1990 updates and reorganizes the standard in several ways. Section 5, "Instruments and Apparatus," has been updated and expanded to include different equipment for measuring air velocity and air temperature and for determining velocity characteristics. The Air Diffusion Performance Index (ADPI) rating method has been moved to Appendix B and an additional rating method, the Draft Rating Method, has been added. The information on data collection and calculations has been moved to Appendix A, and detailed examples for each calculation method are added in Appendix C to assist users.

Standard 113 defines a method of testing for air diffusion performance in the occupied zones of building spaces (e.g., offices). The method is designed for use in both prototype and field installations.

1. PURPOSE

The purpose of this standard is to define a repeatable method of testing the steady-state air diffusion performance of an air distribution system in occupied zones of building spaces. This method is based on air velocity and air temperature distributions at specified heating or cooling loads and operating conditions.

2. SCOPE

2.1 This standard specifies equipment and procedures for measuring air speed and air temperature in occupied zones of building spaces.

2.2 This standard applies to furnished or unfurnished spaces (actual or mock-up), with or without occupants.

2.3 This standard applies to air distribution systems, including systems in which:

- (a) air outlets are located inside, inside and outside, or outside of the occupied zone and
- (b) local air velocities in the occupied zone are or are not under control by individual occupants.

2.4 This standard does not cover:

- (a) rating of individual air outlets and inlets or
- (b) naturally ventilated building spaces.

3. DEFINITIONS

air delivery rate (Q/A): the air volume flow rate per unit area of the entire floor space being conditioned.

air diffusion: the introduction of air into a building space for the purpose of providing acceptable velocity and temperature distribution in the occupied zone.

air diffusion performance index (ADPI): a single number rating of the air diffusion performance of a mixing system at specified supply air conditions and space cooling load. ADPI is based on air speed and effective draft temperature (see Section B.1 in Appendix B).

air distribution: the delivery of air through ducts or plenums.

air outlet: any device for supplying air to a space, such as a diffuser, a grille, or a register.

air inlet: any device through which air is removed from a conditioned space.

air temperature (t): the temperature of the air measured at a test point.

average air outlet speed, (V_o): the time-averaged speed of the air from each individual supply air outlet.

average supply air outlet temperature (t_{dc}): the average value of the individual corrected supply air outlet temperatures, measured at the same time as each of the test position measurements.

average test zone air temperature (t_a): the average of all corrected air temperatures within the test zone (see Section A.2 in Appendix A).

clear zone: When outlets are placed within or near the test zone, a clear zone is defined as the space around the outlet within which long-term occupancy is not recommended.

control temperature: the temperature at the location of the test zone controlling device (e.g., a room thermostat).

corrected air temperature (t_{acn}): the temperature at a test point, *n*, corrected for room temperature swing (see Section A.1 in Appendix A).

design temperature: the specified desired temperature of the test zone.

displacement ventilation (DV) system: a type of air distribution system, used only for cooling purposes, in which air at a temperature below room temperature is supplied to the floor level at a low discharge velocity [<100 fpm (0.5m/s)] and is returned near ceiling level. Thermal plumes that develop over heat sources in the room drive the overall floor-to-ceiling air motion, producing a stratified environment with cooler and fresher air near the floor and warmer and less fresh air near the ceiling (see Section B.2 in Appendix B).

draft: an unwanted local cooling of the body caused by air movement.

draft rating index (DR): an index that establishes a quantitative prediction of the percentage of occupants dissatisfied due to draft.

effective draft temperature (θ): a calculated temperature difference that combines air temperature difference and measured air speed at each test point (see Section A.3 in Appendix A).

interior zone: any space not affected by exterior loads.

mixing system: a type of air distribution system in which conditioned air is delivered to the space at a velocity sufficient to promote complete mixing of supply air with room air, thereby maintaining the entire volume of air in the space at a relatively uniform temperature, humidity, and air-quality