ANSI/ASHRAE Standard 133-2008 (Supersedes ANSI/ASHRAE Standard 133-2001)



ASHRAE STANDARD

Method of Testing Direct Evaporative Air Coolers

Approved by the ASHRAE Standards Committee on June 21, 2008; by the ASHRAE Board of Directors on June 25, 2008; and by the American National Standards Institute on June 26, 2008.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2008 ASHRAE

ISSN 1041-2336



American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE, Atlanta, GA 30329 www.ashrae.org

ASHRAE Standard Project Committee 133 Cognizant TC: TC 5.7, Evaporative Cooling SPLS Liaison: Byron W. Jones

Patricia Thomas Graef, Chair *

Branislav Korenic*

Gursaran D. Mathur*

Roy T. Otterbein*

Leon Shapiro*

Michael S. Sherber*

*Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2007–2008

Stephen D. Kennedy, *Chair* Hugh F. Crowther, *Vice-Chair*

Robert G. Baker Michael F. Beda Donald L. Brandt Steven T. Bushby Paul W. Cabot Kenneth W. Cooper Samuel D. Cummings, Jr.

K. William Dean Robert G. Doerr Roger L. Hedrick Eli P. Howard, III Frank E. Jakob Nadar R. Jayaraman
Byron W. Jones
Jay A. Kohler
James D. Lutz
Carol E. Marriott
R. Michael Martin
Merle F. McBride
Frank Myers
H. Michael Newman
Lawrence J. Schoen
Bodh R. Subherwal
Jerry W. White, Jr.
Bjarne W. Olesen, BOD ExO
Lynn G. Bellenger, CO

Claire B. Ramspeck, Assistant Director of Technology for Standards and Special Projects

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 133-2008 Method of Testing Direct Evaporative Air Coolers

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions and Acronyms	2
4 Symbols and Subscripts	3
5 Requirements	4
6 Instruments and Methods of Measurement	4
7 Equipment and Setup	5
8 Data to be Recorded	6
9 Calculations	6
10 Performance Corrections to Nominal or Standard Airflow Rate and Speed	8
11 Report and Results of Test	8
12 Figures	9
13 References	11
Informative Appendix A: Bibliography	11
Informative Appendix B: Additional Figures	12

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org.

© Copyright 2008 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE Atlanta, GA 30329 www.ashrae.org All rights reserved. (This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

First published in 2001, Standard 133 provides procedures for testing direct evaporative cooling devices under laboratory conditions to obtain rating information. As an ASHRAE method-of-testing standard, it is intended to offer recommended practices and accurate measurement procedures. In addition, the committee incorporates the effects of ambient conditions, testing error, instrument accuracy, and the need to make certain that no other sources of heat transfer are taking place during the testing.

This revision makes two key changes to Standard 133-2001. First, the difference between the dry-bulb and wet-bulb temperatures has been decreased from 25°F to 20°F (14°C to 11°C). The committee agreed that this would increase the times when testing could be accomplished using unconditioned air and still not reduce the accuracy of the test.

Second, to provide better flexibility, temperature measurement in Section 6.1.1 is no longer limited to specific types of instruments as long as they meet the requirements of ANSI/ASHRAE Standard 41.1, Standard Method for Temperature Measurement.

Various other improvements were made as well. All references were updated to the latest editions. Mandatory language was clarified by changing "will" to "shall."

1. PURPOSE

This standard establishes a uniform method of laboratory testing for rating packaged and component direct evaporative air coolers.

2. SCOPE

- **2.1** The scope of this standard covers a method of testing for rating the saturation effectiveness, airflow rate, and total power of packaged and component direct evaporative air coolers.
- **2.2** Covered tests also include the methods for measuring the static pressure differential of the direct evaporative air cooler, density of the air, and speed of rotation of the fan.
- **2.3** This standard requires that packaged and component direct evaporative air coolers be simultaneously tested for airflow, total power, and saturation effectiveness.
- **2.4** The ratings resulting from application of this standard are intended for use by manufacturers, specifiers, installers, and users of evaporative air cooling apparatus for residential, commercial, agricultural, and industrial ventilation; for air

cooling applications; and for commercial, industrial, and agricultural processing applications.

3. DEFINITIONS AND ACRONYMS

adiabatic saturation: evaporating water into air without external gain or loss of heat. Sensible heat in both air and water becomes latent heat in evaporated vapor. The air is cooled and humidified.

appurtenance device power: the electric power to drive accessories, not including fans, pumps, or rotary devices, supplied as a standard component of the production model of the evaporative cooling unit (ECU) and the appurtenances that are necessary for, contribute to, or enhance the cooling capacity of the ECU. Appurtenance device power includes, but is not limited to, water metering devices, conductivity controllers, timers, dump cycle pumps, and solenoids. Devices such as thermostats, transformers providing low voltage to control mechanisms, and freeze protection devices shall not be included.

boundaries: evaporative cooling unit inlet and outlet boundaries are defined as the interface between the cooling unit and the remainder of the system, and these boundaries are at a plane perpendicular to the airstream where it enters or leaves the ECU. Various appurtenances, such as filter media assemblies, inlet boxes, inlet vanes, inlet cones, silencers, screens, rain hoods, dampers, discharge cones, eaves, that are supplied as standard components to the unit shall be included as a part of the cooling unit between the inlet and outlet boundaries.

component direct evaporative cooler: a self-contained cabinet without a fan whose primary functions are (1) the conversion of the sensible heat of unsaturated air passing through the cabinet to latent heat by the process of evaporating recirculating or non-recirculating water directly exposed to this air, and (2) the movement of this air through the cabinet that allows a portion of this water to evaporate. An example of a component direct evaporative cooler is shown in Appendix B, Figure B-7.

determination: a complete set of measurements for a particular point of operation of an ECU. The measurements shall be sufficient to determine all ECU performance variables as defined in this standard.

ECU: an acronym created for use in this document that stands for *evaporative cooling unit*. The term *cooling unit* is also used interchangeably throughout this document for evaporative cooling unit, evaporative air cooler, and evaporative cooler.

ECU airflow rate: the volumetric airflow rate based upon entering air density.

ECU outlet area: the gross inside area measured in the plane(s) of the outlet opening(s).

ECU static pressure differential: the static pressure differential measured across the ECU and its appurtenances at each point of operation.