



STANDARD

ANSI/ASHRAE Standard 135.1-2013

(Supersedes ANSI/ASHRAE Standard 135.1-2011)

Includes ANSI/ASHRAE Addenda listed in the History of Revisions

Method of Test for Conformance to BACnet[®]

See the History of Revisions at the back of this standard for approval dates of addenda.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website (www.ashrae.org) or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2013 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 135
Cognizant TC: TC 1.4, Control Theory and Application
SPLS Liaison: Richard L. Hall

Carl Neilson, *Chair*
Bernhard Isler, *Vice-Chair*
Michael Osborne, *Secretary*
Donald P. Alexander
Barry B. Bridges
Clifford H. Copass
Sharon E. Dinges

Stephen T. Karg
Simon Lemaire
J. Damian Ljungquist
John J. Lynch
David Robin
Frank Schubert
Ted Sunderland

William O. Swan, III
David B. Thompson
Stephen J. Treado
Klaus Wagner
J. Michael Whitcomb
Grant N. Wichenko
Christoph Zeller

ASHRAE STANDARDS COMMITTEE 2013–2014

William F. Walter, *Chair*
Richard L. Hall, *Vice-Chair*
Karim Amrane
Joseph R. Anderson
James Dale Aswegan
Charles S. Barnaby
Steven F. Bruning
John A. Clark
Waller S. Clements

David R. Conover
John F. Dunlap
James W. Earley, Jr.
Steven J. Emmerich
Julie M. Ferguson
Krishnan Gowri
Cecily M. Grzywacz
Rita M. Harrold
Adam W. Hinge
Debra H. Kennoy

Malcolm D. Knight
Rick A. Larson
Mark P. Modera
Cyrus H. Nasser
Janice C. Peterson
Heather L. Platt
Douglas T. Reindl
Julia A. Keen, *BOD ExO*
Thomas E. Werkema, Jr., *CO*

Stephanie C. Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

CLAUSE	PAGE
1. PURPOSE	1
2. SCOPE	1
3. DEFINITIONS	1
4. ELECTRONIC PICS FILE FORMAT	1
4.1 Character Encoding	1
4.2 Structure of EPICS Files	2
4.3 Character Strings	3
4.4 Notational Rules for Parameter Values	3
4.5 Sections of the EPICS File	4
5. EPICS CONSISTENCY TESTS	23
6. CONVENTIONS FOR SPECIFYING BACnet CONFORMANCE TESTS	24
6.1 TCSL Components	24
6.2 TCSL Statements	25
6.3 Time Dependencies	30
6.4 BACnet References	31
6.5 TD Requirements	31
7. OBJECT SUPPORT TESTS	32
7.1 Read Support for Properties in the Test Database	32
7.2 Write Support for Properties in the Test Database	33
7.3 Object Functionality Tests	36
8. APPLICATION SERVICE INITIATION TESTS	152
8.1 AcknowledgeAlarm Service Initiation Tests	152
8.2 ConfirmedCOVNotification Service Initiation Tests	153
8.3 UnconfirmedCOVNotification Service Initiation Tests	162
8.4 ConfirmedEventNotification Service Initiation Tests	165
8.5 UnconfirmedEventNotification Service Initiation Tests	199
8.6 GetAlarmSummary Service Initiation Tests	206
8.7 GetEnrollmentSummary Service Initiation Tests	206
8.8 GetEventInformation Service Initiation Tests	208
8.9 LifeSafetyOperation Service Initiation Tests	210
8.10 SubscribeCOV Service Initiation Tests	210
8.11 SubscribeCOVProperty Service Initiation Tests	211
8.12 AtomicReadFile Service Initiation Tests	212
8.13 AtomicWriteFile Service Initiation Tests	213
8.14 AddListElement Service Initiation Tests	214
8.15 RemoveListElement Service Initiation Tests	214
8.16 CreateObject Service Initiation Tests	215
8.17 DeleteObject Service Initiation Tests	216
8.18 ReadProperty Service Initiation Tests	216
8.19 ReadPropertyConditional Service Initiation Tests	218
8.20 ReadPropertyMultiple Service Initiation Tests	219
8.21 ReadRange Service Initiation Tests	221
8.22 WriteProperty Service Initiation Tests	225
8.23 WritePropertyMultiple Service Initiation Tests	227
8.24 DeviceCommunicationControl Service Initiation Tests	230
8.25 ConfirmedPrivateTransfer Service Initiation Test	231
8.26 UnconfirmedPrivateTransfer Service Initiation Test	231
8.27 ReinitializeDevice Service Initiation Tests	232
8.28 ConfirmedTextMessage Service Initiation Tests	232
8.29 UnconfirmedTextMessage Service Initiation Tests	233
8.30 TimeSynchronization Service Initiation Tests	234
8.31 UTCTimeSynchronization Service Initiation Tests	235
8.32 Who-Has Service Initiation Tests	235

8.33	I-Have Service Initiation Tests	236
8.34	Who-Is Service Initiation Tests	236
8.35	I-Am Service Initiation Tests	237
8.36	VT-Open Service Initiation Tests	237
8.37	VT-Close Service Initiation Tests	238
8.38	VT-Data Service Initiation Tests	239
8.39	RequestKey Service Initiation Tests.....	241
8.40	Authenticate Service Initiation Tests.....	242
9.	APPLICATION SERVICE EXECUTION TESTS	246
9.1	AcknowledgeAlarm Service Execution Tests	246
9.2	ConfirmedCOVNotification Service Execution Tests.....	268
9.3	UnconfirmedCOVNotification Service Execution Tests.....	272
9.4	ConfirmedEventNotification Service Execution Tests.....	274
9.5	UnconfirmedEventNotification Service Execution Tests.....	277
9.6	GetAlarmSummary Service Execution Tests.....	277
9.7	GetEnrollmentSummary Service Execution Tests	278
9.8	GetEventInformation Service Execution Tests.....	282
9.9	LifeSafetyOperation Service Execution Test	285
9.10	SubscribeCOV Service Execution Tests	286
9.11	SubscribeCOVProperty Service Execution Tests.....	294
9.12	AtomicReadFile Service Execution Tests	301
9.13	AtomicWriteFile Service Execution Tests	307
9.14	AddListElement Service Execution Tests	318
9.15	RemoveListElement Service Execution Tests.....	320
9.16	CreateObject Service Execution Tests.....	322
9.17	DeleteObject Service Execution Tests.....	327
9.18	ReadProperty Service Execution Tests.....	328
9.19	ReadPropertyConditional Service Execution Tests.....	330
9.20	ReadPropertyMultiple Service Execution Tests	331
9.21	ReadRange Service Execution Tests	339
9.22	WriteProperty Service Execution Tests.....	349
9.23	WritePropertyMultiple Service Execution Tests	354
9.24	DeviceCommunicationControl Service Execution Test.....	362
9.25	ConfirmedPrivateTransfer Service Execution Tests.....	369
9.26	UnconfirmedPrivateTransfer Service Execution Tests.....	370
9.27	ReinitializeDevice Service Execution Tests	370
9.28	ConfirmedTextMessage Service Execution Tests	373
9.29	UnconfirmedTextMessage Service Execution Tests	374
9.30	TimeSynchronization Service Execution Tests	374
9.31	UTCTimeSynchronization Service Execution Tests	375
9.32	Who-Has Service Execution Tests	376
9.33	Who-Is Service Execution Tests.....	383
9.34	VT-Open Service Execution Tests	386
9.35	VT-Close Service Execution Tests.....	387
9.36	VT-Data Service Execution Tests	389
9.37	RequestKey Service Execution Test.....	389
9.38	Authenticate Service Execution Tests	391
9.39	General Testing of Service Execution	395
10.	NETWORK LAYER PROTOCOL TESTS	397
10.1	General Network Layer Tests.....	397
10.2	Router Functionality Tests	398
10.3	Half-Router Functionality Tests	422
10.4	B/IP PAD Tests	429
10.5	Initiating Network Layer Messages.....	431
10.6	Non-Router Functionality Tests	433
10.7	Route Binding Tests	435

10.8	Virtual Routing Functionality Tests	440
11.	LOGICAL LINK LAYER PROTOCOL TESTS	459
11.1	UI Command and Response	459
11.2	XID Command and Response	459
11.3	TEST Command and Response	460
12.	DATA LINK LAYER PROTOCOLS TESTS	462
12.1	MS/TP State Machine Tests	462
12.2	PTP State Machine Tests	526
13.	SPECIAL FUNCTIONALITY TESTS	565
13.1	Segmentation	565
13.2	Time Master	574
13.3	Character Sets	579
13.4	Malformed PDUs	579
13.5	Slave Proxy Tests	581
13.6	Automatic Network Mapping	583
13.7	Automatic Device Mapping	584
13.8	Backup and Restore Procedure Tests	584
13.9	Application State Machine Tests	596
13.10	Workstation Scheduling Tests	597
14.	BACnet/IP Functionality Tests	615
14.1	Non-BBMD B/IP Device	615
14.2	BBMD B/IP Device with a Server Application	617
14.3	Broadcast Distribution Table Operations	621
14.4	Foreign Device Table Operations (Negative Tests)	625
14.5	BACnet Broadcast Management (No Foreign Device Table, No Applications)	626
14.6	Foreign Device Management	628
14.7	Broadcast Management (BBMD, Foreign Devices, Local Application)	632
14.8	Registering as a Foreign Device	640
14.9	Initiating BVLL Service Requests Conveying an NPDU	641
15.	Reporting Test Results	643
	ANNEX A - Example EPICS (INFORMATIVE)	645

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2013 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE and BACnet are registered trademarks of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ANSI is a registered trademark of the American National Standards Institute.

This is a preview of "ANSI/ASHRAE Standard...". [Click here to purchase the full version from the ANSI store.](#)

1. PURPOSE

To define a standard method for verifying that an implementation of the BACnet protocol provides each capability claimed in its Protocol Implementation Conformance Statement (PICS) in conformance with the BACnet standard.

2. SCOPE

This standard provides a comprehensive set of procedures for verifying the correct implementation of each capability claimed on a BACnet PICS including:

- (a) support of each claimed BACnet service, either as an initiator, executor, or both,
- (b) support of each claimed BACnet object-type, including both required properties and each claimed optional property,
- (c) support of the BACnet network layer protocol,
- (d) support of each claimed data link option, and
- (e) support of all claimed special functionality.

3. DEFINITIONS

All definitions from ANSI/ASHRAE Standard 135-2008 also apply to this addendum.

3.1 local network: the network to which a BACnet device is directly connected.

3.2 remote network: a network that is accessible from a BACnet device only by passing through one or more routers.

3.3 test database: a database of BACnet functionality and objects created by reading the contents of an EPICS.

3.4 Abbreviations and Acronyms Used in the Standard

BNF	Backus-Naur Form syntax
EPICS	electronic protocol implementation conformance statement
IUT	implementation under test
TCSL	testing and conformance scripting language
TD	testing device
TPI	text protocol information

4. ELECTRONIC PICS FILE FORMAT

An electronic protocol implementation conformance statement (EPICS) file contains a BACnet protocol implementation conformance statement expressed in a standardized text form. EPICS files are machine and human readable representations of the implementation of BACnet objects and services within a given device. EPICS files shall use the extension ".TPI" (text protocol information) and contain normal editable text lines consisting of text character codes ending in carriage return/linefeed pairs (X'0D', X'0A').

EPICS files are used by software testing tools to conduct and interpret the results of tests defined in this standard. An EPICS file shall accompany any device tested according to the procedures of this standard.

4.1 Character Encoding

BACnet provides for a variety of possible character encodings. The character encodings in BACnet fall into three groups: octet streams, double octet streams and quad octet streams. Octet streams represent characters as single octet values. In some cases, such as Microsoft DBCS and JIS C 6226, certain octet values signal that the second octet which follows should be viewed along with the leading octet as a single value, thus extending the range to greater than 256 possible characters. In contrast, double octet streams view pairs of octets as representing single characters. The ISO 10646 UCS-2 encoding is an example. The first or leading octet of the pair is the most significant part of the value. Quad octet streams, such as ISO 10646 UCS-4, treat tuples of four octets at a time as single characters with the first or leading octet being the most significant.