



STANDARD

ANSI/ASHRAE Standard 158.2-2018
(Supersedes ANSI/ASHRAE Standard 158.2-2011)

Methods of Testing Capacity of Refrigerant Pressure Regulators

Approved by ASHRAE on July 31, 2018, and by the American National Standards Institute on August 1, 2018.

ASHRAE® Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2018 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 158.2

Cognizant TC: 8.8, Refrigerant System Controls and Accessories

SPLS Liaison: Erick A. Phelps

Kirk Stifle*, *Chair*
Duane A. Wolf*, *Vice-Chair*

Robert A. Jones, *Secretary**
Mia Daniels*
Clinton D. Finstad*

Richie Mohan*
Vance Payne*

** Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2017–2018

Steven J. Emmerich, *Chair*
Donald M. Brundage, *Vice-Chair*
Niels Bidstrup
Michael D. Corbat
Drury B. Crawley
Julie M. Ferguson
Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson

Roger L. Hedrick
Rick M. Heiden
Jonathan Humble
Srinivas Katipamula
Kwang Woo Kim
Larry Kouma
Arsen K. Melikov
R. Lee Millies, Jr.
Karl L. Peterman
Erick A. Phelps

David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Richard T. Swierczyna
Jack H. Zarour
Lawrence C. Markel, *BOD ExO*
M. Ginger Scoggins, *CO*

Steven C. Ferguson, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 158.2-2018

Methods of Testing Capacity of Refrigerant Pressure Regulators

SECTION	PAGE
Foreword	2
1 Purpose.....	2
2 Scope	2
3 Definitions and Symbols.....	2
4 Instrumentation	3
5 General Piping Specifications	3
6 Data to Be Reported	4
7 Test Conditions	4
8 Test Procedure.....	4
9 Incompressible Flow Regime Capacity Calculations	5
10 Compressible Flow Regime Capacity Calculations.....	6
11 Choked Flow Regime Capacity Calculations	6
12 Normative References.....	6
Informative Appendix A: Bibliography	7
Informative Appendix B: Example Tables, Data Sheets, and Graphs.....	8
Informative Appendix C: Example of Computation to Express Regulator Capacity in Terms of Refrigerating Effect	12

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2018 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This standard was written at the request of the Air Conditioning Heating & Refrigeration Institute (AHRI) to provide a standard method of test for the capacity of refrigerant pressure regulators. AHRI Standard 770, Performance Rating of Refrigerant Pressure Regulating Valves (I-P/2014) and AHRI Standard 771, Performance Rating of Refrigerant Pressure Regulating Valves (SI/2014), require that this standard be used as a method of test for capacity. AHRI will continue to maintain Standard 770/771 as it relates to standard methods of rating refrigerant service pressure regulators. Standard 770/771 may also include information concerning other refrigerant pressure regulator performance characteristics.

This standard provides a means of accurately measuring the refrigerant mass flow capacity of regulators. The flow capacity may be expressed in terms of refrigerating effect with various refrigerants by performing simple thermodynamic computations. Examples of the computations necessary to express regulator capacity in kilowatts (tons) or other appropriate units are included in Informative Appendix C of this standard for the user's convenience.

The basis for the method of testing and calculation of capacity for flow through regulators is a research project (PRF 5233) performed at Ray W. Herrick Laboratories, Purdue University, Lafayette, IN, and sponsored by AHRI. This research followed a study performed at Herrick Laboratories, under the auspices of AHRI, by R.T. McKenzie, J.B. Chad-dock, and W.E. Fontaine between September 1963 and September 1966.

1. PURPOSE

This standard provides methods of determining the mass flow capacity of refrigerant pressure regulators with sufficient accuracy to facilitate proper engineering application of the device in systems operating at various conditions with various refrigerants by

- a. prescribing a method of measuring key flow and gradient characteristics of refrigerant pressure regulators using air or water as the working fluid and
- b. prescribing computational means to enable reliable prediction of refrigerant vapor and liquid mass flow capacity based on the measured flow and gradient characteristics.

2. SCOPE

2.1 This standard applies to *refrigerant pressure regulators* that meet the definition found in Section 3 and that are intended for refrigerant service in applications where only single-phase flow occurs within the regulator.

2.2 This standard is applicable to refrigerant pressure regulators

- a. for use in either liquid or vapor refrigerant applications and
- b. for use with refrigerants deemed suitable according to ANSI/ASHRAE Standard 15, *Safety Standard for Refrigeration Systems*¹ and ANSI/ASHRAE Standard 34, *Designation and Safety Classification of Refrigerants*².

2.3 This standard specifies procedures, apparatus, and instrumentation that will produce capacity and gradient information with sufficient accuracy to support the proper application of the tested regulator.

2.4 This standard does not

- a. specify rating conditions or electrical or mechanical design requirements (rating conditions may be found in ARI Standard 770, *Refrigerant Pressure Regulating Valves*³),
- b. make recommendations for safety, or
- c. specify tests for production, specification compliance, or field testing of regulators.

3. DEFINITIONS AND SYMBOLS

3.1 Definitions

capacity: the mass flow rate of a selected refrigerant that will pass through the regulator at specified conditions.

certified standard instrument: an instrument calibrated by the manufacturer or other reliable agency and certified traceable to the National Institute for Standards and Technology (NIST).

controlled parameter: as used in this standard, this term refers to the system pressure that is regulated by the regulator under test.

controlled parameter change (CPC): the difference between the set point and regulated pressure when the regulator is operating at a specified capacity⁴. (See Informative Appendix A, Figure A-1.)

differential pressure regulator (DPR): a regulator that opens or closes in response to a change in the difference between its inlet and outlet pressures.

direct-operated pressure regulator: a throttling valve of any size that responds directly to changes in its regulated pressure. A change in regulated pressure (CPC) provides all the work necessary to position the closure member of the valve.

flowmeter: a device for determining the mass flow rate through the regulator under test.

gradient: the change in regulated pressure (controlled parameter) required to cause the closure member of a refrigerant pressure regulator to move from its opening point (set point) to a specified flow capacity⁴.

inlet pressure regulator (IPR): a regulator that opens or closes in response to a change in its inlet or upstream pressure.

outlet pressure regulator (OPR): a regulator that opens or closes in response to a change in its outlet or downstream pressure.