



STANDARD

ANSI/ASHRAE Standard 25-2001 (RA 2016)
(Reaffirmation of ANSI/ASHRAE Standard 25-2001)

Methods of Testing Forced Convection and Natural Convection Air Coolers for Refrigeration

Approved by ASHRAE on June 28, 2001, and reaffirmed on December 31, 2015; and by the American National Standards Institute on December 17, 2001, and reaffirmed on December 31, 2015.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2016 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 25
Cognizant TC: TC 8.4, Air-to-Refrigerant Heat Transfer Equipment
SPLS Liaison: William J. Landman

Alfi Helmy Malek, Chair*
Roland A. Ares*
Raynald C. Clarke*
Lowell D. Hettinger*

Daniel E. Kramer*
Michel LeCompte*
Dean R. Peterson*
Gordon B. Struder*
Bodh R. Subherwal*

* Denotes members of voting status when the document was approved for publication.

ASHRAE STANDARDS COMMITTEE 2015–2016

Douglass T. Reindl, *Chair*
Rita M. Harrold, *Vice-Chair*
James D. Aswegan
Niels Bidstrup
Donald M. Brundage
John A. Clark
Waller S. Clements
John F. Dunlap
James W. Earley, Jr.
Keith I. Emerson

Steven J. Emmerich
Julie M. Ferguson
Walter T. Grondzik
Roger L. Hedrick
Srinivas Katipamula
Rick A. Larson
Lawrence C. Markel
Arsen K. Melikov
Mark P. Modera
Cyrus H. Nasser

Heather L. Platt
David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Jack H. Zarour
Julia A. Keen, *BOD ExO*
James K. Vallort, *CO*

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE’s Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 25-2001 (RA 2016), Methods of Testing Forced Convection and Natural Convection Air Coolers for Refrigeration

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Basis of Testing	3
5 Methods of Testing	4
6 Instruments.....	4
7 Apparatus	6
8 Test Procedures	9
9 Data to Be Recorded	10
10 Computations.....	11
11 References	12
Appendix A	12

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2016 ASHRAE

1791 Tullie Circle NE • Atlanta, GA 30329 • www.ashrae.org • All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process.)

FOREWORD

This is a reaffirmation of Standard 25-2001. This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. This version of the reaffirmation has no changes.

1. PURPOSE

This standard

- a. establishes uniform methods of testing for obtaining performance data,
- b. lists and defines the terms used in testing,
- c. specifies data to be recorded and formulas to be used in calculations, and
- d. sets limits and tolerances in testing.

2. SCOPE

This standard prescribes methods of testing the cooling capacities and airflow rates of forced convection and natural convection air coolers for refrigeration. It does not include air coolers of the recirculated primary liquid refrigerant type. It does not include air-conditioning units for which testing methods are given in other standards.

3. DEFINITIONS AND SYMBOLS

3.1 Definitions

air cooler: a factory-made device to transfer heat from a refrigerated space to a refrigerant through the medium of air. Coolers shall consist of the unit as delivered and fitted with the accessories, such as heat exchangers, that are supplied with or as a part of the cooler.

dry-type air cooler: an air cooler wherein heat transfer is not implemented by a liquid spray during the operating period.

external static pressure loss: the static pressure loss resulting from airflow through ductwork and other external elements fitted to the air cooler.

forced circulation-type air cooler: an air cooler with the means to mechanically circulate the air.

free delivery-type air cooler: an air cooler designed to take air from and discharge it into the cooled space without ductwork or other external elements that impose air resistance.

gross total cooling effect: the heat absorbed by the refrigerant. This is the sum of the net total cooling effect and the heat equivalent of the energy required to operate the cooler.

internal static pressure loss: the air pressure loss resulting from airflow through the assembled cooler as supplied from the factory.

latent cooling effect: that portion of the cooling effect that results in water vapor condensation in the air circulating through the cooler.

natural convection-type air cooler: an air cooler that depends on natural convection for air circulation.

net total cooling effect: the refrigeration capacity available for space and product cooling. It is equal to the gross total cooling effect less the heat equivalent of energy required to operate the cooler.

nonvolatile refrigerant: one that remains a liquid during the process of absorbing heat within the air cooler.

preliminary run: successive sets of readings compiled during continuous cooler operation with the objective of establishing a steady-state condition.

pressure-type air cooler: an air cooler designed for use with external elements that impose air resistance.

sensible cooling effect: that portion of the total cooling effect that results in changes in dry-bulb temperature of the air and vapor mixture circulating through the cooler. It is expressed either as net or gross depending on whether the heat equivalent of the energy required to operate the cooler is included or omitted.

sensible heat ratio: the ratio of net sensible cooling effect to the net total cooling effect.

set of readings: a complete series of data, taken as simultaneously as practicable, that includes all the information required for the determination of cooler performance.

spray-type air cooler: an air cooler, with or without cooling surface, fitted to spray liquid continuously into the airstream.

standard conditions: the specific set of conditions listed.

standard rating: air cooler performance at specified standard conditions in ARI or other recognized standards.

test run: successive sets of readings showing that conditions have been maintained within the required limits, compiled during cooler operation at a steady-state condition. A test run must always follow a preliminary run without interruption. Whenever successive readings are not within the required limits, the test run shall be extended until the successive sets of readings are within the required accuracy.

total static pressure loss: the sum of the internal and external static pressure losses.