



STANDARD

ANSI/ASHRAE Standard 41.7-2015 (RA 2018)
(Reaffirmation of ANSI/ASHRAE Standard 41.7-2015)

Standard Methods for Gas Flow Measurement

Approved by ASHRAE on April 30, 2018, and by the American National Standards Institute on May 1, 2018.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2018 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 41
Cognizant TC: 1.2, Instruments and Measurements
SPLS Liaison: John F. Dunlap

John P. Scott, *Chair*^{*†}
Kevin L. Amende*
Erik S. Anderson^{*†}
B. Terry Beck*
Patrick E. Collins*
James L. Douglas^{*†}

Richard L. Hall^{*†}
Mark Kedzierski*
Lloyd Le*
Alexander Leyderman*
Hongmei Liang*
Kevin B. Peck*

Michael Perevozchikov*
Frank J. Spevak*
Christopher G. Stone*
Michael Wegenka^{*†}

* Denotes members of voting status when the document was approved for publication

† Denotes members of Subcommittee 41.7

ASHRAE STANDARDS COMMITTEE 2017–2018

Steven J. Emmerich, *Chair*
Donald M. Brundage, *Vice-Chair*
Niels Bidstrup
Michael D. Corbat
Drury B. Crawley
Julie M. Ferguson
Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson

Roger L. Hedrick
Rick M. Heiden
Jonathan Humble
Srinivas Katipamula
Kwang Woo Kim
Larry Kouma
Arsen K. Melikov
R. Lee Millies, Jr.
Karl L. Peterman
Erick A. Phelps

David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Richard T. Swierczyna
Jack H. Zarour
Lawrence C. Markel, *BOD ExO*
M. Ginger Scoggins, *CO*

Steven C. Ferguson, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 41.7-2015 (RA 2018) Standard Methods for Gas Flow Measurement

SECTION	PAGE
Foreword	2
1 Purpose.....	2
2 Scope.....	2
3 Definitions	2
4 Classifications	2
5 Requirements.....	3
6 Instruments	4
7 Gas Flow Rate Measurement Methods.....	4
8 Uncertainty Requirements.....	12
9 Test Report	12
10 Normative References.....	12
Informative Annex A: Informative References and Bibliography	13
Informative Annex B: An Uncertainty Analysis Example for a Coriolis Flowmeter	14
Informative Annex C: An Uncertainty Analysis Example for a Differential Pressure Flowmeter	18

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2018 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

The 1984 edition of Standard 41.7 was limited to square-edged orifice meters. In the 2015 edition, the scope has been expanded to cover the breadth of gas flow measurement devices used for testing heating, ventilating, air-conditioning, and refrigerating systems and components, and to include field gas flow measurements in addition to laboratory gas flow measurements. This standard meets ASHRAE's mandatory language requirements.

Selecting an appropriate gas flow flowmeter can be a daunting task given the wide variety of operating principles, measurement precision, and costs of commercial products. Whether gas flow measurements are to be taken in a laboratory or in the field, selecting the appropriate meter should be based on the required measurement accuracy. Once a gas flowmeter has been selected, the user may need to consult with the meter manufacturer regarding installation specifics, operating range limits, calibration limits, and other similar specifics in order to obtain the expected measurement accuracy. Safety is an important consideration for all procedures involving gases, particularly regarding flammability, toxicity, and corrosiveness. Safety glasses and other personal protection equipment should be worn.

This is a reaffirmation of Standard 41.7-2015. This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. This version of the reaffirmation has no changes.

1. PURPOSE

This standard prescribes methods for gas flow measurement.

2. SCOPE

This standard applies to laboratory and field gas flow measurement for testing heating, ventilating, air-conditioning, and refrigerating systems and components. This standard is restricted to applications where the entire flow stream of gas enters and exits the gas flowmeter in a gas-only state during data recording with the following exceptions:

- a. This standard does not apply to airflow measurements at pressures within this range: -25 kPa to $+25$ kPa (-100 in. H_2O to $+100$ in. H_2O) referenced to ambient pressure. Those measurements are within the scope of ASHRAE Standard 41.2.
- b. This standard does not apply to fan performance rating airflow measurements. Those measurements are within the scope of ASHRAE Standard 51.

- c. This standard does not apply to gaseous-phase refrigerant mass flow measurements where the gas flow includes circulating lubricant. Those measurements are within the scope of ASHRAE Standard 41.10.

3. DEFINITIONS

The following definitions apply to the terms used in this standard.

accuracy: the degree of conformity of an indicated value to the corresponding true value.

equivalent diameter: the diameter of a circle having the same area as a rectangular area.

error: the difference between the test result and its corresponding true value.

mean, \bar{X}_m : the arithmetic average of N readings.

measurement system: the instruments, signal conditioning systems (if any), and data acquisition system (if any).

precision: the closeness of agreement among repeated measurements of the same characteristic by the same method under the same conditions.

random error, ϵ : the portion of total error that varies randomly in repeated measurements throughout a test process.

sample size, N : the number of individual values in a sample.

systematic error, β : the portion of total error that remains constant in repeated measurements throughout a test process.

test point: a specific set of test operating conditions and tolerances for recording data.

true value: the unknown, error-free value of a test result.

uncertainty: a measure of the potential error in a measurement or experimental result that reflects the lack of confidence in the result to a specified level.

unit under test: equipment that is the subject of the gas flow rates measurements using this standard.

4. CLASSIFICATIONS

4.1 Gas Flow Operating State. Gas flow measurement methods shall be restricted to applications where the entire gas flow stream enters and exits the flowmeter in the vapor-only state during data recording. Trace amounts of liquids shall be less than 1% by mass unless otherwise specified by the flowmeter manufacturer or by the test plan in Section 5.1.

4.2 Gas Flow Measurement Applications. Gas flow measurement applications that are within the scope of this standard shall be classified as one of the following types.

4.2.1 Laboratory Applications. Gas flow measurements under laboratory conditions are engineering development tests or tests to determine product ratings.

Informative Note: Laboratory gas flow measurements tend to use more accurate instruments than field measurements do and tend to meet the instrument manufacturer's installation requirements.