

ANSI/ASHRAE Standard 58-1986 (RA 2009)
Reaffirmation of ANSI/ASHRAE Standard 58-1986 [RA 1999]



ASHRAE STANDARD

Method of Testing for Rating Room Air Conditioner and Packaged Terminal Air Conditioner Heating Capacity

Approved by the ASHRAE Standards Committee on October 25, 1986, and reaffirmed on June 20, 2009; by the ASHRAE Board of Directors on December 12, 1986, and reaffirmed on June 24, 2009; and by the American National Standards Institute on February 18, 1987, and reaffirmed on June 25, 2009.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**
1791 Tullie Circle NE, Atlanta, GA 30329
www.ashrae.org

Standard 58-1986 (RA 2009)
Method of Testing for Rating Room Air Conditioner and
Packaged Terminal Air Conditioner Heating Capacity

ASHRAE Standards Project Committee 58-1986

Ronald R. Huffman, *Chair*

David M. Lapychak

W. Robert Nussdorfer

George J. Premaza

James P. Schafer

Richard F. Sharp

Mark W. Paquette

David A. Didion

Kenneth C. Schaible

L. Andrew Maciula

ASHRAE STANDARDS COMMITTEE 2008–2009

Hugh F. Crowther, *Chair*

Steven T. Bushby, *Vice-Chair*

Robert G. Baker

Michael F. Beda

Donald L. Brandt

Paul W. Cabot

Kenneth W. Cooper

Samuel D. Cummings, Jr.

K. William Dean

Martin Dieryckx

Robert G. Doerr

Allan B. Fraser

Nadar R. Jayaraman

Byron W. Jones

Jay A. Kohler

Carol E. Marriott

Merle F. McBride

Frank Myers

H. Michael Newman

Janice C. Peterson

Douglas T. Reindl

Lawrence J. Schoen

Boggarm S. Setty

Bodh R. Subherwal

William F. Walter

Michael W. Woodford

David E. Knebel, *BOD ExO*

Andrew K. Persily, *CO*

Stephanie Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Assistant Director of Technology for Standards and Special Projects of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

© 2009, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (www.ashrae.org). For personal use only. Additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

ANSI/ASHRAE 58-1986 (RA 2009)
Method of Testing for Rating Room Air Conditioner and
Packaged Terminal Air Conditioner Heating Capacity

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope.....	2
3 Definitions	2
4 Classifications.....	2
5 Instruments	3
6 Apparatus	3
7 Test Procedures	7
8 Data to be Recorded.....	8
9 Calculation of Test Results	8
10 Test Report.....	10
11 References	10
Informative Appendix A, Bibliography	10

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© Copyright 2009 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org
All rights reserved.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

The 1986 standard was approved by the ASHRAE Standards Committee on Oct. 25, 1986; by the ASHRAE Board of Directors on Dec. 12, 1986; and by the American National Standards Institute on Feb. 18, 1987.

The standard was reaffirmed with minor editorial changes by the Standards Committee on Oct. 18, 1988. The ASHRAE Board of Directors approved the reaffirmation on Oct. 26, 1999 and the American National Standards Institute on Oct. 26, 1999.

This is a reaffirmation of Standard 58-1986 (RA 1999). This standard was prepared under the auspices of the American Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE). It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform standards throughout the industry.

This version of the reaffirmation has no updates included other than a revised foreword and Standards Committee roster. A revised version of this standard will be released for public review in the near future.

1. PURPOSE

The purpose of this standard is to prescribe test methods for determining the heating capacities and airflow quantities for room air conditioners and packaged terminal air conditioners equipped with means for room heating.

2. SCOPE

2.1 This standard

- (a) establishes a uniform method of testing for obtaining rating data,
- (b) specifies test equipment for performing such tests,
- (c) specifies data required and calculations to be used, and
- (d) lists and defines the terms used in testing.

2.2 For purposes of this standard, room air conditioners and packaged terminal air conditioners are defined in Section 3, "Definitions."

2.3 This standard does not prescribe methods of testing to obtain cooling capacities of room air conditioners or packaged terminal air conditioners.

3. DEFINITIONS

accuracy of readings: where percentage limits of readings are herein given, the reference basis is the magnitude of the greater quantity measured and not the scale of the instrument.

heat pump room air conditioner/heat pump packaged terminal air conditioner: a room air conditioner or packaged terminal air conditioner that employs a means for reversing the function of the indoor and outdoor coils such that the indoor coil becomes the refrigerating system condenser, allowing for heating of the air in the conditioned space; similarly, the outdoor coil becomes the evaporator, utilizing outdoor air as a source of heat.

heating capacity: the rate, expressed in Btu/h (W), at which the equipment adds heat to the air passing through it under specified conditions of operation.

indoor air-enthalpy test method: a procedure for determining heating capacity in Btu/h (W) that involves measurement of the quality of air entering and leaving and the airflow rate and the air-enthalpy change.

indoor coil: the heat exchanger that removes heat from or adds heat to the conditioned space.

outdoor coil: the heat exchanger that rejects heat to, or absorbs heat from, a source external to the conditioned space.

packaged terminal air conditioner: a factory-selected combination of heating and cooling components, assemblies, or sections, including a primary source of refrigeration and dehumidification, intended to serve an individual room or zone.

qualification test: a procedure employed for verifying the accuracy of the measuring techniques (temperature, airflow rates, duct heat calibration) employed in determination of room heating effect. This qualification procedure is periodically employed in determining room heating effect.

room air conditioner: an encased assembly designed as a unit primarily for mounting in a window, through a wall, or as a console. It is designed primarily to provide free delivery of conditioned air to an enclosed space, room, or zone. It includes a primary source of refrigeration and dehumidification, means for air circulation, air cleaning, and heating, and may include means for ventilation and humidification.

standard air: air having a density of 0.075 lb/ft³ (1.202 kg/m³) and equivalent to dry air at a temperature of 70°F (21.1°C) and a barometric pressure of 29.92 in. Hg (101 kPa).

standard barometric pressure: 29.92 in. Hg (101 kPa).

4. CLASSIFICATIONS

4.1 Two basic types of products are considered in this standard, as seen in the title, scope, and definitions: room air conditioners and packaged terminal air conditioners. For the purpose of conciseness throughout the body of the text, the general term "air conditioner" will be used.

4.2 Two types of heating means commonly are employed in these products: electrical resistance and heat pump (reverse cycle). Additional means include steam and hot water.

4.3 There are two basic methods of testing heat pump units: steady-state (no defrosting) and transient (with defrost cycles required).

4.4 There are two basic heating capacity calculations: the specific heat method for no moisture change and the enthalpy method when moisture is added.